



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBISC-03 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: July 29, 2019
Project Number: PV1805

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-60.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

FEATURES




- Roof curbs sides and ends are 16 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact you York distributor or Provent directly.

STRUCTURALLY CALCULATED VIBRATION ISOLATION ROOF CURBS FOR YORK UNITS

ZR 036-060, XP 036-060, ZF 036-072



PROVENT P/N	A	B	EST. WEIGHT
CBISCSUN367218**	8"	18"	260 Lbs.
CBISCSUN367221**	11"	21"	280 Lbs.
CBISCSUN367224**	14"	24"	300 Lbs.

**Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBISC-03


DATE:
9/27/2018

PART NUMBER:

REV:
1

DRAWN BY:
ALL

STEEL ATTACHMENT



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT


WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL

WELDMENT AND BOLTING DETAIL




BASE CURB SUPPORT

OPTIONAL BOTTOM BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
5/16" $\varnothing$ HOLE USE 1/2" $\varnothing$ A307 BOLT WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" $\varnothing$ HOLE USE 5/8" $\varnothing$ A307 BOLT WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL




Client: ProVent PV1805
Project: CBISC-03 Iso Curb (CBISCUN3672**Upper curb rail)
Unit: ZR 036-060, XP 036-060, ZF 036-072

Curb Information

Hcurb upper = 5.5 in (Height of upper curb rail)
Lcurb = 72 in (Length of curb)
wcurb = 36.25 in (Width of curb)
WGTcurb = 270 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 1

Unit Information

WGTunit = 640 lbs (Weight of Unit)
Wtmax = 234 lbs (Maximum corner weight)
Wtmin = 96 lbs (Minimum corner weight)
Hunit = 32.625 in (Height of unit above curb)
Hcm = 16.3125 in (Height to center of mass)
Lunit = 82.25 in (Length of unit)
Wunit = 44.875 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 1702 lbs (unit only) (0.7*Fpmax)
FpmaxASD = 2421 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 807 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) (Eq. 29.5-2)
Fh ASD long = 440 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
Fvert ASD = 750 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 1359 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 1145 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 269 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 635 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 978 lbs = [FpmaxASD*Hcm+2*(1+0.14*S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 764 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 6 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 372 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1359 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1145 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 978 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 764 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

$F_y = 50$ ksi $F_u = 65$ ksi $t = 0.0713$ 14 Gauge
 $E = 29500$ ksi

Calculate Section Properties of Curb

$A' = 5.500$ in $a = 5.144$ in $= A' - (2r + t)$
 $B' = 1.500$ in $a' = 5.429$ in $= A' - t$
 $C' = 0.000$ in [0 if no lips] $b = 1.322$ in $= B' - [r + t/2 + a(r + t/2)]$
 $a = 0.000$ in [0 - no Lip; 1 w/ lip] $b' = 1.464$ in $= B' - [t/2 + a/2]$
 $R = 0.1069$ (Inside bend radius) $c = 0.000$ in $= a[C' - (r + t/2)]$
 $t = 0.0713$ in $c' = 0.000$ in $= a[C' - t/2]$
 $r' = 0.143$ in $= R + t/2$ $u = 0.224$ in $= \pi r/2$
 $x = 0.261$ in (Distance between centroid and web centerline)
 $I_x = 2.424$ in (Moment of Inertia about X-Axis)
 $I_y = 0.109$ in (Moment of Inertia about Y-Axis)
 $A = 0.59$ in²
 $r_x = 2.03$ in
 $r_y = 0.432$ in
 $r_{min} = 0.432$ in



Axial Compression

$P_u = 0.851$ k (Max Axial Comp) $\Omega_c = 1.80$
 $P_n/\Omega_c = 4.309$ k
 $F_e = 15.06$ ksi $\lambda_c = 1.82$
 $F_n = 13.21$ ksi
 $L_y = 75.00$ in
 $k_y L_y/r_y = 139$

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$

Lateral unbraced length (assume $k=0.8$)

Compression Check = **O.K.**

Check Web Crippling

$h = 5.5$ in $t = 0.0713$ in $N = 7.00$
 $\Omega_w = 1.75$ $P_n = 1.947$ k
 $P_n/\Omega_w = 1.112$ k
Long side: $P_{uTrans} = 0.679$ k
Short side: $P_{uLong} = 0.978$ k

-- Check limits:
 $h/t = 77.14 \leq 200$
 $N/t = 98.18 \leq 210$
 $N/h = 1.273 \leq 2.0$
 $R/t = 1.50 \leq 12.0$

$C = 7.50$
 $C_R = 0.08$
 $C_N = 0.12$
 $C_h = 0.048$

(See table C3.4.1-2, fastened to support, two flange, end loading)

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$

O.K. # clips = 2
O.K. # clips = 1

Check Web Stiffener

N/A
width of stiffener = 7.000 in $t_s = 0.0566$ 16 Gauge
web of stiff. $w = 6.717$ in $R_s = 0.0849$ in
***Check $w/t_s \leq 1.28\sqrt{E/F_y}$ $\Omega_c = 1.70$
 $w/t_s = 118.675$
 $1.28\sqrt{E/F_y} = 31.091$ --> w/t_s over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$
 $P_{wc} = 1.947$ k $A_e = 0.380$ in²
 $P_n = 14.669$ k
 $P_n/\Omega_c = 8.629$ k

Not Req'd

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

$T_{crnmax} = 426$ lbs $Max(F_{pmaxASD}/4 - OR - F_{hASDtrans}/4 \text{ corner connections})$
 $V_{crnmax} = 572$ lbs (Max Ten/2 corner connections per side)
Bolt: $T_{all} = 2480$ lbs $V_{all} = 1096$ lbs
Threaded Insert: $T_{all} = 2860$ lbs $V_{all} = 1714$ lbs
of Bolts required for Tension = 0.2
of Bolts required for Shear = 0.5
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.694 **O.K.** StressComb = 0.347 **O.K.**

***If combined fails:
USE --> 2.0

Check 1/8" welded connection

Assume $L/t > 25$: $25^*t = 1.783$ in $\Omega = 2.35$
 $L_{req'd} = 0.387$ in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in (clip thickness)

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2 F_{u2} \sqrt{t_2^3 d}$

$P_{ns} = 2377$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2377$ #

$P_{ns} = 2.7 t_1 d F_{u1}$

$P_{ns} = 2.7 t_1 d F_{u1}$

$P_{ns} = 2.7 t_2 d F_{u2}$

$P_{ns} = 2.7 t_2 d F_{u2}$

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k [screw pull-out strength]

$P_{not} = 0.85 t_c d F_{u2}$

$P_{nov} = 2.607$ k [screw pull-over strength]

$t_c = \min(t_1, t_2)$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{nov} = 1.5 t_1 d_w F_{u1}$

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

Long side:	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
	1.702	2	0.85	540 #	4	2.00 in
Short side:	1.702	1	1.70	540 #	4	2.00 in

clip width (in) = 7.00

clip height = 2.5 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.416$ in²


$A_{nt} = 0.082$ in²

$R_n/\Omega = 8.674$ k

$R_n = 0.6 F_y A_{gv} + F_y A_{nt} \leq 0.6 F_u A_{nv} + F_u A_{nt}$

[AISI Sect. E5.3]

BSR O.K.



Curb Loads (copied from above)

Transverse:	Comp _{MAX} = 1359 lbs
(on long edge)	Tens _{MAX} = 1145 lbs
	Shear _{MAX} = 851 lbs
Longitudinal:	Comp _{MAX} = 978 lbs
(on short edge)	Tens _{MAX} = 764 lbs
	Shear _{MAX} = 851 lbs

Max compression force on isolator: 0.978 k ≤ 1.660 k **O.K.**

Max uplift on isolator: 0.764 k ≤ 1.660 k **O.K.**

Max shear on isolator: 0.284 k ≤ 0.800 k **O.K.**

Forces on top bolt:

$d_o = 0.375$ in

upper rail, $t = 0.1017$ in

Tension = 0.764 k

Shear = 0.284 k

Shear on curb rail:

$P_n = t_e F_u$

$\Omega = 2.00$

[Appendix A, Section E3.1 AISI]

$P_n/\Omega = 6.611$ k

$e = 1.0$ in

Shear O.K.

Net section rupture:

$P_n = A_n F_t$

$\Omega = 2.22$

[Appendix A, Section E3.2 AISI]

$P_n/\Omega = 7.117$ k

$A_n = 0.165$ in

N.S.R. O.K.

Bolt Bearing Strength:

$P_n = C m_f d t F_u$

$\Omega = 2.50$

[Section E3.3.1 AISI]

$P_n/\Omega = 2.975$ k

$d/t = 3.69$

$C = 3.00$

$m_f = 1.00$

Bearing O.K.

Shear and tension in bolt:

[Appendix A, Section E3.4 AISI]

Tension

$P_{nt} = A_b F_{nt}$

$F_{nt} = 40.5$ ksi

$A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k

Bolt tension O.K.

$\Omega_t = 2.25$

[Table E3.4-1, AISI]

Shear

$P_{nv} = A_b F_{nv}$

$F_{nv} = 24.0$ ksi

$\Omega_v = 2.40$

[Table E3.4-1, AISI]

$P_{nv}/\Omega = 1.104$ k

Bolt shear O.K.

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$

$f_v = 2.57$ ksi

O.K.

Combined Not Applicable


$F'_{nt} = 40.50$ ksi

$F_{nv}/\Omega = 10.00$ ksi

Loads at each Isolator

Type: JQA

Transverse loading:	Comp _{MAX} = 679.3 lbs
(on long edge)	Tens _{MAX} = 572.4 lbs
# isolators: 2	Shear _{MAX} = 283.7 lbs
Longitudinal loading:	Comp _{MAX} = 978.2 lbs
(on short edge)	Tens _{MAX} = 764.4 lbs
# isolators: 1	Shear _{MAX} = 283.7 lbs






Client: ProVent PV1805
Project: CBISC-03 Iso Curb [CBISCUN3672**] Base curb
Unit: ZR 036-060, XP 036-060, ZF 036-072

Curb Information

Hcurb = 25 in (Height of curb)
Lcurb = 75 in (Length of curb)
wcurb = 39.25 in (Width of curb)
WGTcurb = 270 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 1

Unit Information

WGTunit = 640 lbs (Weight of Unit)
Wtmax = 234 lbs (Maximum corner weight)
Wtmin = 96 lbs (Minimum corner weight)
Hunit = 32.625 in (Height of unit above curb)
Hcm = 16.3125 in (Height to center of mass)
Lunit = 82.25 in (Length of unit)
Wunit = 44.875 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 1702 lbs (0.7*Fpmax) FpmaxASD = 2421 lbs (unit and curb)
(unit only)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
FhASDtrans = 1220 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
FhASDlong = 666 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
FvertASD = 750 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 1300 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 1086 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 413 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 779 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 963 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 749 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 51 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 417 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1300 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1086 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 963 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 749 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 **16 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.717 in = A' - (2r + t)
B' = 1.750 in	a' = 24.943 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.609 in = B' - [r + t/2 + a(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.722 in = B' - [t/2 + αt/2]
R = 0.0849 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0566 in	c' = 0.000 in = α[C' - t/2]
r' = 0.113 in = R + t/2	u = 0.178 in = πr/2
x = 0.105 in (Distance between centroid and web centerline)	
I _x = 102.712 in (Moment of Inertia about X-Axis)	
I _y = 0.175 in (Moment of Inertia about Y-Axis)	
A = 1.60 in ²	
r _x = 8.01 in	
r _y = 0.331 in	
r _{min} = 0.331 in	



Axial Compression

P _u = 0.851 k	(Max Axial Comp)	Ω _c = 1.80
P _n /Ω _c = 6.895 k		
F _e = 8.84 ksi	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$	$\lambda_c = \sqrt{\frac{F_y}{F_e}}$
λ _c = 2.38	If λ _c ≤ 1.5; F _n = (0.658 ^{λ_c²) F_y}	$F_e = \frac{\pi^2 E}{(kl/r)^2}$
F _n = 7.75 ksi	If λ _c > 1.5; F _n = $\frac{0.877}{\lambda_c^2} F_y$	
L _y = 75.00 in	Lateral unbraced length	
k _y L _y /r _y = 182	(assume k=0.8)	

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0566 in	h/t = 441.70 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 123.67 ≤ 210	C _N = 0.35	
Q _w = 1.75	N/h = 0.28 ≤ 2.0	C _h = 0.02	
P _n = 1.346 k	R/t = 1.50 ≤ 9.0		
P _n /Q _w = 0.769 k	O.K. # clips = 2	$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Long side: P _{uTrans} = 0.650 k	web stiffener REQ'D # clips = 1		
Short side: P _{uLong} = 0.963 k	***h/t > 200; use web stiffeners		

Check Web Stiffener

width of stiffener = 7.000 in	16Ga x 1.5in x 7in (C-channel)	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in		R _s = 0.0849 in
***Check w/ts ≤ 1.28VE/F _y		Ω _c = 1.70
w/ts = 118.675		
1.28V(E/F _y) = 31.091	--> w/ts over limit Use C3.7.2	
P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}		A _e = 0.380 in ²
P _{wc} = 1.346 k		
P _n = 14.248 k		
P _n /Ω _c = 8.381 k	O.K.	

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{crnmax} = 426 lbs	Max(F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections)
V _{crnmax} = 543 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.2	
# of Bolts required for Shear = 0.5	
# of Bolts Used = 1.0	

***If combined fails:

USE --> 4.0

Check Combined Stress in Bolts & Inserts: 0.667 **O.K.**

StressComb = 0.167 **O.K.**



Check 1/8" welded connection

<--- USE WELD

$\Omega = 2.35$

Assume $L/t > 25$: $25 \cdot t = 1.415$ in
 $L_{req'd} = 0.463$ in

$$P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$$

$$L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$

Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} =	1359	lbs
	Tens _{MAX} =	1145	lbs
	Shear _{MAX} =	851	lbs
Longitudinal: (on short edge)	Comp _{MAX} =	978	lbs
	Tens _{MAX} =	764	lbs
	Shear _{MAX} =	851	lbs

Max compression force on isolator: 0.978 k ≤ 1.600 k **O.K.**
Max uplift on isolator: 0.764 k ≤ 1.600 k **O.K.**
Max shear on isolator: 0.284 k ≤ 1.000 k **O.K.**

Forces on bottom bolts:

$d_b = 0.625$ in
base curb, $t = 0.0566$ in
Tension = 0.382 k / bolt
Shear = 0.142 k / bolt

Shear on base curb: $P_n = t F_u$
 $P_n / \Omega = 3.679$ k

Shear O.K.

Net section rupture: $P_n = A_n F_t$
 $P_n / \Omega = 5.059$ k

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_y d t F_u$
 $P_n / \Omega = 2.663$ k

Bearing O.K.

Shear and tension in bolt:

Tension $P_{nt} = A_b F_{nt}$
 $P_{nt} / \Omega = 6.136$ k
Shear $P_{nv} = A_b F_{nv}$
 $P_{nv} / \Omega = 3.451$ k

$\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $e = 1.0$ in

$\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $A_n = 0.078$ in

$$F_t = (0.1 + 3d/s) F_u \leq F_u = 65.000 \text{ ksi}$$

$\Omega = 2.50$ (Section E3.3.1 AISI)
 $d/t = 11.04$

$C = 2.90$ $m_f = 1.00$

(Appendix A, Section E3.4 AISI)

$F_{nt} = 45.0$ ksi $A_b = 0.3068$ in²

Bolt tension O.K. $\Omega_t = 2.25$

$F_{nv} = 27.0$ ksi $\Omega_v = 2.40$

Bolt shear O.K. ***[Table E3.4-1, AISI]***

$$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$



$f_v = 0.46$ ksi

$F_{nv} / \Omega = 11.25$ ksi

Combined Not Applicable

Loads at each Isolator Type: JQB

Transverse loading: (on long edge)	Comp _{MAX} =	679.3	lbs
	Tens _{MAX} =	572.4	lbs
	Shear _{MAX} =	283.7	lbs
Longitudinal loading: (on short edge)	Comp _{MAX} =	978.2	lbs
	Tens _{MAX} =	764.4	lbs
	Shear _{MAX} =	283.7	lbs



Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX} =	2820	lbs	Shear _{MAX} =	1210	lbs
Compression _{SEISMIC} =	3124	lbs	$= [F_{pmaxASD} (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) (WGT_{unit+curb} / 2) \cdot w_{curb}] / w_{curb}$			
Tension _{SEISMIC} =	2820	lbs	$= Comp_{SEISMIC} - (0.6 - 0.14 S_{DS}) (WGT_{unit+curb})$			
Compression _{WIND} =	1182	lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) + 0.6 (WGT_{unit+curb} / 2) \cdot w_{curb} - F_{vertASD} \cdot w_{curb} / 2] / w_{curb}$			
Tension _{WIND} =	1386	lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) - 0.6 (WGT_{unit+curb} / 2) \cdot w_{curb} + F_{vertASD} \cdot w_{curb} / 2] / w_{curb}$			
Longitudinal:	Uplift _{MAX} =	1605	lbs	Shear _{MAX} =	1210	lbs
Compression _{SEISMIC} =	1909	lbs	$= [F_{pmaxASD} (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) (WGT_{unit+curb} / 2) \cdot L_{curb}] / L_{curb}$			
Tension _{SEISMIC} =	1605	lbs	$= Comp_{SEISMIC} - (0.6 - 0.14 S_{DS}) (WGT_{unit+curb})$			
Compression _{WIND} =	265	lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) + 0.6 (WGT_{unit+curb} / 2) \cdot L_{curb} - F_{vertASD} \cdot L_{curb} / 2] / L_{curb}$			
Tension _{WIND} =	469	lbs	$= [F_{htransASD} (H_{cm} + H_{curb}) - 0.6 (WGT_{unit+curb} / 2) \cdot L_{curb} + F_{vertASD} \cdot L_{curb} / 2] / L_{curb}$			

Wood Attachment:

1/4" ϕ wood lag screws

w/ 3.5" Min. Embed (SGmin = 0.43)

Transverse: $Tall_{metal} = 946.67$ lbs
 $Tall_{wood} = 671.25$ lbs

$Vall_{metal} = 1043.33$ lbs
 $Vall_{wood} = 224$ lbs

of Screws Req'd for Uplift = 4.20

of Screws Req'd for Shear = 5.40

Total # of screws required = 11

COMBINED LOADING: 0.873 O.K.

Req'd Min Spacing = 6.7 in o.c.

Use 11 - 1/4" ϕ wood lag screws @ 6.7 in o.c. along long side of curb w/ 3.5" Min. Embed



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

Longitudinal:

of Screws Req'd for Uplift = 2.39
of Screws Req'd for Shear = 5.40
Total # of screws required = 9

COMBINED LOADING: 0.866 O.K.
Screw Spacing = 3.9 in o.c.

Use 9 - 1/4" ϕ wood lag screws @ 3.9 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse:
Tall_{bolt} = 6903 lbs
of Bolts Req'd for Uplift = 0.41
of Bolts Req'd for Shear = 0.33
Total # of bolts required = 2

Vall_{bolt} = 3682 lbs
COMBINED LOADING: 0.369 O.K.
Bolt Spacing = 63.0 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 63 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.23
of Bolts Req'd for Shear = 0.33
Total # of bolts required = 2

COMBINED LOADING: 0.281 O.K.
Bolt Spacing = 27.3 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 27.3 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7 Ω_o E (Ω_o = 2.5)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs Vall_{LRFD} = 3188 lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
Tall_{ASD} = Tall_{LRFD}/ α = 1026.2 lbs Vall_{ASD} = Vall_{LRFD}/ α = 1704.8 lbs ($D = 0.465$, $E = 0.535$)
Transverse: Uplift_{MAX} = 6642 lbs Shear_{MAX} = 3026 lbs
Compression_{SEISMIC} = 6946 lbs = $[2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$
Tension_{SEISMIC} = 6642 lbs = $Comp_{SEISMIC} - [0.6 - 0.14SDS] \cdot (WGT_{unit+curb})$
Shear_{SEISMIC} = 3026 lbs = $2.5 \cdot F_{pmaxASD} / 2$
Min Bolts Req'd Uplift = 6.47 spacing = 8.50 in o.c. Tapplied = 830.2 lbs
Min Bolts Req'd Shear = 1.77 spacing = 51 in o.c. Vapplied = 378.2 lbs
Try using 8 bolts spaced at 9.00 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.03$

Use 8 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 9 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 3605 lbs Shear_{MAX} = 3026 lbs
Compression_{SEISMIC} = 3909 lbs = $[2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$
Tension_{SEISMIC} = 3605 lbs = $Comp_{SEISMIC} - [0.6 - 0.14SDS] \cdot (WGT_{unit+curb})$
Shear_{SEISMIC} = 3026 lbs = $2.5 \cdot F_{pmaxASD} / 2$
Min Bolts Req'd Uplift = 3.51 spacing = 5.08333 in o.c. Tapplied = 721.1 lbs
Min Bolts Req'd Shear = 1.77 spacing = 15.25 in o.c. Vapplied = 605.2 lbs
Try using 5 bolts spaced at 6.81 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.06$

Use 5 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: (CBISCSUN3: Unit: ZR 036-060, XP 036-060, ZF 036-072)			
UPPER CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: JQB Top stud diameter: 3/8			
Anchor bolt diameter: 5/8 Anchor hole diameter: 11/16			
BASE CURB THICKNESS: 0.0566 in 16 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" ϕ wood lag screws w/ 3.5" Min. Embed (SGmin = 0.43)	1/2" ϕ A307 Bolts to steel angle below deck	3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	11 @ 6.7 in o.c.	2 @ 63 in o.c.	8 @ 9 in o.c.
SHORT DIRECTION	9 @ 3.91 in o.c.	2 @ 27.25 in o.c.	5 @ 6.81 in o.c.