



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120

619-727-4800

**Structural Calculations
for
Vibration Isolation Roof Curb CBISC-07**



Prepared for:

PROVENT

**3847 Wabash Drive
Mira Loma, CA 91725**

Date: August 1, 2019

Project Number: PV1802

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-60.

Welded Isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

FEATURES


- Roof curb base 12 ga.
- Roof curb upper rail 14 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.

VIBRATION ISOLATION ROOF CURBS YORK UNITS


ZF 180




PROVENT P/N	A	B	EST. WEIGHT
CBISCSLU18018**	8"	18"	475 Lbs
CBISCSLU18021**	11"	21"	525 Lbs
CBISCSLU18024**	14"	24"	575 Lbs

**Note: Spring configuration must be added to part number at time of order

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



PROFILE DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91752

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBISC-07


DATE:
01/29/18

PART NUMBER:

REV:

DRAWN BY:
ALL

STEEL ATTACHMENT



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT


WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____


FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL

WELDMENT AND BOLTING DETAIL




BASE CURB SUPPORT

OPTIONAL BOTTOM
BUMPER FOR:
ISCALSLU180
ISCALSLM1830

FOR JQA:
5/16" Ø HOLE USE 1/2" Ø A307 BOLT
WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
1 1/16" Ø HOLE USE 5/8" Ø A307 BOLT
WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL



Client: ProVent PV1802
Project: CBISC-07 curb for ZF180 Unit
Description: Upper curb rail design

Curb Information

Hcurb = 6 in (Height from spring isolator to top of upper rail curb)
Lcurb = 114.75 in (Length of curb)
wcurb = 83.5 in (Width of curb)
WGTcurb = 599.5 lbs (Weight of curb+10% for pitched roof)

Unit Information

WGTunit = 2281 lbs (Weight of Unit + accessories)
Wtmax = 613 lbs (Maximum corner weight)
Wtmin = 528 lbs (Minimum corner weight)
Hunit = 48.625 in (Height of unit above curb)
Hcm = 24.3125 in (Height from top of curb to center of mass of unit)
Lunit = 125.25 in (Length of unit)
Wunit = 92 in (Width of unit)

Seismic Loading - 2015 IBC

Ss = 2.850 (Worst case for majority of CA = Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 6067 lbs (0.7*Fpmax) FpmaxASD = 7662 lbs (unit and curb)
(unit only)

Wind Loading - 2015 IBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.90 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer pg. 309 ASCE 7-10)
GCr(vert) = 1.5 (Refer pg. 309 ASCE 7-10)
qz = 34.4 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
FhASD trans = 1865 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
FhASD long = 1370 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
FvertASD = 2480 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 3319 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2557 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 39 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 1150 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2838 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 2076 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = -214 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 897 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 3319 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2557 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2838 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2076 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.



Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

(curb assumed to be symmetric C-Section without Lips)

A' = 6.000 in
B' = 1.500 in
C' = 0.000 in (0 if no lips)
a = 0.000 in (0 - no Lip; 1 w/ lip)
R = 0.1069 in (Inside bend radius)
t = 0.0713 in
r' = 0.143 in = R+t/2
x = 0.246 in (Distance between centroid and web centerline)
Ix = 2.996 in (Moment of Inertia about X-Axis)
Iy = 0.112 in (Moment of Inertia about Y-Axis)
A = 0.62 in²
rx = 2.19 in
ry = 0.423 in
rmin = 0.423 in

a = 5.644 in = A'-(2r+t)
a' = 5.929 in = A'-t
b = 1.322 in = B'-(r+t/2+a(r+t/2))
b' = 1.464 in = B'-(t/2+at/2)
c = 0.000 in = a[C'-(r+t/2)]
c' = 0.000 in = a[C'-t/2]
u = 0.224 in = $\pi r/2$

Axial Compression

Pu = 3.034 k [Max Axial Comp] $\Omega_c = 1.80$
Pn/ Ω_c = 3.549 k
Fe = 11.70 ksi
 $\lambda_c = 2.07$
Fn = 10.26 ksi
Ly = 83.5 in
 $k_y L_y/r_y = 158$

$P_n = \frac{F_n A}{\Omega_c}$ If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kL/r)^2}$

Lateral unbraced length
(assume k=0.8)

Compression Check = **O.K.**

Check Web Crippling

h = 6 in -- Check limits:
t = 0.0713 in h/t = 84.15 $\leq$ 200
N = 7.00 N/t = 98.18 $\leq$ 210
 $\Omega_w = 1.75$ N/h = 1.167 $\leq$ 2.0
Pn = 1.883 k R/t = 1.50 $\leq$ 12.0
 $P_n/\Omega_w = 1.076$ k
Long side: PuTrans = 1.106 k **web stiffener REQ'D** # clips = 3
Short side: PuLong = 0.946 k **O.K.** # clips = 3

C = 7.50
CR = 0.08
CN = 0.12
Ch = 0.048

[See table C3.4.1-2, fastened to support, two flange, end loading]

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

Check Web Stiffener

16Ga x 3/4in x 7in [C-channel]
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts $\leq$ 1.28VE/Fys $\Omega_c = 1.70$
w/ts = 118.675
1.28v(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_s F_y) \geq P_{wc}$
Pwc = 1.883 k Ae = 0.380 in²
Pn = 14.625 k
Pn/ Ω_c = 8.603 k **O.K.**

Corner Connections

(Use 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded insert)

Tcrnmax = 1517 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1278 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 5000 lbs Vall = 4470 lbs
Threaded Insert: Tall = 4289 lbs Vall = 661 lbs
of Bolts required for Tension = 0.4
of Bolts required for Shear = 1.9
of Bolts Used = 2.0
Check Combined Stress in Bolts & Inserts: 1.144 **N.G.** StressComb = 0.763 **O.K.**

(By Inspection, Threaded Inserts Control)
***If combined fails:
USE --> 3.0

Check 1/8" welded connection

Assume L/t > 25: 25*t = 1.783 in $\Omega = 2.35$
Lreq'd = 0.864 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



Connection Curb Clip to Upper Rail		#10 SMS screws	$\Omega = 3.0$
$t_1 = 0.0713$ in (hold down clip thickness - 14 Ga)	$F_{u1} = 65$ ksi		
$t_2 = 0.0713$ in (upper rail thickness)	$F_{u2} = 65$ ksi		
$d = 0.190$ in (screw diameter)	$d_w = 0.375$ in (nom. washer diameter)		
$t_2/t_1 = 1.0$			
For $t_2/t_1 \leq 1.0$:		For $t_2/t_1 \geq 2.5$:	
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2d}$	$P_{ns} = 2266$ #	$P_{ns} = 2.7t_1dF_{u1}$	$P_{ns} = 2377$ #
$P_{ns} = 2.7t_1dF_{u1}$	2.27 k	$P_{ns} = 2.7t_2dF_{u2}$	2.38 k
$P_{ns} = 2.7t_2dF_{u2}$	2.38 k		
$P_{ns}/\Omega = 755$ #			
$P_{ss}/\Omega = 540$ # <- Controls			
Tension: $P_{not} = 0.748$ k (screw pull-out strength)	$P_{not} = 0.85t_c d F_{u2}$	$t_c = \min(t_1, t_2)$	
$P_{nov} = 2.607$ k (screw pull-over strength)	$P_{nov} = 1.5t_1 d_w F_{u1}$		
$P_{ts}/\Omega = 249$ # <- Controls			
$P_{ts}/\Omega = 820$ #	(full tensile screw capacity)		
	Shear (k) # clips V_{clip} (k) V_{allow} (k) # screws spacing		
Long side:	3.03 3 1.01 2.160 4 2.0 in 3 clips w/ 4 - #10 SMS screws		O.K.
Short side:	3.03 3 1.01 2.160 4 2.0 in 3 clips w/ 4 - #10 SMS screws		O.K.
clip width = 7.00 in	clip height = 2.5 in		
min spacing = 0.57 in O.K.	edge distance = 0.5 in (min. 1.5d)		
Check Block shear rupture:	thinnest part = 0.0713	AISI BSR applies	
$F_y = 50$ ksi	$\Omega = 2.22$ bolt/screw connection		
$A_{gv} = 0.428$ in ²	$A_{nv} = 0.380$ in ²	$A_{nt} = 0.082$ in ²	
$R_n/\Omega = 8.192$ k	$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$		
BSR O.K.	(AISI Sect. E5.3)		

Curb Loads (copied from above)

Transverse:	Comp _{MAX} = 3319 lbs
(on long edge)	Tens _{MAX} = 2557 lbs
	Shear _{MAX} = 3034 lbs
Longitudinal:	Comp _{MAX} = 2838 lbs
(on short edge)	Tens _{MAX} = 2076 lbs
	Shear _{MAX} = 3034 lbs

Max compression force on isolator: 1.106 k ≤ 1.660 k **O.K.**

Max uplift on isolator: 0.852 k

Max shear on isolator: 1.011 k

Forces on top bolt:

$d_b = 0.375$ in

upper rail, $t = 0.0713$ in

Tension = 0.852 k

Shear = 1.011 k

Shear on curb rail:

$P_n = t_e F_u$

$P_n/\Omega = 4.635$ k

Shear O.K.

Net section rupture:

$P_n = A_n F_t$

$P_n/\Omega = 4.989$ k

N.S.R. O.K.

Bolt Bearing Strength:

$P_n = C m_f d t F_u$

$P_n/\Omega = 2.086$ k

Bearing O.K.

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$

$P_{nt}/\Omega = 1.988$ k

Bolt tension O.K.

Shear $P_{nv} = A_b F_{nv}$

$P_{nv}/\Omega = 1.104$ k

Bolt shear O.K.

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$

Combined Not Applicable


$F'_{nt} = 15.57$ ksi

$f_v = 9.16$ ksi **O.K.**

$F_{nv}/\Omega = 10.00$ ksi

Loads at each IQA Isolator

Transverse loading:	Comp _{MAX} = 1106.3 lbs
(on long edge)	Tens _{MAX} = 852.3 lbs
# isolators: 3	Shear _{MAX} = 1011.2 lbs
Longitudinal loading:	Comp _{MAX} = 945.9 lbs
(on short edge)	Tens _{MAX} = 691.9 lbs
# isolators: 3	Shear _{MAX} = 1011.2 lbs





Client: ProVent PV1802
Project: CBISC-07 curb for ZF180 Unit
Description: Base curb design

Curb Information

Hcurb = 25 in (Height from support structure to top of curb)
Lcurb = 115.25 in (Length of curb)
wcurb = 84 in (Width of curb)
WGTcurb = 599.5 lbs (Weight of curb+10% for pitched roof)

Unit Information

WGTunit = 2281 lbs (Weight of Unit + accessories)
Wtmax = 613 lbs (Maximum corner weight)
Wtmin = 528 lbs (Minimum corner weight)
Hunit = 48.625 in (Height of unit above curb)
Hcm = 34.3125 in (Height from top of curb to center of mass of unit)
Lunit = 125.25 in (Length of unit)
Wunit = 92 in (Width of unit)

Seismic Loading - 2015 IBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 6067 lbs (0.7*Fpmax) FpmaxASD = 7662 lbs (unit and curb)
(unit only)

Wind Loading - 2015 IBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.90 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(herid) = 1.9 (Refer pg. 309 ASCE 7-10)
GCr(vert) = 1.5 (Refer pg. 309 ASCE 7-10)
qz = 34.4 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 2514 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 1846 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 2480 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse

Compression_{SEISMIC} = 4031 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 3269 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 523 lbs = [Fh trans ASD *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension_{WIND} = 1634 lbs = Comp_{WIND}+Fvert-0.6*WGTunit
----> Negative values indicate Compression load rather than Tension.

Longitudinal

Compression_{SEISMIC} = 3359 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 2597 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 45 lbs = [Fh trans ASD *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension_{WIND} = 1157 lbs = Comp_{WIND}+Fvert-0.6*WGTunit
----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 4031 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 3269 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 3359 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2597 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.



Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.1017 [12 Gauge]
E = 29500 ksi

Calculate Section Properties of Curb

(curb assumed to be symmetric C-Section without Lips)

A' = 25.000 in a = 24.492 in = A' - (2r + t)
B' = 2.000 in a' = 24.898 in = A' + t
C' = 0.000 in (0 if no lips) b = 1.746 in = B' - (r + t/2 + a(r + t/2))
d = 0.000 in (0 - no Lip; 1 w/ lip) b' = 1.949 in = B' - (t/2 + a(t/2))
R = 0.1525 (Inside bend radius) c = 0.000 in = a(C' - (r + t/2))
t = 0.1017 in c' = 0.000 in = a(C' - t/2)
r' = 0.203 in = R + t/2 u = 0.319 in = $\pi r/2$
x = 0.133 in (Distance between centroid and web centerline)
Ix = 189.589 in (Moment of Inertia about X-Axis)
Iy = 0.451 in (Moment of Inertia about Y-Axis)
A = 2.91 in²
rx = 8.07 in
ry = 0.393 in
rmin = 0.393 in

Axial Compression

Pu = 3.034 k (Max Axial Comp) $\Omega_c = 1.80$
Pn/Qc = 7.266 k
Fe = 5.12 ksi
 $\lambda_c = 3.12$
Fn = 4.49 ksi
Ly = 117.25 in Lateral unbraced length
kyLy/ry = 238 (assume k=0.8)

$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$
 $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Compression Check = **O.K.**

Check Web Crippling

h = 25 in -- Check limits: C = 4.00
t = 0.1017 in h/t = 245.82 ≤ 200 Cr = 0.14
N = 7.00 N/t = 68.83 ≤ 210 CN = 0.35
 $\Omega_w = 1.75$ N/h = 0.28 ≤ 2.0 Ch = 0.02
Pn = 4.106 k R/t = 1.50 ≤ 9.0
Pn/Qw = 2.346 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$
Long side: Pu/trans = 1.344 k **O.K.** # clips = 3
Short side: Pu/Long = 1.679 k **O.K.** # clips = 2

***h/t > 200; use web stiffeners

Check Web Stiffener

N/A
width of stiffener = 7.000 in ts = 0.0566 [16 Gauge]
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts $\leq 1.28\sqrt{E/F_y}$ $\Omega_c = 1.70$
w/ts = 118.675
1.28 $\sqrt{E/F_y}$ = 31.091 --> w/ts over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$
Pwc = 4.106 k Ae = 0.380 in²
Pn = 16.181 k
Pn/Qc = 9.518 k **O.K.**

Corner Connections

(Use 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded insert)

Tcrnmax = 1517 lbs Max[F_{pmasASD}/4 - QR - F_{ASDtrans}/4 corner connections]
Vcrnmax = 1634 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 5000 lbs Vall = 4470 lbs
Threaded Insert: Tall = 4289 lbs Vall = 661 lbs
of Bolts required for Tension = 0.4 [By Inspection, Threaded Inserts Control]
of Bolts required for Shear = 2.5
of Bolts Used = 3.0 ***If combined fails: USE --- 4.0
Check Combined Stress in Bolts & Inserts: 0.942 **O.K.** StressComb = 0.707 **O.K.**

Check 1/8" welded connection

Assume L/t > 25: 25*t = 2.543 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$
Lreq'd = 0.775 in $\Omega = 2.35$



Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} =	3319 lbs
	Tens _{MAX} =	2557 lbs
	Shear _{MAX} =	3034 lbs
Longitudinal: (on short edge)	Comp _{MAX} =	2838 lbs
	Tens _{MAX} =	2076 lbs
	Shear _{MAX} =	3034 lbs

Max compression force on isolator: 1.106 k ≤ 1.660 k **O.K.**
Max uplift on isolator: 0.852 k
Max shear on isolator: 1.011 k

Forces on bottom bolts:

$d_b = 0.5$ in
base curb, $t = 0.1017$ in
Tension = 0.426 k / bolt
Shear = 0.506 k / bolt

Shear on base curb: $P_n = t_e F_u$ $\Omega = 2.00$ [Appendix A, Section E3.1 AISI]
 $P_n / \Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ [Appendix A, Section E3.2 AISI]
 $P_n / \Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ [Section E3.3.1 AISI]
 $P_n / \Omega = 3.966$ k $d / t = 4.92$

Bearing O.K.

Shear and tension in bolt:


Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega_t = 2.25$ [Table E3.4-1, AISI]
Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega_v = 2.40$ [Table E3.4-1, AISI]
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.**

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 2.58$ ksi **O.K.**
 $F'_{nt} = 45.00$ ksi $F_{nv} / \Omega = 11.25$ ksi

Combined Not Applicable

Loads at each IQA Isolator

Transverse loading: (on long edge)	Comp _{MAX} =	1106.3 lbs
	Tens _{MAX} =	852.3 lbs
	Shear _{MAX} =	1011.2 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} =	945.9 lbs
	Tens _{MAX} =	691.9 lbs
	Shear _{MAX} =	1011.2 lbs



Connection of Curb to Supporting Structure

Roof Loading	SEISMIC: (0.6-0.14SDS)D + 0.7E	WIND: 0.6D + W
Transverse:	Uplift _{MAX} = 6272 lbs	Shear _{MAX} = 3831 lbs
Compression _{SEISMIC} =	7234 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * (WGT_{unit+curb} / 2) * w_{curb}] / w_{curb}$
Tension _{SEISMIC} =	6272 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14 S_{DS}] * (WGT_{unit+curb})$
Compression _{WIND} =	1399 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * w_{curb} - F_{vertASD} * w_{curb} / 2] / w_{curb}$
Tension _{WIND} =	2151 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * w_{curb} + F_{vertASD} * w_{curb} / 2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 4805 lbs	Shear _{MAX} = 3831 lbs
Compression _{SEISMIC} =	5767 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * (WGT_{unit+curb} / 2) * L_{curb}] / L_{curb}$
Tension _{SEISMIC} =	4805 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14 S_{DS}] * (WGT_{unit+curb})$
Compression _{WIND} =	574 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * L_{curb} - F_{vertASD} * L_{curb} / 2] / L_{curb}$
Tension _{WIND} =	1326 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * L_{curb} + F_{vertASD} * L_{curb} / 2] / L_{curb}$

Wood Attachment:	1/4" φ Simpson SDS screws		w/ 3.5" Min. Embed	
	Tall _{metal} = 324 lbs	Vall _{metal} = 1020 lbs	Tall _{wood} = 642 lbs	Vall _{wood} = 272 lbs
Transverse:	# of Screws Req'd for Uplift = 19.36	# of Bolts Required = 20	# of Screws Req'd for Shear = 14.08	Req'd Min Spacing = 5.6 in o.c.
Use 20 - 1/4" φ Simpson SDS screws @ 5.6 in o.c. along long side of curb w/ 3.5" Min. Embed				
Longitudinal:	# of Screws Req'd for Uplift = 14.83	# of Bolts Required = 15	# of Screws Req'd for Shear = 14.08	Req'd Min Spacing = 5.4 in o.c.
Use 15 - 1/4" φ Simpson SDS screws @ 5.4 in o.c. along short side of curb w/ 3.5" Min. Embed				

Steel Deck Attachment: 1/2" φ A307 Bolts attached to steel angle below deck

Transverse:	Tall _{steel} = 4417 lbs	Vall _{steel} = 2316 lbs	Tall _{bolt} = 1325 lbs	Vall _{bolt} = 1325 lbs
	# of Bolts Req'd for Uplift = 4.73	# of Bolts Required = 5	# of Bolts Req'd for Shear = 2.89	Req'd Min Spacing = 25.8 in o.c.
Use 5 - 1/2" φ A307 Bolts attached to steel angle below deck @ 25.8 in o.c. along long side of curb				
Longitudinal:	# of Bolts Req'd for Uplift = 3.63	# of Bolts Required = 4	# of Bolts Req'd for Shear = 2.89	Req'd Min Spacing = 24.0 in o.c.
Use 4 - 1/2" φ A307 Bolts attached to steel angle below deck @ 24 in o.c. along long side of curb				



For Concrete anchorage: SEISMIC $(0.6-0.14SDS)D + 0.7Q_p E$ ($Q_p = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 6" embed

$$\begin{aligned} T_{all,LRFD} &= 1919 \text{ lbs} & V_{all,LRFD} &= 3188 \text{ lbs} & \alpha &= (1 + 0.2SDS)D + 2.5E = 1.87 \\ T_{all,ASD} &= T_{all,LRFD}/\alpha = 1026.2 \text{ lbs} & V_{all,ASD} &= V_{all,LRFD}/\alpha = 1704.8 \text{ lbs} & (D = 0.465, E = 0.535) \end{aligned}$$

Transverse:	Uplift _{MAX} = 14387 lbs	Shear _{MAX} = 9578 lbs
--------------------	-----------------------------------	---------------------------------

$$\text{Compression}_{SEISMIC} = 15349 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 14387 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14SDS] \cdot [WGT_{unit+curb}]$$

$$\text{Shear}_{SEISMIC} = 9578 \text{ lbs} = 2.5 \cdot F_{pmaxASD}/2$$

$$\text{Min Bolts Req'd Uplift} = 14.02 \text{ spacing} = 6.52 \text{ in o.c.} \quad T_{applied} = 846.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 5.62 \text{ spacing} = 18.25 \text{ in o.c.} \quad V_{applied} = 563.4 \text{ lbs}$$

Try using	17 bolts
spaced at	6.45 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$$

Use 17 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 6.5 in o.c. max. along long side of curb w/ 6" embed

Longitudinal:	Uplift _{MAX} = 10719 lbs	Shear _{MAX} = 9578 lbs
----------------------	-----------------------------------	---------------------------------

$$\text{Compression}_{SEISMIC} = 11681 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 10719 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14SDS] \cdot [WGT_{unit+curb}]$$

$$\text{Shear}_{SEISMIC} = 9578 \text{ lbs} = 2.5 \cdot F_{pmaxASD}/2$$

$$\text{Min Bolts Req'd Uplift} = 10.45 \text{ spacing} = 6 \text{ in o.c.} \quad T_{applied} = 765.7 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 5.62 \text{ spacing} = 12 \text{ in o.c.} \quad V_{applied} = 684.1 \text{ lbs}$$

Try using	14 bolts
spaced at	5.54 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$$

Use 14 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 5.5 in o.c. max. along short side of curb w/ 6" embed