



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBISC-04 Series



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: April 22, 2020

Project Number: PV1805

For wood, concrete and steel attachment see Roof Anchorage Detail, Form No. CB-60.

Welded isolation springs housing are standard. For bolted spring housing, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. CB-61

VIBRATION ISOLATION ROOF CURBS YORK UNITS

ZT, ZH, ZJ, ZR 037, 049, 061
ZF, ZH, ZJ, ZR, XP 078-150

PROVENT P/N	A	B	EST. WEIGHT
CBISCPRD371518**	8"	18"	325 Lbs
CBISCPRD371521**	11"	21"	347 Lbs
CBISCPRD371524**	14"	24"	370 Lbs

**Note: Spring configuration must be added to part number at time of order




Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

FEATURES

- Roof curbs sides and ends are 12 ga.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

NOTES

- Attach ductwork to roof curb. Flanges of duct rest on top of the curb, support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or Provent directly.




3847 WABASH DRIVE
MIRA LOMA, CA 91752
PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO: CBISC-04
DATE: 9/27/2018

PART NUMBER: -
REV: 2
DRAWN BY: ALL

WELDMENT AND BOLTING DETAIL




BASE CURB SUPPORT

OPTIONAL BOTTOM BUMPER FOR:
ISCALSLU180
ISCALSML1830

FOR JQA:
5/16"Ø HOLE USE 1/2"Ø A307 BOLT WITH FLAT WASHER AND NUT

FOR JQB, JQBX, JQE, JQF:
3/8"Ø HOLE USE 5/8"Ø A307 BOLT WITH FLAT WASHER AND NUT



FOR BOLT ON ISOLATORS



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-61

DATE:
02/08/18

REV:
1

DRAWN BY:
ALL




Client: ProVent PV1805
Project: CBISC-04 Iso Curb (CBISCPD3715**Upper curb rail)
Unit: ZT,ZR,ZJ 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150

Curb Information

Hcurb upper = 5.5 in (Height of upper curb rail)
Lcurb = 80.375 in (Length of curb)
wcurb = 50.5 in (Width of curb)
WGTcurb = 370 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 2

Unit Information

WGTunit = 1700 lbs (Weight of Unit)
Wtmax = 329 lbs (Maximum corner weight)
Wtmin = 191 lbs (Minimum corner weight)
Hunit = 50.75 in (Height of unit above curb)
Hcm = 25.375 in (Height to center of mass)
Lunit = 89 in (Length of unit)
Wunit = 59 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 4522 lbs (0.7*Fpmax) FpmaxASD = 5506 lbs (unit and curb)
(unit only)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 1289 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) (Eq. 29.5-2)
Fh ASD long = 854 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
Fvert ASD = 1067 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 3105 lbs = [FpmaxASD*Hcm+2*(1+0.14SDS)*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2537 lbs = Comp_{SEISMIC}-(0.6-0.14SDS)*WGTunit
Compression_{WIND} = 509 lbs = [Fh trans ASD *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension_{WIND} = 556 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2261 lbs = [FpmaxASD*Hcm+2*(1+0.14*SDS)*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1693 lbs = Comp_{SEISMIC}-(0.6-0.14SDS)*WGTunit
Compression_{WIND} = 131 lbs = [Fh trans ASD *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension_{WIND} = 178 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 3105 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2537 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2261 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1693 lbs	---> Along short edge of curb.


---> Negative values indicate Compression load rather than Tension.

Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.322 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.464 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.261 in (Distance between centroid and web centerline)	
Ix = 2.424 in (Moment of Inertia about X-Axis)	
Iy = 0.109 in (Moment of Inertia about Y-Axis)	
A = 0.59 in ²	
rx = 2.03 in	
ry = 0.432 in	
rmin = 0.432 in	



Axial Compression

Pu = 2.261 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 4.894 k
Fe = 17.11 ksi
λc = 1.71 If λc ≤ 1.5; Fn = (0.658λc²)Fy λc = √(Fy/Fe) Fe = π²E / (kl/r)²
Fn = 15.00 ksi If λc > 1.5; Fn = 0.877 / λc² * Fy
Ly = 70.38 in Lateral unbraced length
kyLy/ry = 130 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 CR = 0.08
N = 7.00 N/t = 98.18 ≤ 210 CN = 0.12
Ωw = 1.75 N/h = 1.273 ≤ 2.0 Ch = 0.048
Pn = 1.947 k R/t = 1.50 ≤ 12.0
Pn/Ωw = 1.112 k
Long side: PuTrans = 1.553 k **web stiffener REQ'D** # clips = 2
Short side: PuLong = 1.130 k **web stiffener REQ'D** # clips = 2

(See table C3.4.1-2, fastened to support, two flange, end loading)

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \frac{R}{t} \right) \left(1 + C_N \frac{N}{t} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

16Ga x 3/4in x 7in [C-channel]
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys Ωc = 1.70
w/ts = 118.675
1.28v(E/Fys) = 31.091 --> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc Ae = 0.380 in²
Pwc = 1.947 k
Pn = 14.669 k
Pn/Ωc = 8.629 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
Tcrnmax = 1131 lbs Max[FpmaxASD/4 -OR- FhASDtrans/4 corner connections]
Vcrnmax = 1269 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.5
of Bolts required for Shear = 1.2 ***If combined fails:
of Bolts Used = 2.0 USE --> 3.0
Check Combined Stress in Bolts & Inserts: 0.807 **O.K.** StressComb = 0.538 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25*t = 1.783 in Pn/Ω = 1/Ω * 0.75tLu ≥ Vreq Lreq'd = VreqΩ / (0.75tFu)



Connection Unit to Curb Clip #12 SMS screw $\Omega = 3.0$


$t_1 = 0.0713$ in (clip thickness) $F_{u1} = 65$ ksi
 $t_2 = 0.0713$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.216$ in (screw diameter) $d_w = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.0$

For $t_2/t_1 \leq 1.0$: $P_{ns} = 2416$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 2703$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.42 k $P_{ns} = 2.7t_1dF_{u1}$ 2.70 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.70 k $P_{ns} = 2.7t_2dF_{u2}$ 2.70 k
 $P_{ns}/\Omega = 805$ # <- Controls
 $P_{ss}/\Omega = 840$ #

Tension: $P_{not} = 0.851$ k (screw pull-out strength) $P_{not} = 0.85t_c d F_{u2}$
 $P_{nov} = 2.607$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ts}/\Omega = 284$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 845$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	4.522	2	2.26	805 #	4	2.00 in
Short side:	4.522	2	2.26	805 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in
min spacing = 0.65 in edge distance = 0.5 in (min. 1.5d)
Check Block shear rupture: O.K. thinnest part = 0.0713 AISI BSR applies
 $F_y = 50$ ksi $\Omega = 2.22$ bolt/screw connection
 $A_{gv} = 0.463$ in² $A_{nv} = 0.410$ in² $A_{nt} = 0.081$ in²
 $R_n/\Omega = 8.647$ k $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
BSR O.K.



Curb Loads (copied from above)

Transverse: (on long edge)	Comp _{MAX} = 3105 lbs
	Tens _{MAX} = 2537 lbs
	Shear _{MAX} = 2261 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2261 lbs
	Tens _{MAX} = 1693 lbs
	Shear _{MAX} = 2261 lbs


Loads at each Isolator Type: JQA

Transverse loading: (on long edge)	Comp _{MAX} = 1552.6 lbs
	Tens _{MAX} = 1268.7 lbs
	Shear _{MAX} = 565.3 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1130.3 lbs
	Tens _{MAX} = 846.4 lbs
	Shear _{MAX} = 565.3 lbs

Max compression force on isolator: 1.553 k ≤ 1.660 k **O.K.**
Max uplift on isolator: 1.269 k ≤ 1.660 k **O.K.**
Max shear on isolator: 0.565 k ≤ 0.800 k **O.K.**

Forces on top bolt:

$d_b = 0.375$ in
upper rail, t = 0.0713 in
Tension = 1.269 k
Shear = 0.565 k



Shear on curb rail: $P_n = t_e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 4.635$ k $e = 1.0$ in
Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K. $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 2.086$ k $d/t = 5.26$
 $C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega_t = 2.25$ (Table E3.4-1, AISI)
Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega_v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 5.12$ ksi **O.K.**

Combined Not Applicable $F'_{nt} = 31.92$ ksi $F_{nv}/\Omega = 10.00$ ksi




Client: ProVent PV1805
Project: CBISC-04 Iso Curb (CBISCPRD3715**) Base curb
Unit: ZT,ZR,ZJ 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150

Curb Information

Hcurb = 25 in (Height of curb)
Lcurb = 83.375 in (Length of curb)
wcurb = 53.5 in (Width of curb)
WGTCurb = 370 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 2

Unit Information

WGTunit = 1700 lbs (Weight of Unit)
Wtmax = 329 lbs (Maximum corner weight)
Wtmin = 191 lbs (Minimum corner weight)
Hunit = 50.75 in (Height of unit above curb)
Hcm = 25.375 in (Height to center of mass)
Lunit = 89 in (Length of unit)
Wunit = 59 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 4522 lbs (0.7*Fpmax) FpmaxASD = 5506 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ACSE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr_(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr_(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
F_{h ASD trans} = 1736 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
F_{h ASD long} = 1151 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F_{vert ASD} = 1067 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 2978 lbs = [FpmaxASD*Hcm+2*(1+0.14*SDS)*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2410 lbs = Comp_{SEISMIC}-(0.6-0.14*SDS)*WGTunit
Compression_{WIND} = 684 lbs = [F_{h transASD}*Hcm+2*0.6*Wtmax*wcurb-F_{vertASD}*wcurb/2]/wcurb
Tension_{WIND} = 732 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2209 lbs = [FpmaxASD*Hcm+2*(1+0.14*SDS)*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1641 lbs = Comp_{SEISMIC}-(0.6-0.14*SDS)*WGTunit
Compression_{WIND} = 211 lbs = [F_{h transASD}*Hcm+2*0.6*Wtmax*Lcurb-F_{vertASD}*Lcurb/2]/Lcurb
Tension_{WIND} = 259 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

<u>Transverse:</u>	Comp _{MAX} = 2978 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2410 lbs	----> Along long edge of curb.
<u>Longitudinal:</u>	Comp _{MAX} = 2209 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1641 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r+t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - [t/2+αt/2]
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
Ix = 128.737 in (Moment of Inertia about X-Axis)	
Iy = 0.218 in (Moment of Inertia about Y-Axis)	
A = 2.01 in ²	
rx = 8.00 in	
ry = 0.329 in	
rmin = 0.329 in	



Axial Compression

Pu = 2.261 k	(Max Axial Comp)	Ωc = 1.80
Pn/Ωc = 8.960 k		
Fe = 9.14 ksi	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$	$\lambda_c = \sqrt{\frac{F_y}{F_e}}$
λc = 2.34	If λc ≤ 1.5; $F_n = (0.658\lambda_c^2) F_y$	$F_e = \frac{\pi^2 E}{(kl/r)^2}$
Fn = 8.01 ksi	If λc > 1.5; $F_n = \frac{0.877}{\lambda_c^2} F_y$	
Ly = 73.38 in	Lateral unbraced length	
kyLx/ry = 179	(assume k=0.8)	

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 350.63 ≤ 200	CR = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	CN = 0.35	
Ωw = 1.75	N/h = 0.28 ≤ 2.0	Ch = 0.02	
Pn = 2.105 k	R/t = 1.50 ≤ 9.0		
Pn/Ωw = 1.203 k			
Long side: PuTrans = 1.489 k	web stiffener REQ'D # clips = 2	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: PuLong = 1.105 k	O.K. # clips = 2		

*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 1.5in x 7in [C-channel]

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28VE/Fys	Ωc = 1.70
w/ts = 118.675	
1.28v(E/Fys) = 31.091	--> w/ts over limit Use C3.7.2
$P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$	
Pwc = 2.105 k	Ae = 0.380 in ²
Pn = 14.780 k	
Pn/Ωc = 8.694 k	O.K.

Corner Connections 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 1131 lbs	Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1205 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.5	
# of Bolts required for Shear = 1.1	
# of Bolts Used = 2.0	
Check Combined Stress in Bolts & Inserts: 0.778 O.K.	***If combined fails: USE --> 4.0
	StressComb = 0.389 O.K.



Check 1/8" welded connection

<--- USE WELD $\Omega = 2.35$
 Assume $L/t > 25$: $25*t = 1.783$ in $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ $L_{req}'d = \frac{V_{req}\Omega}{0.75tF_u}$
 $L_{req}'d = 0.815$ in

Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 3105 lbs
	Tens _{MAX} = 2537 lbs
	Shear _{MAX} = 2261 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2261 lbs
	Tens _{MAX} = 1693 lbs
	Shear _{MAX} = 2261 lbs

Loads at each Isolator Type: **IQBX**

Transverse loading: (on long edge) # isolators: 2	Comp _{MAX} = 1552.6 lbs
	Tens _{MAX} = 1268.7 lbs
	Shear _{MAX} = 565.3 lbs
Longitudinal loading: (on short edge) # isolators: 2	Comp _{MAX} = 1130.3 lbs
	Tens _{MAX} = 846.4 lbs
	Shear _{MAX} = 565.3 lbs

Max compression force on isolator: 1.553 k ≤ 2.000 k **O.K.**
 Max uplift on isolator: 1.269 k ≤ 2.000 k **O.K.**
 Max shear on isolator: 0.565 k ≤ 1.500 k **O.K.**

Forces on bottom bolts:

$d_b = 0.625$ in
 base curb, $t = 0.0713$ in
 Tension = 0.634 k / bolt
 Shear = 0.283 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 4.635$ k $e = 1.0$ in
Shear O.K.



Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 6.372$ k $A_n = 0.098$ in
 $F_t = (0.1 + 3d/s)F_u \leq F_u = 65.000$ ksi
N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 3.476$ k $d/t = 8.77$
 $C = 3.00$ $m_f = 1.00$
Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.3068$ in²
 $P_{nt}/\Omega = 6.136$ k **Bolt tension O.K.** $\Omega t = 2.25$
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv}/\Omega = 3.451$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 0.92$ ksi
 $F'_{nt} = 45.0$ ksi $F_{nv}/\Omega = 11.25$ ksi

Combined Not Applicable



Connection of Curb to Supporting Structure

Roof Loading SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$ WIND: $0.6D + W$

Transverse:	Uplift _{MAX} = 5804 lbs	Shear _{MAX} = 2753 lbs
Compression _{SEISMIC} =	6495 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$
Tension _{SEISMIC} =	5804 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
Compression _{WIND} =	1722 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$
Tension _{WIND} =	1547 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$
Longitudinal:	Uplift _{MAX} = 3946 lbs	Shear _{MAX} = 2753 lbs
Compression _{SEISMIC} =	4637 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$
Tension _{SEISMIC} =	3946 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
Compression _{WIND} =	783 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$
Tension _{WIND} =	608 lbs	$= [F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$

Wood Attachment: **1/4" φ wood lag screws** w/ **3.5" Min. Embed** (SGmin = 0.43)

Tall _{metal} =	946.67 lbs	Vall _{metal} =	1043.33 lbs
Transverse:	Tall _{wood} = 671.25 lbs	Vall _{wood} =	224 lbs
# of Screws Req'd for Uplift =	8.65	COMBINED LOADING:	0.952 O.K.
# of Screws Req'd for Shear =	12.29	Req'd Min Spacing =	3.6 in o.c.
Total # of screws required =	22		

Use 22 - 1/4" φ wood lag screws @ 3.6 in o.c. along long side of curb w/ 3.5" Min. Embed



Longitudinal:

of Screws Req'd for Uplift = 5.88
of Screws Req'd for Shear = 12.29
Total # of screws required = 19

COMBINED LOADING: 0.956 O.K.
Screw Spacing = 2.5 in o.c.

Use 19 - 1/4" ϕ wood lag screws @ 2.5 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse:
Tall_{bolt} = 6903 lbs
of Bolts Req'd for Uplift = 0.84
of Bolts Req'd for Shear = 0.75
Total # of bolts required = 2

Vall_{bolt} = 3682 lbs
COMBINED LOADING: 0.794 O.K.
Bolt Spacing = 71.4 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 71.4 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.57
of Bolts Req'd for Shear = 0.75
Total # of bolts required = 2

COMBINED LOADING: 0.660 O.K.
Bolt Spacing = 41.5 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 41.5 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7 Ω_o E ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs Vall_{LRFD} = 3188 lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
Tall_{ASD} = Tall_{LRFD}/ α = 1026.2 lbs Vall_{ASD} = Vall_{LRFD}/ α = 1704.8 lbs ($D = 0.465, E = 0.535$)
Transverse: Uplift_{MAX} = 13580 lbs Shear_{MAX} = 6883 lbs
Compression_{SEISMIC} = 14272 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb} / 2) * w_{curb}] / w_{curb}$
Tension_{SEISMIC} = 13580 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
Shear_{SEISMIC} = 6883 lbs = $2.5 * F_{pmaxASD} / 2$
Min Bolts Req'd Uplift = 13.23 spacing = 4.57 in o.c. T_{applied} = 905.4 lbs
Min Bolts Req'd Shear = 4.04 spacing = 14.84375 in o.c. V_{applied} = 458.9 lbs

Try using 15 bolts spaced at 5.10 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$

Use 15 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 5.1 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 8936 lbs Shear_{MAX} = 6883 lbs
Compression_{SEISMIC} = 9627 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb} / 2) * L_{curb}] / L_{curb}$
Tension_{SEISMIC} = 8936 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$
Shear_{SEISMIC} = 6883 lbs = $2.5 * F_{pmaxASD} / 2$
Min Bolts Req'd Uplift = 8.71 spacing = 3.6875 in o.c. T_{applied} = 812.4 lbs
Min Bolts Req'd Shear = 4.04 spacing = 7.375 in o.c. V_{applied} = 625.7 lbs

Try using 11 bolts spaced at 4.15 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$

Use 11 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 4.2 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBISC-04 (CBISCPRD3: Unit: ZT,ZR,ZI 037-150; ZF,ZH,ZI,ZR,XP,DH,DM,DF,DR,BP 078-150			
UPPER CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: JQBX Top stud diameter: 3/8			
Anchor bolt diameter: 5/8 Anchor hole diameter: 11/16			
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD 1/4" ϕ wood lag screws w/ 3.5" Min. Embed (SGmin = 0.43)	STEEL 1/2" ϕ A307 Bolts to steel angle below deck	CONCRETE 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	22 @ 3.59 in o.c.	2 @ 71.38 in o.c.	15 @ 5.1 in o.c.
SHORT DIRECTION	19 @ 2.53 in o.c.	2 @ 41.5 in o.c.	11 @ 4.15 in o.c.