



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800



**Structural Calculations
for
CBKD-136 Series**




Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 1, 2019
Project Number: PV1806


For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60.	STRUCTURALLY CALCULATED KNOCK-DOWN ROOF CURBS FOR YORK UNITS	PROVENT P/N	A	EST. WEIGHT	SEISMIC KIT P/N
		CBKDSLM183008	8"	125 Lbs.	
		CBKDSLM183011	11"	139 Lbs.	
		CBKDSLM183014	14"	154 Lbs.	
Will conform to seismic code requirements for knock-down or pre-assembled application. (Contact factory for assembled	ZJ, ZR 180-300; XP 180-240 ZF 210-300				Meets seismic requirements for the following codes: CBC 2016 IBC 2015



ATTACH TO UNIT WITH
(4) #10 x 6" TEK SCREWS
EACH HOLD DOWN



HOLD DOWN DETAIL



Pre-Threaded Flange
1/4-20 X 3/4" Bolt

CROSS SECTION DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91725
PHONE (951) 685-1101
FAX (619) 872-9799



SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBKD-136
PART NUMBER:
KDKITSLM1830
DATE:
1/7/2019
REV:
1
DRAWN BY:
ALL




Client: ProVent PV1806
Description: CBKD-136 14" KDKITSLM1830
Unit: ZJ,ZR 180-300; ZF 210-300; XP 180-240

Curb Information

Hcurb = 14 in (Height of curb)
Lcurb = 125.75 in (Length of curb)
wcurb = 83.5 in (Width of curb)
WGTCurb = 192 lbs (Weight of curb)
Clips long side = 3 # Clips short side = 1

Unit Information

WGTunit = 3061.3 lbs (Weight of Unit)
Wtmax = 908 lbs (Maximum corner weight)
Wtmin = 306 lbs (Minimum corner weight)
Hunit = 52.625 in (Height of unit above curb)
Hcm = 26.3125 in (Height to center of mass)
Lunit = 136.25 in (Length of unit)
Wunit = 92 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp/3/Rp
FpmaxASD = 3054 lbs (0.7*Fpmax)
FpmaxASD = 3245 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 2337 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 1578 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 2548 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 3261 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2239 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 552 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 1263 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2938 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1916 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 146 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 857 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 3261 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2239 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2938 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1916 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 **16 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 14.000 in a = 13.717 in = A' - (2r + t)
B' = 3.000 in a' = 13.943 in = A' - t
C' = 1.000 in (0 if no lips) b = 2.717 in = B' - [r + t/2 + a(r + t/2)]
σ = 1.000 (0 - no Lip; 1 w/ lip) b' = 2.943 in = B' - [t/2 + at/2]
R = 0.0849 (Inside bend radius) c = 0.859 in = a[C' - (r + t/2)]
t = 0.0566 in c' = 0.972 in = a[C' - t/2]
r' = 0.113 in = R + t/2 u = 0.178 in = πr/2
x = 0.653 in (Distance between centroid and web centerline)
I_x = 33.089 in (Moment of Inertia about X-Axis)
I_y = 1.346 in (Moment of Inertia about Y-Axis)
A = 1.22 in²
r_x = 5.20 in
r_y = 1.050 in
r_{min} = 1.050 in



Axial Compression

P_u = 1.527 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 25.270 k
F_e = 71.03 ksi $\lambda_c = \frac{P_n}{F_e A}$ If $\lambda_c \leq 1.5$: $F_n = (0.658^{\lambda_c^2}) F_y$
 $\lambda_c = 0.84$ $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c > 1.5$: $F_n = \frac{0.877}{\lambda_c^2} F_y$
F_n = 37.24 ksi Lateral unbraced length
L_y = 84 in (assume k=0.8)
k_yL_y/r_y = 64

Compression Check = O.K.

Check Web Crippling

h = 14 in -- Check limits: C = 4.00
t = 0.0566 in h/t = 247.35 ≤ 200 C_R = 0.14
N = 7.00 N/t = 123.67 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.5 ≤ 2.0 C_h = 0.02
P_n = 1.591 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 0.909 k $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$
Long side: P_{uTrans} = 1.087 k **web stiffener REQ'D** # clips = 3
Short side: P_{uLong} = 0.979 k **web stiffener REQ'D** # clips = 3

***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28E/F_y Ω_c = 1.70
w/t_s = 118.675
1.28E/F_y = 31.091 --> w/t_s over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_s F_y) \geq P_{wc}$
P_{wc} = 1.591 k A_e = 0.380 in²
P_n = 14.420 k P_n/Ω = 8.483 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 763 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1119 lbs [Max Ten/2 corner connections per side]
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 1.0
of Bolts Used = 2.0
Check Combined Stress in Bolts & Inserts: 0.665 **O.K.** StressComb = 0.443 **O.K.**

***If combined fails:

USE --> 3.0

Check 1/8" welded connection

--- USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.415 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req} d = \frac{V_{req} \Omega}{0.75 t F_u}$
L_{req}d = 0.953 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

$P_{ns} = 1887$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 1887$ #

Shear:

$P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 629$ #

$P_{ss}/\Omega = 540$ # <- Controls

$P_{not} = 0.85t_c d F_{u2}$

Tension:

$P_{not} = 1.068$ k (screw pull-out strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.069$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	3.054	3	1.02	540 #	2	6.00 in
Short side:	3.054	3	1.02	540 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min, 1.5d)

Check Block shear rupture: O.K.

$F_y = 50$ ksi

thinnest part = 0.0566 AISI BSR applies

$A_{gv} = 0.368$ in²

$\Omega = 2.22$ bolt/screw connection

$R_n/\Omega = 5.954$ k


$A_{nv} = 0.352$ in²

$A_{nt} = 0.034$ in²

BSR O.K.

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:

Uplift_{MAX} = 2539 lbs

Shear_{MAX} = 1623 lbs

Compression_{SEISMIC} = 3626 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 2539 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$

Compression_{WIND} = 830 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$

Tension_{WIND} = 1426 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$

Longitudinal: Uplift_{MAX} = 2013 lbs Shear_{MAX} = 1623 lbs

Compression_{SEISMIC} = 3100 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 2013 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$

Compression_{WIND} = 208 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$

Tension_{WIND} = 804 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

$T_{allmetal} = 946.67$ lbs

$V_{allmetal} = 1043.33$ lbs

Transverse:

$T_{allwood} = 1195.95$ lbs

$V_{allwood} = 1024$ lbs

of Screws Req'd for Uplift = 2.68

COMBINED LOADING: 0.927 O.K.

of Screws Req'd for Shear = 1.58

Screw Spacing = 39.3 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 39.3 in o.c. along long side of curb

Longitudinal:

of Screws Req'd for Uplift = 2.1

COMBINED LOADING: 0.817 O.K.

of Screws Req'd for Shear = 1.6

Screw Spacing = 25.2 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 25.2 in o.c. along short side of curb

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

Transverse:

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

of Bolts Req'd for Uplift = 0.37

COMBINED LOADING: 0.140 O.K.

of Bolts Req'd for Shear = 0.44

Bolt Spacing = 113.8 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 113.8 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.29

COMBINED LOADING: 0.121 O.K.

of Bolts Req'd for Shear = 0.44

Req'd Min Spacing = 71.5 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 71.5 in o.c. along short side of curb



For Concrete anchorage: SEISMIC $[0.6-0.14S_{DS}D + 0.7\Omega_0 E]$ ($\Omega_0 = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$\begin{aligned} T_{all,LRFD} &= 1722 \text{ lbs} & V_{all,LRFD} &= 2032 \text{ lbs} & \alpha &= (1 + 0.2SDS)D + 2.5E = 1.87 \\ T_{all,ASD} &= T_{all,LRFD}/\alpha = 920.9 \text{ lbs} & V_{all,ASD} &= V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} & (D = 0.465, E = 0.535) \\ \text{Transverse:} & & \text{Uplift}_{MAX} &= 4890 \text{ lbs} & \text{Shear}_{MAX} &= 4056 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 5976 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb} \\ \text{Tension}_{SEISMIC} &= 4890 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 4056 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD}/2 \\ \text{Min Bolts Req'd Uplift} &= 5.31 \text{ spacing} = 20.35 \text{ in o.c.} & & T_{applied} = 698.5 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 3.73 \text{ spacing} = 33.91667 \text{ in o.c.} & & V_{applied} = 579.5 \text{ lbs} \end{aligned}$$

Try using 7 bolts spaced at 18.96 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.29$
---	--

Use 7 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 19 in o.c. max. along long side of curb w/ 4" embed

$$\begin{aligned} \text{Longitudinal:} & & \text{Uplift}_{MAX} &= 3574 \text{ lbs} & \text{Shear}_{MAX} &= 4056 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 4660 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb} \\ \text{Tension}_{SEISMIC} &= 3574 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 4056 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD}/2 \\ \text{Min Bolts Req'd Uplift} &= 3.88 \text{ spacing} = 19.83333 \text{ in o.c.} & & T_{applied} = 714.7 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 3.73 \text{ spacing} = 19.83333 \text{ in o.c.} & & V_{applied} = 811.3 \text{ lbs} \end{aligned}$$

Try using 5 bolts spaced at 17.88 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.52$
---	--

Use 5 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 17.9 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-136			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 39.25 in o.c.	2 @ 113.75 in o.c.	7 @ 18.96 in o.c.
SHORT DIRECTION	4 @ 25.17 in o.c.	2 @ 71.5 in o.c.	5 @ 17.88 in o.c.




Client: ProVent PV1806
Description: CBKD-136 11" KDKITSLM1830
Unit: ZJ,ZR 180-300; ZF 210-300; XP 180-240

Curb Information

Hcurb = 11 in (Height of curb)
Lcurb = 125.75 in (Length of curb)
wcurb = 83.5 in (Width of curb)
WGTcurb = 192 lbs (Weight of curb)
Clips long side = 3 # Clips short side = 1

Unit Information

WGTunit = 3061.3 lbs (Weight of Unit)
Wtmax = 908 lbs (Maximum corner weight)
Wtmin = 306 lbs (Minimum corner weight)
Hunit = 52.625 in (Height of unit above curb)
Hcm = 26.3125 in (Height to center of mass)
Lunit = 136.25 in (Length of unit)
Wunit = 92 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp*3/Rp
FpmaxASD = 3054 lbs (0.7*Fpmax)
FpmaxASD = 3245 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 2232 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 1507 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 2548 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 3261 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2239 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 519 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 1230 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2938 lbs = [FpmaxASD*Hcm+2*(1+0.14*S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1916 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 131 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 842 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 3261 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2239 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2938 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1916 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 11.000 in	a = 10.644 in = A' - (2r + t)
B' = 3.000 in	a' = 10.929 in = A' - t
C' = 1.000 in (0 if no lips)	b = 2.644 in = B' - [r + t/2 + a(r + t/2)]
o = 1.000 in (0 - no Lip; 1 w/ lip)	b' = 2.929 in = B' - [t/2 + a(t/2)]
R = 0.1069 in (Inside bend radius)	c = 0.822 in = o[C' - (r + t/2)]
t = 0.0713 in	c' = 0.964 in = o[C' - t/2]
r = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.751 in (Distance between centroid and web centerline)	
I _x = 23.130 in (Moment of Inertia about X-Axis)	
I _y = 1.555 in (Moment of Inertia about Y-Axis)	
A = 1.32 in ²	
r _x = 4.19 in	
r _y = 1.087 in	
r _{min} = 1.087 in	



Axial Compression

P_u = 1.527 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 27.790 k
F_e = 76.14 ksi $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 0.81 If λ_c ≤ 1.5; F_n = (0.658<sup>λ_c²) F_y
F_n = 37.98 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 84 in Lateral unbraced length
k_yL_y/r_y = 62 (assume k=0.8)</sup>

Compression Check = O.K.

Check Web Crippling

h = 11 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 154.28 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.636364 ≤ 2.0	C _h = 0.02	
P _n = 2.529 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 1.445 k			
Long side: P _{uTrans} = 1.087 k	O.K. # clips = 3	$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _{uLong} = 0.979 k	O.K. # clips = 3		

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70
w/t_s = 118.675
1.28√(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 2.529 k P_n/Ω = 8.869 k
P_n = 15.077 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{cn}max = 763 lbs Max[F_{pmaxASD}/4 - OR- F_{hASDtrans}/4 corner connections]
V_{cn}max = 1119 lbs [Max Ten/2 corner connections per side]
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 1.0
of Bolts Used = 2.0 ***If combined fails: USE --> 3.0
Check Combined Stress in Bolts & Inserts: 0.665 O.K. StressComb = 0.443 O.K.

Check 1/8" welded connection

Assume L/t > 25: 25*t = 1.783 in Ω = 2.35
L_{req'd} = 0.757 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2377$ #

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$



Check Block shear rupture: O.K.

$F_y = 50$ ksi

$A_{gv} = 0.463$ in²

$R_n/\Omega = 7.500$ k

BSR O.K.

thinnest part = 0.0713 AISI BSR applies

$\Omega = 2.22$ bolt/screw connection

$A_{nv} = 0.443$ in² $A_{nt} = 0.042$ in²

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse: Uplift_{MAX} = 2423 lbs Shear_{MAX} = 1623 lbs

Compression_{SEISMIC} = 3509 lbs = $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 2423 lbs = $Comp_{SEISMIC} \cdot (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$

Compression_{WIND} = 699 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} - F_{vertASD} \cdot w_{curb}/2] / w_{curb}$

Tension_{WIND} = 1295 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} + F_{vertASD} \cdot w_{curb}/2] / w_{curb}$

Longitudinal: Uplift_{MAX} = 1936 lbs Shear_{MAX} = 1623 lbs

Compression_{SEISMIC} = 3022 lbs = $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 1936 lbs = $Comp_{SEISMIC} \cdot (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$

Compression_{WIND} = 149 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} - F_{vertASD} \cdot L_{curb}/2] / L_{curb}$

Tension_{WIND} = 745 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} + F_{vertASD} \cdot L_{curb}/2] / L_{curb}$

Wood Attachment: Use 5/8" ϕ wood lag screws w/ 3.5" Min. Embed

Tall_{metal} = 946.67 lbs Vall_{metal} = 1043.33 lbs

Transverse: Tall_{wood} = 1195.95 lbs Vall_{wood} = 1024 lbs

of Screws Req'd for Uplift = 2.56

of Screws Req'd for Shear = 1.58

Total # of screws Required = 4

COMBINED LOADING: 0.903 O.K.

Screw Spacing = 39.3 in o.c.

Use 5/8" ϕ wood lag screws @ 39.3 in o.c. along long side of curb

Longitudinal:

of Screws Req'd for Uplift = 2.0

of Screws Req'd for Shear = 1.6

Total # of screws Required = 4

COMBINED LOADING: 0.801 O.K.

Screw Spacing = 25.2 in o.c.

Use 5/8" ϕ wood lag screws @ 25.2 in o.c. along short side of curb

Steel Deck Attachment: Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall_{bolt} = 6903 lbs Vall_{bolt} = 3682 lbs

Transverse: Tall_{bolt} = 6903 lbs Vall_{bolt} = 3682 lbs

of Bolts Req'd for Uplift = 0.35

of Bolts Req'd for Shear = 0.44

Total # of Bolts Required = 2

COMBINED LOADING: 0.135 O.K.

Bolt Spacing = 113.8 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 113.8 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.28

of Bolts Req'd for Shear = 0.44

Total # of Bolts Required = 2

COMBINED LOADING: 0.118 O.K.

Req'd Min Spacing = 71.5 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 71.5 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

For Concrete anchorage: SEISMIC $[0.6-0.14SDSID + 0.7\Omega_o E]$ ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$\begin{aligned} T_{all,LRFD} &= 1722 \text{ lbs} & V_{all,LRFD} &= 2032 \text{ lbs} & \alpha &= (1 + 0.2SDS)D + 2.5E = 1.87 \\ T_{all,ASD} = T_{all,LRFD}/\alpha &= 920.9 \text{ lbs} & V_{all,ASD} = V_{all,LRFD}/\alpha &= 1086.6 \text{ lbs} & (D = 0.465, E = 0.535) \\ \text{Transverse:} & & \text{Uplift}_{MAX} &= 4598 \text{ lbs} & \text{Shear}_{MAX} &= 4056 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 5685 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot [WGT_{unit+curb}/2] \cdot w_{curb}] / w_{curb} \\ \text{Tension}_{SEISMIC} &= 4598 \text{ lbs} & &= \text{Comp}_{SEISMIC} - [0.6 - 0.14SDS] \cdot [WGT_{unit+curb}] \\ \text{Shear}_{SEISMIC} &= 4056 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 4.99 \text{ spacing} = 25.44 \text{ in o.c.} & \text{Applied} &= 766.3 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 3.73 \text{ spacing} = 33.91667 \text{ in o.c.} & \text{Applied} &= 676.1 \text{ lbs} \\ \text{Try using } 6 \text{ bolts} & & \text{COMBINED LOADING} &= \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.45 \\ \text{spaced at } 22.75 \text{ in o.c.} & & & & & \end{aligned}$$

Use 6 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 22.8 in o.c. max. along long side of curb w/ 4" embed

$$\begin{aligned} \text{Longitudinal:} & & \text{Uplift}_{MAX} &= 3380 \text{ lbs} & \text{Shear}_{MAX} &= 4056 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 4467 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot [WGT_{unit+curb}/2] \cdot L_{curb}] / L_{curb} \\ \text{Tension}_{SEISMIC} &= 3380 \text{ lbs} & &= \text{Comp}_{SEISMIC} - [0.6 - 0.14SDS] \cdot [WGT_{unit+curb}] \\ \text{Shear}_{SEISMIC} &= 4056 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 3.67 \text{ spacing} = 19.83333 \text{ in o.c.} & \text{Applied} &= 676.0 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 3.73 \text{ spacing} = 19.83333 \text{ in o.c.} & \text{Applied} &= 811.3 \text{ lbs} \\ \text{Try using } 5 \text{ bolts} & & \text{COMBINED LOADING} &= \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.48 \\ \text{spaced at } 17.88 \text{ in o.c.} & & & & & \end{aligned}$$

Use 5 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 17.9 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-136			
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 39.25 in o.c.	2 @ 113.75 in o.c.	6 @ 22.75 in o.c.
SHORT DIRECTION	4 @ 25.17 in o.c.	2 @ 71.5 in o.c.	5 @ 17.88 in o.c.




Client: ProVent PV1806
Description: CBKD-136 8" KDKITSLM1830
Unit: ZJ,ZR 180-300; ZF 210-300; XP 180-240

Curb Information

Hcurb = 8 in (Height of curb)
Lcurb = 125.75 in (Length of curb)
wcurb = 83.5 in (Width of curb)
WGTCurb = 192 lbs (Weight of curb)
Clips long side = 3 # Clips short side = 0

Unit Information

WGUnit = 3061.3 lbs (Weight of Unit)
Wtmax = 908 lbs (Maximum corner weight)
Wtmin = 306 lbs (Minimum corner weight)
Hunit = 52.625 in (Height of unit above curb)
Hcm = 26.3125 in (Height to center of mass)
Lunit = 136.25 in (Length of unit)
Wunit = 92 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp*3/Rp
FpmaxASD = 3054 lbs (0.7*Fpmax)
FpmaxASD = 3245 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf
Fh ASD trans = 2126 lbs = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD long = 1436 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fvert ASD = 2548 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb) (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 3261 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2239 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 486 lbs = [Fh trans ASD]*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 1197 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2938 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1916 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 116 lbs = [Fh trans ASD]*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 827 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 3261 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2239 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2938 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1916 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 8.000 in a = 7.644 in = A' - (2r + t)
B' = 3.000 in a' = 7.929 in = A' - t
C' = 1.000 in [0 if no lips] b = 2.644 in = B' - [r + t/2 + a(r + t/2)]
α = 1.000 [0 = no Lip; 1 w/ lip] b' = 2.929 in = B' - (t/2 + at/2)
R = 0.1069 [Inside bend radius] c = 0.822 in = α[C' - (r + t/2)]
t = 0.0713 in c' = 0.964 in = α[C' - t/2]
r' = 0.143 in = R + t/2 u = 0.224 in = πr/2
x = 0.896 in [Distance between centroid and web centerline]
Ix = 10.928 in [Moment of Inertia about X-Axis]
Iy = 1.411 in [Moment of Inertia about Y-Axis]
A = 1.10 in²
rx = 3.15 in
ry = 1.131 in
rmin = 1.131 in



Axial Compression

Pu = 1.527 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 23.774 k
Fe = 82.49 ksi
λc = 0.78
Fn = 38.80 ksi
Ly = 84 in
k_yL_y/r_y = 59

If λ_c ≤ 1.5; F_n = (0.658<sup>λ_c²) F_y
If λ_c > 1.5; F_n = 0.877 F_y
λ_c = √(F_y/F_e) F_e = (π²E)/(kl/r)²</sup>

Lateral unbraced length
(assume k=0.8)

Compression Check = **O.K.**

Check Web Crippling

h = 8 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 112.20 ≤ 200 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.875 ≤ 2.0 C_h = 0.02
P_n = 2.652 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.515 k
Long side: P_{uTrans} = 1.087 k
Short side: P_{uLong} = 1.469 k

P_n = C t² F_y sin(90) (1 - C_R √(R/t)) (1 + C_N √(N/t)) (1 - C_h √(h/t))
clips = 3
clips = 2

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/F_y Ωc = 1.70
w/ts = 118.675
1.28√E/F_y = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.652 k A_e = 0.380 in²
P_n = 15.163 k P_n/Ω = 8.919 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{cnmax} = 763 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{cnmax} = 1119 lbs [Max Ten/2 corner connections per side]
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs

of Bolts required for Tension = 0.3

of Bolts required for Shear = 1.0

of Bolts Used = 2.0

***If combined fails:

USE --> 3.0

Check Combined Stress in Bolts & Inserts: 0.665 O.K.

StressComb = 0.443 O.K.

Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

Assume L/t > 25*t = 1.783 in

P_n/Ω = 1/Ω 0.75tL F_u ≥ V_{req}

L_{req'd} = V_{req}Ω / (0.75tF_u)

L_{req'd} = 0.757 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$



Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side: 3.054	3	1.02	540 #	2	6.00 in
Short side: 3.054	2	1.53	540 #	3	3.00 in

clip width (in) = 7.00

min spacing = 0.57 in

clip height = 1.4 in

edge distance = 0.5 in (min. 1.5d)

thinnest part = 0.0713 AISI BSR applies

Check Block shear rupture: O.K.

$F_y = 50$ ksi

$A_{gv} = 0.463$ in²

$R_n/\Omega = 7.500$ k

$\Omega = 2.22$ bolt/screw connection

$A_{nv} = 0.430$ in²

$A_{nt} = 0.042$ in²

BSR O.K.

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ [AISI Sect. E5.3]

Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:

Uplift_{MAX} = 2306 lbs

Shear_{MAX} = 1623 lbs

Compression_{SEISMIC} = 3393 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}]/w_{curb}$

Tension_{SEISMIC} = 2306 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$

Compression_{WIND} = 576 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2]/w_{curb}$

Tension_{WIND} = 1172 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2]/w_{curb}$

Longitudinal: Uplift_{MAX} = 1858 lbs Shear_{MAX} = 1623 lbs

Compression_{SEISMIC} = 2945 lbs = $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}]/L_{curb}$

Tension_{SEISMIC} = 1858 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$

Compression_{WIND} = 94 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2]/L_{curb}$

Tension_{WIND} = 690 lbs = $[F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2]/L_{curb}$

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Transverse:

Tall_{wood} = 1195.95 lbs

Vall_{wood} = 1024 lbs

of Screws Req'd for Uplift = 2.44

of Screws Req'd for Shear = 1.58

Total # of screws Required = 4

COMBINED LOADING: 0.878 O.K.

Screw Spacing = 39.3 in o.c.

Use 5/8" ϕ wood lag screws @ 39.3 in o.c. along long side of curb

Longitudinal:

of Screws Req'd for Uplift = 2.0

of Screws Req'd for Shear = 1.6

Total # of screws Required = 3

COMBINED LOADING: 1.046 NO GOOD

Screw Spacing = 37.8 in o.c.

Use 5/8" ϕ wood lag screws @ 37.8 in o.c. along short side of curb

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall_{bolt} = 6903 lbs

Vall_{bolt} = 3682 lbs

Transverse:

Tall_{bolt} = 6903 lbs

Vall_{bolt} = 3682 lbs

of Bolts Req'd for Uplift = 0.33

of Bolts Req'd for Shear = 0.44

Total # of Bolts Required = 2

COMBINED LOADING: 0.131 O.K.

Bolt Spacing = 113.8 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 113.8 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.27

of Bolts Req'd for Shear = 0.44

Total # of Bolts Required = 2

COMBINED LOADING: 0.116 O.K.

Req'd Min Spacing = 71.5 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 71.5 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_eE (Ω_e = 2.5)

Concrete Attachment: 3/4" φ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$\begin{aligned} T_{all,LRFD} &= 1722 \text{ lbs} & V_{all,LRFD} &= 2032 \text{ lbs} & \alpha &= (1 + 0.2SDS)D + 2.5E = 1.87 \\ T_{all,ASD} &= T_{all,LRFD}/\alpha = 920.9 \text{ lbs} & V_{all,ASD} &= V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} & (D = 0.465, E = 0.535) \\ \text{Transverse:} & & \text{Uplift}_{MAX} &= 4307 \text{ lbs} & \text{Shear}_{MAX} &= 4056 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 5393 \text{ lbs} & &= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb} \\ \text{Tension}_{SEISMIC} &= 4307 \text{ lbs} & &= \text{Comp}_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 4056 \text{ lbs} & &= 2.5 * F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 4.68 \text{ spacing} = 25.44 \text{ in o.c.} & & \text{Tapplied} = 717.8 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 3.73 \text{ spacing} = 33.91667 \text{ in o.c.} & & \text{Vapplied} = 676.1 \text{ lbs} \end{aligned}$$

Try using 6 bolts spaced at 22.75 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.40$
---	--

Use 6 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 22.8 in o.c. max. along long side of curb w/ 4" embed

$$\begin{aligned} \text{Longitudinal:} & & \text{Uplift}_{MAX} &= 3186 \text{ lbs} & \text{Shear}_{MAX} &= 4056 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 4273 \text{ lbs} & &= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb} \\ \text{Tension}_{SEISMIC} &= 3186 \text{ lbs} & &= \text{Comp}_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 4056 \text{ lbs} & &= 2.5 * F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 3.46 \text{ spacing} = 19.83333 \text{ in o.c.} & & \text{Tapplied} = 637.3 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 3.73 \text{ spacing} = 19.83333 \text{ in o.c.} & & \text{Vapplied} = 811.3 \text{ lbs} \end{aligned}$$

Try using 5 bolts spaced at 17.88 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.44$
---	--

Use 5 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 17.9 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-136			
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 2 clips with 3 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" φ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" φ A307 bolts	3/4" φ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 39.25 in o.c.	2 @ 113.75 in o.c.	6 @ 22.75 in o.c.
SHORT DIRECTION	3 @ 37.75 in o.c.	2 @ 71.5 in o.c.	5 @ 17.88 in o.c.