



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBKD-141 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 1, 2019
Project Number: PV1806

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60.




Will conform to seismic code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)

STRUCTURALLY CALCULATED KNOCK-DOWN ROOF CURBS FOR YORK UNITS



ZX, ZY 08-12; ZX 14; ZY 07

ProVent P/N	A	WEIGHT	SEISMIC KIT P/N	WEIGHT
CBKDPRL08	8"	115 Lbs	KDKITPRL	60 Lbs
CBKDPRL11	11"	129 Lbs		
CBKDPRL14	14"	144 Lbs		

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



HOLD DOWN DETAIL



3847 WABASH DRIVE
MIRA LOMA, CA 91725
PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBKD-141

PART NUMBER:
KDKITPRL Series

DATE:
01/07/19

REV:
4

DRAWN BY:
ALL




Client: ProVent PV1806
Description: CBKD-141 14" KDKITPRL
Unit: ZX, ZY 08-12; ZX 14; ZY 07

Curb Information

Hcurb = 14 in (Height of curb)
Lcurb = 84 in (Length of curb)
wcurb = 53.5 in (Width of curb)
WGTCurb = 204 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 1

Unit Information

WGTunit = 653 lbs (Weight of Unit)
Wtmax = 176 lbs (Maximum corner weight)
Wtmin = 151 lbs (Minimum corner weight)
Hunit = 40.56 in (Height of unit above curb)
Hcm = 20.28 in (Height to center of mass)
Lunit = 74.05 in (Length of unit)
Wunit = 48.88 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp*3/Rp
FpmaxASD = 651 lbs (0.7*Fpmax)
FpmaxASD = 855 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 1040 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 687 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 736 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 693 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 474 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 238 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 581 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 603 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 385 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 9 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 353 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 693 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 581 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 603 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 385 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 14.000 in	a = 13.644 in = A' - (2r + t)
B' = 3.000 in	a' = 13.929 in = A' - t
C' = 1.000 in [0 if no lips]	b = 2.644 in = B' - [r + t/2 + a(r + t/2)]
α = 1.000 [0 - no Lip; 1 w/ lip]	b' = 2.929 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.822 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.964 in = α[C' - t/2]
r = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.646 in (Distance between centroid and web centerline)	
I _x = 41.261 in (Moment of Inertia about X-Axis)	
I _y = 1.659 in (Moment of Inertia about Y-Axis)	
A = 1.53 in ²	
r _x = 5.19 in	
r _y = 1.041 in	
r _{min} = 1.041 in	



Axial Compression

P_u = 0.520 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 31.517 k
F_e = 69.87 ksi $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 0.85 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 37.06 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 84 in Lateral unbraced length
k_yL_y/r_y = 65 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 14 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 196.35 ≤ 200 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
α_w = 1.75 N/h = 0.5 ≤ 2.0 C_h = 0.02
P_n = 2.422 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.384 k $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$
Long side: P_{uTrans} = 0.346 k **O.K.** # clips = 2
Short side: P_{uLong} = 0.201 k **O.K.** # clips = 3

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28V_e/F_y Ω_c = 1.70
w/t_s = 118.675
1.28V_e(E/F_y) = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 2.422 k P_n/Ω = 8.825 k
P_n = 15.002 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded Inserts

T_{crnmax} = 260 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 291 lbs (Max Ten/2 corner connections per side)
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs
of Bolts required for Tension = 0.1
of Bolts required for Shear = 0.3
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.370 **O.K.** StressComb = 0.185 **O.K.**

***If combined fails:
USE --> 2.0

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.197 in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 < 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2377$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2377$ #

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.38 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 792$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.040	2	0.52	540 #	2	6.00 in
Short side:	0.687	3	0.23	540 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.443$ in²


$A_{nt} = 0.042$ in²

$R_n/\Omega = 7.500$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX} =	804 lbs	Shear _{MAX} =	520 lbs
-------------	-------------------------	---------	------------------------	---------

Compression_{SEISMIC} = 1090 lbs = $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 804 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb})$

Compression_{WIND} = 556 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} - F_{vertASD} \cdot w_{curb}/2] / w_{curb}$

Tension_{WIND} = 777 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} + F_{vertASD} \cdot w_{curb}/2] / w_{curb}$

Longitudinal:	Uplift _{MAX} =	605 lbs	Shear _{MAX} =	427 lbs
---------------	-------------------------	---------	------------------------	---------

Compression_{SEISMIC} = 891 lbs = $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 605 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb})$

Compression_{WIND} = 169 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} - F_{vertASD} \cdot L_{curb}/2] / L_{curb}$

Tension_{WIND} = 391 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} + F_{vertASD} \cdot L_{curb}/2] / L_{curb}$

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

$T_{allmetal} = 946.67$ lbs

$V_{allmetal} = 1043.33$ lbs

$T_{allwood} = 1195.95$ lbs

$V_{allwood} = 1024$ lbs

Transverse:

of Screws Req'd for Uplift = 0.85

COMBINED LOADING: 0.839 O.K.

of Screws Req'd for Shear = 0.51

Screw Spacing = #DIV/0! in o.c.

Total # of screws Required = 1

#DIV/0!

Longitudinal:

of Screws Req'd for Uplift = 0.6

COMBINED LOADING: 0.175 O.K.

of Screws Req'd for Shear = 0.4

Screw Spacing = 45.5 in o.c.

Total # of screws Required = 2

Use 5/8" ϕ wood lag screws @ 45.5 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

Transverse:

of Bolts Req'd for Uplift = 0.12

COMBINED LOADING: 0.021 O.K.

of Bolts Req'd for Shear = 0.14

Bolt Spacing = 72.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 72 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.09

COMBINED LOADING: 0.014 O.K.

of Bolts Req'd for Shear = 0.12

Req'd Min Spacing = 41.5 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 41.5 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ____ of ____

For Concrete anchorage: SEISMIC $[0.6-0.14SDS]D + 0.7\Omega_o E$ ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$\begin{aligned} T_{all,LRFD} &= 1722 \text{ lbs} & V_{all,LRFD} &= 2032 \text{ lbs} & \alpha &= (1 + 0.2SDS)D + 2.5E = 1.87 \\ T_{all,ASD} = T_{all,LRFD}/\alpha &= 920.9 \text{ lbs} & V_{all,ASD} = V_{all,LRFD}/\alpha &= 1086.6 \text{ lbs} & (D = 0.465, E = 0.535) \\ \text{Transverse:} & & \text{Uplift}_{MAX} &= 1626 \text{ lbs} & \text{Shear}_{MAX} &= 1069 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 1912 \text{ lbs} & &= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb} \\ \text{Tension}_{SEISMIC} &= 1626 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14SDS] * (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 1069 \text{ lbs} & &= 2.5 * F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 1.77 \text{ spacing} = 60.00 \text{ in o.c.} & T_{applied} &= 541.9 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.00 \text{ spacing} = 60 \text{ in o.c.} & V_{applied} &= 356.2 \text{ lbs} \\ \text{Try using } 3 \text{ bolts spaced at } 36.00 \text{ in o.c.} & \text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 & &= 0.92 \end{aligned}$$

Use 3 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 36 in o.c. max. along long side of curb w/ 4" embed

$$\begin{aligned} \text{Longitudinal:} & & \text{Uplift}_{MAX} &= 1128 \text{ lbs} & \text{Shear}_{MAX} &= 1069 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 1415 \text{ lbs} & &= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb} \\ \text{Tension}_{SEISMIC} &= 1128 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14SDS] * (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 1069 \text{ lbs} & &= 2.5 * F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 1.23 \text{ spacing} = 29.5 \text{ in o.c.} & T_{applied} &= 282.1 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.00 \text{ spacing} = 29.5 \text{ in o.c.} & V_{applied} &= 267.1 \text{ lbs} \\ \text{Try using } 4 \text{ bolts spaced at } 13.83 \text{ in o.c.} & \text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 & &= 0.55 \end{aligned}$$

Use 4 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 13.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-141			
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 2 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	#DIV/0!	2 @ 72 in o.c.	3 @ 36 in o.c.
SHORT DIRECTION	2 @ 45.5 in o.c.	2 @ 41.5 in o.c.	4 @ 13.83 in o.c.




Client: ProVent PV1806
Description: CBKD-141 11" KDKITPRL
Unit: ZX, ZY 08-12; ZX 14; ZY 07

Curb Information

Hcurb = 11 in (Height of curb)
Lcurb = 84 in (Length of curb)
wcurb = 53.5 in (Width of curb)
WGTCurb = 204 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 1

Unit Information

WGTunit = 653 lbs (Weight of Unit)
Wtmax = 176 lbs (Maximum corner weight)
Wtmin = 151 lbs (Minimum corner weight)
Hunit = 40.56 in (Height of unit above curb)
Hcm = 20.28 in (Height to center of mass)
Lunit = 74.05 in (Length of unit)
Wunit = 48.88 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp*3/Rp
FpmaxASD = 651 lbs (0.7*Fpmax)
FpmaxASD = 855 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf
FhASD trans = 983 lbs
FhASD long = 649 lbs
FvertASD = 736 lbs
= 0.00256*Kz*Kzt*Kd*V² [Eq. 29.3-1 ASCE 7-10]
= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) [Eq. 29.5-2]
= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
= 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

Compression_{SEISMIC} = 693 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 474 lbs = Comp_{SEISMIC}-[0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 216 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 560 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 603 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 385 lbs = Comp_{SEISMIC}-[0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 0 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 344 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 693 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 560 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 603 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 385 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

$F_y = 50$ ksi $F_u = 65$ ksi $t = 0.0566$ 16 Gauge
 $E = 29500$ ksi

Calculate Section Properties of Curb

$A' = 11.000$ in	$a = 10.717$ in = $A' - (2r+t)$
$B' = 3.000$ in	$a' = 10.943$ in = $A' - t$
$C' = 1.000$ in (0 if no lips)	$b = 2.717$ in = $B' - [r+t/2+a(r+t/2)]$
$a = 1.000$ in (0 - no Lip; 1 w/ lip)	$b' = 2.943$ in = $B' - [t/2+at/2]$
$R = 0.0849$ (Inside bend radius)	$c = 0.859$ in = $a[C' - (r+t/2)]$
$t = 0.0566$ in	$c' = 0.972$ in = $a[C' - t/2]$
$r' = 0.113$ in = $R+t/2$	$u = 0.178$ in = $\pi r/2$
$x = 0.759$ in (Distance between centroid and web centerline)	
$I_x = 18.573$ in (Moment of Inertia about X-Axis)	
$I_y = 1.261$ in (Moment of Inertia about Y-Axis)	
$A = 1.05$ in ²	
$r_x = 4.20$ in	
$r_y = 1.095$ in	
$r_{min} = 1.095$ in	



Axial Compression

$P_u = 0.491$ k (Max Axial Comp) $\Omega_c = 1.80$
 $P_n/\Omega_c = 22.286$ k
 $F_e = 77.34$ ksi
 $\lambda_c = 0.80$
 $F_n = 38.15$ ksi
 $L_y = 84$ in
 $k_y L_y/r_y = 61$

If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume $k=0.8$)

Compression Check = O.K.

Check Web Crippling

$h = 11$ in -- Check limits: $C = 4.00$
 $t = 0.0566$ in $h/t = 194.35 \leq 200$ $C_R = 0.14$
 $N = 7.00$ $N/t = 123.67 \leq 210$ $C_N = 0.35$
 $\Omega_w = 1.75$ $N/h = 0.636364 \leq 2.0$ $C_h = 0.02$
 $P_n = 1.674$ k
 $P_n/\Omega_w = 0.957$ k
Long side: $P_{uTrans} = 0.346$ k
Short side: $P_{uLong} = 0.201$ k

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

O.K. # clips = 2
O.K. # clips = 3

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)
width of stiffener = 7.000 in $t_s = 0.0566$ 16 Gauge
web of stiff. $w = 6.717$ in $R_s = 0.0849$ in
***Check $w/t_s \leq 1.28\sqrt{E/F_y}$ $\Omega_c = 1.70$
 $w/t_s = 118.675$
 $1.28\sqrt{E/F_y} = 31.091$ --> w/t_s over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$
 $P_{wc} = 1.674$ k $A_e = 0.380$ in²
 $P_n = 14.478$ k $P_n/\Omega = 8.517$ k

Not Req'd

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
 $T_{cnmax} = 246$ lbs $\text{Max}(F_{pmASD}/4 - \text{OR} - F_{hASDTrans}/4 \text{ corner connections})$
 $V_{cnmax} = 280$ lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.1
of Bolts required for Shear = 0.3
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.354 **O.K.** StressComb = 0.177 **O.K.**

***If combined fails: USE --> 2.0

Check 1/8" welded connection

<--- USE WELD $\Omega = 2.35$
Assume $L/t > 25$; $25 \cdot t = 1.415$ in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req} = \frac{V_{req} \Omega}{0.75 t F_u}$
 $L_{req'd} = 0.238$ in



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

$P_{ns} = 1887$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 1887$ #

Shear:

$P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 629$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension:

$P_{not} = 1.068$ k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$P_{nov} = 2.069$ k (screw pull-over strength)

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

	Shear [k]	# clips	V_{clip} [k]	V_{allow} [lb]	# screws	spacing
Long side:	0.983	2	0.49	540 #	2	6.00 in
Short side:	0.651	3	0.22	540 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.57 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: 0.K.

thinnest part = 0.0566 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.368$ in²

$A_{nv} = 0.352$ in²

$A_{nt} = 0.034$ in²

$R_n/\Omega = 5.954$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR 0.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX}	756 lbs	Shear _{MAX}	491 lbs
Compression _{SEISMIC}	1042 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$		
Tension _{SEISMIC}	756 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$		
Compression _{WIND}	464 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$		
Tension _{WIND}	685 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$		
Longitudinal:	Uplift _{MAX}	575 lbs	Shear _{MAX}	427 lbs
Compression _{SEISMIC}	861 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$		
Tension _{SEISMIC}	575 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$		
Compression _{WIND}	131 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$		
Tension _{WIND}	352 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$		

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Tall _{metal}	946.67 lbs	Vall _{metal}	1043.33 lbs
Tall _{wood}	1195.95 lbs	Vall _{wood}	1024 lbs
# of Screws Req'd for Uplift	0.80	COMBINED LOADING:	0.760 O.K.
# of Screws Req'd for Shear	0.48	Screw Spacing	#DIV/0! in o.c.
Total # of screws Required	1		

#DIV/0!

Longitudinal:

# of Screws Req'd for Uplift	0.6	COMBINED LOADING:	0.166 O.K.
# of Screws Req'd for Shear	0.4	Screw Spacing	45.5 in o.c.
Total # of screws Required	2		

Use 5/8" ϕ wood lag screws @ 45.5 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall _{bolt}	6903 lbs	Vall _{bolt}	3682 lbs
Tall _{deck}	6903 lbs	Vall _{deck}	3682 lbs
# of Bolts Req'd for Uplift	0.11	COMBINED LOADING:	0.019 O.K.
# of Bolts Req'd for Shear	0.13	Bolt Spacing	72.0 in o.c.
Total # of Bolts Required	2		

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 72 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift	0.08	COMBINED LOADING:	0.014 O.K.
# of Bolts Req'd for Shear	0.12	Req'd Min Spacing	41.5 in o.c.
Total # of Bolts Required	2		

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 41.5 in o.c. along short side of curb



For Concrete anchorage: SEISMIC $0.6-0.14S_{DS}D + 0.7\Omega_0 E$ ($\Omega_0 = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$\begin{aligned} T_{all,LRFD} &= 1722 \text{ lbs} & V_{all,LRFD} &= 2032 \text{ lbs} & \alpha &= (1 + 0.2SDS)D + 2.5E = 1.87 \\ T_{all,ASD} &= T_{all,LRFD}/\alpha = 920.9 \text{ lbs} & V_{all,ASD} &= V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} & (D = 0.465, E = 0.535) \\ \text{Transverse:} & & Uplift_{MAX} &= 1506 \text{ lbs} & Shear_{MAX} &= 1069 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 1792 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb} \\ \text{Tension}_{SEISMIC} &= 1506 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 1069 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 1.64 \text{ spacing} = 60.00 \text{ in o.c.} & T_{applied} &= 501.9 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.00 \text{ spacing} = 60 \text{ in o.c.} & V_{applied} &= 356.2 \text{ lbs} \end{aligned}$$

Try using 3 bolts spaced at 36.00 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.87$
---	--

Use 3 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 36 in o.c. max. along long side of curb w/ 4" embed

$$\begin{aligned} \text{Longitudinal:} & & Uplift_{MAX} &= 1052 \text{ lbs} & Shear_{MAX} &= 1069 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 1338 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb} \\ \text{Tension}_{SEISMIC} &= 1052 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 1069 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 1.14 \text{ spacing} = 29.5 \text{ in o.c.} & T_{applied} &= 263.0 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.00 \text{ spacing} = 29.5 \text{ in o.c.} & V_{applied} &= 267.1 \text{ lbs} \end{aligned}$$

Try using 4 bolts spaced at 13.83 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.53$
---	--

Use 4 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 13.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-141			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 2 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	#DIV/0!	2 @ 72 in o.c.	3 @ 36 in o.c.
SHORT DIRECTION	2 @ 45.5 in o.c.	2 @ 41.5 in o.c.	4 @ 13.83 in o.c.




Client: ProVent PV1806
Description: CBKD-141 8" KDKITPRL
Unit: ZX, ZY 08-12; ZX 14; ZY 07

Curb Information

Hcurb = 8 in (Height of curb)
Lcurb = 84 in (Length of curb)
wcurb = 53.5 in (Width of curb)
WGTCurb = 204 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 1

Unit Information

WGTunit = 653 lbs (Weight of Unit)
Wtmax = 176 lbs (Maximum corner weight)
Wtmin = 151 lbs (Minimum corner weight)
Hunit = 40.56 in (Height of unit above curb)
Hcm = 20.28 in (Height to center of mass)
Lunit = 74.05 in (Length of unit)
Wunit = 48.88 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp/3/Rp
FpmaxASD = 651 lbs (0.7*Fpmax)
FpmaxASD = 855 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 926 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 611 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 736 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 693 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 474 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 194 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 538 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 603 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 385 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = -9 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 335 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 693 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 538 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 603 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 385 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

$F_y = 50$ ksi $F_u = 65$ ksi $t = 0.0566$ 16 Gauge
 $E = 29500$ ksi

Calculate Section Properties of Curb

$A' = 8.000$ in	$a = 7.717$ in $= A' - (2r + t)$
$B' = 3.000$ in	$a' = 7.943$ in $= A' - t$
$C' = 1.000$ in (0 if no lips)	$b = 2.717$ in $= B' - [r + t/2 + a(r + t/2)]$
$d = 1.000$ (0 - no Lip; 1 w/ lip)	$b' = 2.943$ in $= B' - [t/2 + at/2]$
$R = 0.0849$ (Inside bend radius)	$c = 0.859$ in $= a[C' - (r + t/2)]$
$t = 0.0566$ in	$c' = 0.972$ in $= a[C' - t/2]$
$r' = 0.113$ in $= R + t/2$	$u = 0.178$ in $= \pi r/2$
$x = 0.905$ in (Distance between centroid and web centerline)	
$I_x = 8.792$ in (Moment of Inertia about X-Axis)	
$I_y = 1.145$ in (Moment of Inertia about Y-Axis)	
$A = 0.88$ in ²	
$r_x = 3.16$ in	
$r_y = 1.139$ in	
$r_{min} = 1.139$ in	



Axial Compression

$P_u = 0.463$ k (Max Axial Comp) $\Omega_c = 1.80$
 $P_n/\Omega_c = 19.076$ k
 $F_e = 83.71$ ksi
 $\lambda_c = 0.77$
 $F_n = 38.94$ ksi
 $L_y = 84$ in
 $K_y L_y/r_y = 59$

$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(K L/r)^2}$

Lateral unbraced length (assume $k=0.8$)

Compression Check = **0.K**

Check Web Crippling

$h = 8$ in -- Check limits: $C = 4.00$
 $t = 0.0566$ in $h/t = 141.34 \leq 200$ $C_R = 0.14$
 $N = 7.00$ $N/t = 123.67 \leq 210$ $C_N = 0.35$
 $\Omega_w = 1.75$ $N/h = 0.875 \leq 2.0$ $C_h = 0.02$
 $P_n = 1.770$ k $R/t = 1.50 \leq 9.0$
 $P_n/\Omega_w = 1.011$ k
Long side: $P_{uTrans} = 0.346$ k
Short side: $P_{uLong} = 0.201$ k

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$
0.K # clips = 2
0.K # clips = 3

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)
width of stiffener = 7.000 in $t_s = 0.0566$ 16 Gauge
web of stiff. $w = 6.717$ in $R_s = 0.0849$ in
***Check $w/t_s \leq 1.28\sqrt{E/F_y}$ $\Omega_c = 1.70$
 $w/t_s = 118.675$
 $1.28\sqrt{E/F_y} = 31.091$ --> w/t_s over limit Use C3.7.2
 $P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$
 $P_{wc} = 1.770$ k $A_e = 0.380$ in²
 $P_n = 14.545$ k $P_n/\Omega = 8.556$ k

Not Req'd

Corner Connections

1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
 $T_{crnmax} = 231$ lbs $\text{Max}[F_{pmASU}/4 \text{ -OR- } F_{ASUtrans}/4 \text{ corner connections}]$
 $V_{crnmax} = 269$ lbs (Max Ten/2 corner connections per side)
Bolt: $T_{all} = 2480$ lbs $V_{all} = 1096$ lbs
Threaded Insert: $T_{all} = 2860$ lbs $V_{all} = 1714$ lbs
of Bolts required for Tension = 0.1
of Bolts required for Shear = 0.2
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.339 **0.K** StressComb = 0.169 **0.K**

***If combined fails: USE --> 2.0

Check 1/8" welded connection

Assume $L/t > 25$; $25 \times t = 1.415$ in $\Omega = 2.35$
 $L_{req'd} = 0.229$ in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{us} = 4.2F_{u2}\sqrt{t_2d}$ 3.86 k

$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 629$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{nol} = 1.068$ k (screw pull-out strength)

$P_{nov} = 2.069$ k (screw pull-over strength)

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

(full tensile screw capacity)

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 1887$ #


$P_{ns} = 2.7t_1dF_{u1}$ 1.89 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$



Check Block shear rupture: 0.K.

$F_y = 50$ ksi

$A_{gv} = 0.368$ in²

$R_n/\Omega = 5.954$ k

BSR O.K.

thinnest part = 0.0566 AISI BSR applies

$\Omega = 2.22$ bolt/screw connection

$A_{nv} = 0.352$ in² $A_{nt} = 0.034$ in²

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$
(AISI Sect. E5.3)

Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14SDS)D + 0.7E$

WIND: $0.6D + W$

Transverse:

Uplift_{MAX} = 708 lbs

Shear_{MAX} = 463 lbs

Compression_{SEISMIC} = 994 lbs $= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 708 lbs $= Comp_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb})$

Compression_{WIND} = 379 lbs $= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$

Tension_{WIND} = 600 lbs $= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$

Longitudinal: Uplift_{MAX} = 544 lbs

Shear_{MAX} = 427 lbs

Compression_{SEISMIC} = 830 lbs $= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 544 lbs $= Comp_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb})$

Compression_{WIND} = 95 lbs $= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$

Tension_{WIND} = 316 lbs $= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

$T_{allmetal} = 946.67$ lbs

$V_{allmetal} = 1043.33$ lbs

Transverse:

$T_{allwood} = 1195.95$ lbs

$V_{allwood} = 1024$ lbs

of Screws Req'd for Uplift = 0.75

of Screws Req'd for Shear = 0.45

Total # of screws Required = 1

COMBINED LOADING: 0.684 O.K.

Screw Spacing = #DIV/0! in o.c.

#DIV/0!

Longitudinal:

of Screws Req'd for Uplift = 0.6

of Screws Req'd for Shear = 0.4

Total # of screws Required = 2

COMBINED LOADING: 0.158 O.K.

Screw Spacing = 45.5 in o.c.

Use 5/8" ϕ wood lag screws @ 45.5 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

Transverse:

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

of Bolts Req'd for Uplift = 0.10

of Bolts Req'd for Shear = 0.13

Total # of Bolts Required = 2

COMBINED LOADING: 0.017 O.K.

Bolt Spacing = 72.0 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 72 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.08

of Bolts Req'd for Shear = 0.12

Total # of Bolts Required = 2

COMBINED LOADING: 0.013 O.K.

Req'd Min Spacing = 41.5 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 41.5 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ___ of ___

For Concrete anchorage: SEISMIC $[0.6-0.14SDS]D + 0.7Q_oE$ ($Q_o = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti HIT-HY 200 adhesive anchors w/ 4" embed

$$T_{all,LRFD} = 1722 \text{ lbs} \quad V_{all,LRFD} = 2032 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.87$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 920.9 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} \quad (D = 0.465, E = 0.535)$$

Transverse:	Uplift_{MAX} =	1386 lbs	Shear_{MAX} =	1069 lbs
--------------------	-------------------------------	-----------------	------------------------------	-----------------

$$\text{Compression}_{SEISMIC} = 1672 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 1386 \text{ lbs} = \text{Comp}_{SEISMIC} \cdot [0.6 - 0.14SDS] \cdot (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 1069 \text{ lbs} = 2.5 \cdot F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.51 \text{ spacing} = 60.00 \text{ in o.c.} \quad T_{applied} = 462.0 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 60 \text{ in o.c.} \quad V_{applied} = 356.2 \text{ lbs}$$

Try using 3 bolts spaced at 36.00 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.83$
--	--

Use 3 - 3/4" ϕ Hilti HIT-HY 200 adhesive anchors @ 36 in o.c. max. along long side of curb w/ 4" embed

Longitudinal:	Uplift_{MAX} =	976 lbs	Shear_{MAX} =	1069 lbs
----------------------	-------------------------------	----------------	------------------------------	-----------------

$$\text{Compression}_{SEISMIC} = 1262 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 976 \text{ lbs} = \text{Comp}_{SEISMIC} \cdot [0.6 - 0.14SDS] \cdot (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 1069 \text{ lbs} = 2.5 \cdot F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 1.06 \text{ spacing} = 29.5 \text{ in o.c.} \quad T_{applied} = 243.9 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.00 \text{ spacing} = 29.5 \text{ in o.c.} \quad V_{applied} = 267.1 \text{ lbs}$$

Try using 4 bolts spaced at 13.83 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.51$
--	--

Use 4 - 3/4" ϕ Hilti HIT-HY 200 adhesive anchors @ 13.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-141			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 3 clips with 2 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 2 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD 5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	STEEL 5/8" ϕ A307 bolts	CONCRETE 3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	#DIV/0!	2 @ 72 in o.c.	3 @ 36 in o.c.
SHORT DIRECTION	2 @ 45.5 in o.c.	2 @ 41.5 in o.c.	4 @ 13.83 in o.c.