



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

Structural Calculations
for
CBKD-80 Series



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 1, 2019
Project Number: PV1806

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-60.






Will conform to seismic code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)

STRUCTURALLY CALCULATED KNOCK-DOWN ROOF CURBS FOR YORK UNITS

ZT, ZR, ZJ, ZH, ZH 037-150
ZF, ZH, ZJ, ZR, XP, DH, DM, DF, DR, BP 078-150

ProVent P/N	A	WEIGHT	SEISMIC KIT P/N	WEIGHT
CBKDPDRD371508	8"	115 Lbs	KDKITPRD371508	8 Lbs
CBKDPDRD371511	11"	129 Lbs	KDKITPRD371511	10 Lbs
CBKDPDRD371514	14"	144 Lbs	KDKITPRD371514	11 Lbs

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



3847 WABASH DRIVE
MIRA LOMA, CA 91725
PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBKD-80
DATE:
01/07/19
REV:
3

PART NUMBER:
KDKITPRD3715 Series
DRAWN BY:
ALL




Client: ProVent PV1806
Description: CBKD-80 14" KDKITPRD3715**
Unit: ZT,ZR,ZJ,ZH 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150

Curb Information

Hcurb = 14 in (Height of curb)
Lcurb = 80.875 in (Length of curb)
wcurb = 51 in (Width of curb)
WGTCurb = 155 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 0

Unit Information

WGTunit = 1700 lbs (Weight of Unit)
Wtmax = 329 lbs (Maximum corner weight)
Wtmin = 191 lbs (Minimum corner weight)
Hunit = 50.75 in (Height of unit above curb)
Hcm = 25.375 in (Height to center of mass)
Lunit = 89 in (Length of unit)
Wunit = 59 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp*3/Rp
FpmaxASD = 1696 lbs (0.7*Fpmax) FpmaxASD = 1850 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² [Eq. 29.3-1 ASCE 7-10]
FhASDtrans = 1484 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) [Eq. 29.5-2]
FhASDlong = 983 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
FvertASD = 1067 lbs = 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

CompressionSEISMIC = 1677 lbs = [FpmaxASD*Hcm+2*(1+0.14Sps)*Wtmax*wcurb]/wcurb
TensionSEISMIC = 1109 lbs = CompSEISMIC-(0.6-0.14Sps)*WGTunit
CompressionWIND = 599 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
TensionWIND = 647 lbs = CompWIND+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

CompressionSEISMIC = 1365 lbs = [FpmaxASD*Hcm+2*(1+0.14Sps)*Wtmax*Lcurb]/Lcurb
TensionSEISMIC = 797 lbs = CompSEISMIC-(0.6-0.14Sps)*WGTunit
CompressionWIND = 170 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
TensionWIND = 217 lbs = CompWIND+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	CompMAX = 1677 lbs	---> Along long edge of curb.
(on long edge)	TensMAX = 1109 lbs	---> Along long edge of curb.
Longitudinal:	CompMAX = 1365 lbs	---> Along short edge of curb.
(on short edge)	TensMAX = 797 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 16 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 14.000 in a = 13.644 in = A' - (2r + t)
B' = 2.000 in a' = 13.929 in = A' - t
C' = 0.000 in (0 if no lips) b = 1.822 in = B' - [r + t/2 + a(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip) b' = 1.964 in = B' - [t/2 + αt/2]
R = 0.1069 (Inside bend radius) c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R + t/2 u = 0.224 in = πr/2
x = 0.218 in (Distance between centroid and web centerline)
Ix = 29.228 in (Moment of Inertia about X-Axis)
Iy = 0.300 in (Moment of Inertia about Y-Axis)
A = 1.26 in²
rx = 4.81 in
ry = 0.487 in
rmin = 0.487 in



Axial Compression

Pu = 0.848 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 21.644 k
Fe = 43.22 ksi
λc = 1.08
Fn = 30.81 ksi
Ly = 50 in
kyLy/ry = 82
Lateral unbraced length (assume k=0.8)

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

$$\lambda_c = \sqrt{\frac{F_y}{F_c}} \quad F_c = \frac{\pi^2 E}{(kl/r)^2}$$

Compression Check = O.K.

Check Web Crippling

h = 14 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 196.35 ≤ 200 CR = 0.14
N = 7.00 N/t = 98.18 ≤ 210 CN = 0.35
Ωw = 1.75 N/h = 0.5 ≤ 2.0 Ch = 0.02
Pn = 2.422 k R/t = 1.50 ≤ 9.0
Pn/Ωw = 1.384 k
Long side: PuTrans = 0.838 k
Short side: PuLong = 0.683 k

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

O.K. # clips = 2
O.K. # clips = 2

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/Fys Ωc = 1.70
w/ts = 118.675
1.28√E/Fys = 31.091 --> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc
Pwc = 2.422 k Ae = 0.380 in²
Pn = 15.002 k Pn/Ω = 8.825 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcornmax = 424 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcornmax = 554 lbs (Max Ten/2 corner connections per side)

Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs

of Bolts required for Tension = 0.2

of Bolts required for Shear = 0.5

of Bolts Used = 1.0

Check Combined Stress in Bolts & Inserts: 0.677 O.K.

***If combined fails:

USE --> 2.0

StressComb = 0.338 O.K.

Check 1/8" welded connection

<--- USE WELD

Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in

Lreq'd = 0.375 in

$$P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$$

$$L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$



Connection Unit to Curb Clip

#14 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.242$ in (screw diameter)

$d_w = 0.500$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2 F_{u2} \sqrt{t_2^3/d}$

$P_{ns} = 3028$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 3028$ #

$P_{ns} = 2.7 t_1 d F_{u1}$

$P_{ns} = 2.7 t_1 d F_{u1}$

$P_{ns} = 2.7 t_2 d F_{u2}$

$P_{ns} = 2.7 t_2 d F_{u2}$

$P_{ns}/\Omega = 1009$ # <- Controls

$P_{ss}/\Omega = 1045$ #

Tension: $P_{not} = 1.360$ k (screw pull-out strength)

$P_{not} = 0.85 t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 3.476$ k (screw pull-over strength)

$P_{nov} = 1.5 t_1 d_w F_{u1}$

$P_{ts}/\Omega = 453$ # <- Controls

$P_{ts}/\Omega = 1220$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.696	2	0.85	1009 #	2	6.00 in
Short side:	1.696	2	0.85	1009 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.73 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²

$A_{nv} = 0.438$ in²


$A_{nt} = 0.040$ in²

$R_n/\Omega = 7.445$ k

$R_n = 0.6 F_y A_{gv} + F_u A_{nt} \leq 0.6 F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: 0.6-0.14SDS/D + 0.7E

WIND: 0.6D + W

Transverse: Uplift_{MAX} = 1983 lbs Shear_{MAX} = 925 lbs

Compression_{SEISMIC} = 2603 lbs = $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 1983 lbs = $Comp_{SEISMIC} \cdot [0.6 - 0.14 S_{DS}] \cdot (WGT_{unit+curb})$

Compression_{WIND} = 1168 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} - F_{vertASD} \cdot w_{curb}/2] / w_{curb}$

Tension_{WIND} = 1123 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} + F_{vertASD} \cdot w_{curb}/2] / w_{curb}$

Longitudinal: Uplift_{MAX} = 1456 lbs Shear_{MAX} = 925 lbs

Compression_{SEISMIC} = 2075 lbs = $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 1456 lbs = $Comp_{SEISMIC} \cdot [0.6 - 0.14 S_{DS}] \cdot (WGT_{unit+curb})$

Compression_{WIND} = 502 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} - F_{vertASD} \cdot L_{curb}/2] / L_{curb}$

Tension_{WIND} = 456 lbs = $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} + F_{vertASD} \cdot L_{curb}/2] / L_{curb}$

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Transverse:

Tall_{wood} = 1195.95 lbs

Vall_{wood} = 1024 lbs

of Screws Req'd for Uplift = 2.09

COMBINED LOADING: 0.512 O.K.

of Screws Req'd for Shear = 0.90

Screw Spacing = 18.2 in o.c.

Total # of screws Required = 5

Use 5/8" ϕ wood lag screws @ 18.2 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

of Screws Req'd for Uplift = 1.5

COMBINED LOADING: 0.530 O.K.

of Screws Req'd for Shear = 0.9

Screw Spacing = 14.3 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 14.3 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall_{bolts} = 6903 lbs

Vall_{bolts} = 3682 lbs

Transverse:

Tall_{bolts} = 6903 lbs

Vall_{bolts} = 3682 lbs

of Bolts Req'd for Uplift = 0.29

COMBINED LOADING: 0.071 O.K.

of Bolts Req'd for Shear = 0.25

Bolt Spacing = 68.9 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 68.9 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.21

COMBINED LOADING: 0.055 O.K.

of Bolts Req'd for Shear = 0.25

Req'd Min Spacing = 39.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 39 in o.c. along short side of curb



For Concrete anchorage: SEISMIC $[0.6-0.14S_{DS}]D + 0.7\Omega_0 E$ ($\Omega_0 = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$\begin{aligned} T_{all,LRFD} &= 1722 \text{ lbs} & V_{all,LRFD} &= 2032 \text{ lbs} & \alpha &= (1 + 0.2S_{DS})D + 2.5E = 1.87 \\ T_{all,ASD} &= T_{all,LRFD}/\alpha = 920.9 \text{ lbs} & V_{all,ASD} &= V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} & (D = 0.465, E = 0.535) \\ \text{Transverse:} & & \text{Uplift}_{MAX} &= 4126 \text{ lbs} & \text{Shear}_{MAX} &= 2313 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 4746 \text{ lbs} & &= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb} \\ \text{Tension}_{SEISMIC} &= 4126 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 2313 \text{ lbs} & &= 2.5 * F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 4.48 \text{ spacing} = 14.22 \text{ in o.c.} & \text{T}_{applied} &= 589.4 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.13 \text{ spacing} = 28.4375 \text{ in o.c.} & \text{V}_{applied} &= 330.4 \text{ lbs} \\ \text{Try using } 7 \text{ bolts} & & \text{COMBINED LOADING} &= \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.94 \\ \text{spaced at } 11.48 \text{ in o.c.} & & & & & \end{aligned}$$

Use 7 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 11.5 in o.c. max. along long side of curb w/ 4" embed

$$\begin{aligned} \text{Longitudinal:} & & \text{Uplift}_{MAX} &= 2807 \text{ lbs} & \text{Shear}_{MAX} &= 2313 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 3426 \text{ lbs} & &= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb} \\ \text{Tension}_{SEISMIC} &= 2807 \text{ lbs} & &= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 2313 \text{ lbs} & &= 2.5 * F_{pmaxASD} / 2 \\ \text{Min Bolts Req'd Uplift} &= 3.05 \text{ spacing} = 9 \text{ in o.c.} & \text{T}_{applied} &= 401.0 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.13 \text{ spacing} = 13.5 \text{ in o.c.} & \text{V}_{applied} &= 330.4 \text{ lbs} \\ \text{Try using } 7 \text{ bolts} & & \text{COMBINED LOADING} &= \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.74 \\ \text{spaced at } 6.50 \text{ in o.c.} & & & & & \end{aligned}$$

Use 7 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 6.5 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-80			
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 2 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	5 @ 18.22 in o.c.	2 @ 68.88 in o.c.	7 @ 11.48 in o.c.
SHORT DIRECTION	4 @ 14.33 in o.c.	2 @ 39 in o.c.	7 @ 6.5 in o.c.




Client: ProVent PV1806
Description: CBKD-80 11PV1806 KDKITPRD3715**
Unit: ZT,ZR,ZJ,ZH 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150

Curb Information

Hcurb = 11 in (Height of curb)
Lcurb = 80.875 in (Length of curb)
wcurb = 51 in (Width of curb)
WGTCurb = 155 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 0

Unit Information

WGTunit = 1700 lbs (Weight of Unit)
Wtmax = 329 lbs (Maximum corner weight)
Wtmin = 191 lbs (Minimum corner weight)
Hunit = 50.75 in (Height of unit above curb)
Hcm = 25.375 in (Height to center of mass)
Lunit = 89 in (Length of unit)
Wunit = 59 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp*3/Rp
FpmaxASD = 1696 lbs (0.7*Fpmax)
FpmaxASD = 1850 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² [Eq. 29.3-1 ASCE 7-10]
FhASDtrans = 1415 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) [Eq. 29.5-2]
FhASDlong = 938 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
FvertASD = 1067 lbs = 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

Compression_{SEISMIC} = 1677 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 1109 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 565 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 612 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 1365 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 797 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 155 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 203 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1677 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1109 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1365 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 797 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0566 16 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 11.000 in a = 10.717 in = A' - (2r + t)
B' = 2.000 in a' = 10.943 in = A' - t
C' = 0.000 in (0 if no lips) b = 1.859 in = B' - [r + t/2 + a(r + l/2)]
a = 0.000 (0 - no Lip; 1 w/ lip) b' = 1.972 in = B' - [t/2 + a(t/2)]
R = 0.0849 (Inside bend radius) c = 0.000 in = a[C' - (r + t/2)]
t = 0.0566 in c' = 0.000 in = a[C' - t/2]
r' = 0.113 in = R + t/2 u = 0.178 in = $\pi r/2$
x = 0.263 in (Distance between centroid and web centerline)
Ix = 12.703 in (Moment of Inertia about X-Axis)
Iy = 0.231 in (Moment of Inertia about Y-Axis)
A = 0.84 in²
rx = 3.90 in
ry = 0.526 in
rmin = 0.526 in



Axial Compression

Pu = 0.848 k (Max Axial Comp) $\Omega_c = 1.80$
Pn/ Ω_c = 15.337 k
Fe = 50.29 ksi $\lambda_c = 1.00$
Fn = 32.98 ksi
Ly = 50 in
k_yL_y/r_y = 76
Lateral unbraced length (assume k=0.8)

Compression Check = **O.K.**

Check Web Crippling

h = 11 in -- Check limits: C = 4.00
t = 0.0566 in h/t = 194.35 ≤ 200 C_R = 0.14
N = 7.00 N/t = 123.67 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.636364 ≤ 2.0 C_h = 0.02
P_n = 1.674 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 0.957 k
Long side: Pu_{trans} = 0.838 k
Short side: Pu_{Long} = 0.683 k

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28vE/Fys Ω_c = 1.70
w/ts = 118.675
1.28vE/Fys = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_{st}F_y) ≥ P_{wc}
P_{wc} = 1.674 k Ae = 0.380 in²
P_n = 14.478 k P_n/Ω = 8.517 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{cn}max = 424 lbs Max(F_{pm}ASD/4 - OR - F_hASD/4 corner connections)
V_{cn}max = 554 lbs (Max Ten/2 corner connections per side)
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs
of Bolts required for Tension = 0.2
of Bolts required for Shear = 0.5
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.677 O.K.

***If combined fails:
USE --> 2.0

StressComb = 0.338 O.K.

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.415 in P_n/Ω = 1/Ω * 0.75tL_{fu} ≥ V_{req} L_{req'd} = V_{req}Ω / 0.75tF_u
L_{req'd} = 0.472 in



Connection Unit to Curb Clip

#14 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.242$ in (screw diameter)

$d_w = 0.500$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 2404$ # 4.36 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.40 k

$P_{ns} = 2.7t_2dF_{u2}$ 4.32 k

$P_{ns}/\Omega = 801$ # <- Controls

$P_{ss}/\Omega = 1045$ #

Tension: $P_{not} = 1.360$ k (screw pull-out strength)

For $t_2/t_1 > 2.5$:

$P_{ns} = 2404$ # 2.40 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.40 k

$P_{ns} = 2.7t_2dF_{u2}$ 4.32 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 1220$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.696	2	0.85	801 #	2	6.00 in
Short side:	1.696	2	0.85	801 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.73 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.368$ in²


$A_{nv} = 0.347$ in²

$A_{nt} = 0.032$ in²

$R_n/\Omega = 5.910$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$
(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:

$Uplift_{MAX} = 1874$ lbs

$Shear_{MAX} = 925$ lbs

Compression_{SEISMIC} = 2494 lbs = $[F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 1874 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * [WGT_{unit+curb}]$

Compression_{WIND} = 1032 lbs = $[F_{h trans ASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vert ASD} * w_{curb}/2] / w_{curb}$

Tension_{WIND} = 986 lbs = $[F_{h trans ASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vert ASD} * w_{curb}/2] / w_{curb}$

Longitudinal:

$Uplift_{MAX} = 1387$ lbs

$Shear_{MAX} = 925$ lbs

Compression_{SEISMIC} = 2006 lbs = $[F_{pmax} ASD * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 1387 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * [WGT_{unit+curb}]$

Compression_{WIND} = 445 lbs = $[F_{h trans ASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vert ASD} * L_{curb}/2] / L_{curb}$

Tension_{WIND} = 399 lbs = $[F_{h trans ASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vert ASD} * L_{curb}/2] / L_{curb}$

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

$Tall_{metal} = 946.67$ lbs

$V_{all metal} = 1043.33$ lbs

Transverse:

$Tall_{wood} = 1195.95$ lbs

$V_{all wood} = 1024$ lbs

of Screws Req'd for Uplift = 1.98

COMBINED LOADING: 0.618 O.K.

of Screws Req'd for Shear = 0.90

Screw Spacing = 24.3 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 24.3 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

of Screws Req'd for Uplift = 1.5

COMBINED LOADING: 0.516 O.K.

of Screws Req'd for Shear = 0.9

Screw Spacing = 14.3 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 14.3 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

$Tall_{bolt} = 6903$ lbs

$V_{all bolt} = 3682$ lbs

Transverse:

$Tall_{bolt} = 6903$ lbs

$V_{all bolt} = 3682$ lbs

of Bolts Req'd for Uplift = 0.27

COMBINED LOADING: 0.067 O.K.

of Bolts Req'd for Shear = 0.25

Bolt Spacing = 68.9 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 68.9 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.20

COMBINED LOADING: 0.053 O.K.

of Bolts Req'd for Shear = 0.25

Req'd Min Spacing = 39.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 39 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.

San Diego, CA 92120

(619)727-4800

Page ____ of ____

For Concrete anchorage: SEISMIC $[0.6-0.14SDS]D + 0.7\Omega_o E$ ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$T_{all,LRFD} = 1722 \text{ lbs} \quad V_{all,LRFD} = 2032 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.87$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 920.9 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} \quad (D = 0.465, E = 0.535)$$

$$\text{Transverse: } Uplift_{MAX} = 3854 \text{ lbs} \quad Shear_{MAX} = 2313 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 4474 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 3854 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14SDS] \cdot (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 2313 \text{ lbs} = 2.5 \cdot F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 4.19 \text{ spacing} = 14.22 \text{ in o.c.} \quad T_{applied} = 550.6 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.13 \text{ spacing} = 28.4375 \text{ in o.c.} \quad V_{applied} = 330.4 \text{ lbs}$$

Try using 7 bolts
spaced at 11.48 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.90$$

Use 7 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 11.5 in o.c. max. along long side of curb w/ 4" embed

$$\text{Longitudinal: } Uplift_{MAX} = 2635 \text{ lbs} \quad Shear_{MAX} = 2313 \text{ lbs}$$

$$\text{Compression}_{SEISMIC} = 3255 \text{ lbs} = [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 2635 \text{ lbs} = \text{Comp}_{SEISMIC} - [0.6 - 0.14SDS] \cdot (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 2313 \text{ lbs} = 2.5 \cdot F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 2.86 \text{ spacing} = 13.5 \text{ in o.c.} \quad T_{applied} = 439.2 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 2.13 \text{ spacing} = 13.5 \text{ in o.c.} \quad V_{applied} = 385.5 \text{ lbs}$$

Try using 6 bolts
spaced at 7.80 in o.c.

$$\text{COMBINED LOADING} = \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.83$$

Use 6 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 7.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-80			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 2 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 24.29 in o.c.	2 @ 68.88 in o.c.	7 @ 11.48 in o.c.
SHORT DIRECTION	4 @ 14.33 in o.c.	2 @ 39 in o.c.	6 @ 7.8 in o.c.




Client: ProVent PV1806
Description: CBKD-80 8" KDKITPRD3715**
Unit: ZT,ZR,ZJ,ZH 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150

Curb Information

Hcurb = 8 in (Height of curb)
Lcurb = 80.875 in (Length of curb)
wcurb = 51 in (Width of curb)
WGTCurb = 155 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 0

Unit Information

WGTunit = 1700 lbs (Weight of Unit)
Wtmax = 329 lbs (Maximum corner weight)
Wtmin = 191 lbs (Minimum corner weight)
Hunit = 50.75 in (Height of unit above curb)
Hcm = 25.375 in (Height to center of mass)
Lunit = 89 in (Length of unit)
Wunit = 59 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category U)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 [Fa*Ss]
Sds = 1.900 (2/3*Sms)
Ip = 1.50 (Importance Factor Category III Building)
Fpmax = 1.425 Wp (0.4*ap*Sds*Ip)*Wp*3/Rp
FpmaxASD = 1696 lbs (0.7*Fpmax) FpmaxASD = 1850 lbs (unit and curb)
(unit only)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr (horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr (vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V^2 [Eq. 29.3-1 ASCE 7-10]
Fh ASD trans = 1346 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) [Eq. 29.5-2]
Fh ASD long = 892 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 1067 lbs = 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

CompressionSEISMIC = 1677 lbs = [FpmaxASD*Hcm+2*(1+0.14Sds)*Wtmax*wcurb]/wcurb
TensionSEISMIC = 1109 lbs = CompSEISMIC-[0.6-0.14Sds]*WGTunit
CompressionWIND = 531 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
TensionWIND = 578 lbs = CompWIND+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

CompressionSEISMIC = 1365 lbs = [FpmaxASD*Hcm+2*(1+0.14Sds)*Wtmax*Lcurb]/Lcurb
TensionSEISMIC = 797 lbs = CompSEISMIC-[0.6-0.14Sds]*WGTunit
CompressionWIND = 141 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
TensionWIND = 188 lbs = CompWIND+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	CompMAX = 1677 lbs	----> Along long edge of curb.
(on long edge)	TensMAX = 1109 lbs	----> Along long edge of curb.
Longitudinal:	CompMAX = 1365 lbs	----> Along short edge of curb.
(on short edge)	TensMAX = 797 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 16 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 8.000 in	a = 7.717 in = A' - (2r + t)
B' = 2.000 in	a' = 7.943 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.859 in = B' - [r + t/2 + a(r + t/2)]
d = 0.000 in (0 - no Lip; 1 w/ lip)	b' = 1.972 in = B' - [t/2 + at/2]
R = 0.0849 (Inside bend radius)	c = 0.000 in = a[C' - (r + t/2)]
t = 0.0566 in	c' = 0.000 in = a[C' - t/2]
r' = 0.113 in = R + t/2	u = 0.178 in = πr/2
x = 0.330 in (Distance between centroid and web centerline)	
I _x = 5.799 in (Moment of Inertia about X-Axis)	
I _y = 0.217 in (Moment of Inertia about Y-Axis)	
A = 0.67 in ²	
r _x = 2.95 in	
r _y = 0.570 in	
r _{min} = 0.570 in	



Axial Compression

P_u = 0.848 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 13.006 k
F_e = 59.07 ksi
λ_c = 0.92
F_n = 35.08 ksi
L_y = 50 in
k_yL_y/r_y = 70

λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$

If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$

Lateral unbraced length (assume k=0.8)

Compression Check = **O.K.**

Check Web Crippling

h = 8 in -- Check limits: C = 4.00
t = 0.0566 in h/t = 141.34 ≤ 200 C_R = 0.14
N = 7.00 N/t = 123.67 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.875 ≤ 2.0 C_h = 0.02
P_n = 1.770 k
P_n/Ω_w = 1.011 k
Long side: P_{uTrans} = 0.838 k
Short side: P_{uLong} = 0.683 k

P_n = C_t² F_y sin(90) $\left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$

O.K. # clips = 2
O.K. # clips = 2

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)
width of stiffener = 7.000 in t_s = 0.0566 16 Gauge
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28V/E/F_y Ω_c = 1.70
w/t_s = 118.675
1.28V/E/F_y = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 1.770 k A_e = 0.380 in²
P_n = 14.545 k P_n/Ω = 8.556 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crnmax} = 424 lbs Max(F_{pnmaxASD/4} -OR- F_{hASDtrans/4} corner connections)
V_{crnmax} = 554 lbs (Max Ten/2 corner connections per side)
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs
of Bolts required for Tension = 0.2
of Bolts required for Shear = 0.5
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.677 **O.K.** StressComb = 0.338 **O.K.**
***If combined fails: USE --> 2.0

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.415 in P_n/Ω = $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ L_{req'd} = $\frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 0.472 in



Connection Unit to Curb Clip

#14 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.242$ in (screw diameter)

$d_w = 0.500$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 2404$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2404$ #

$P_{ns} = 2.7t_1dF_{u1}$ 2.40 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.40 k

$P_{ns} = 2.7t_2dF_{u2}$ 4.32 k

$P_{ns} = 2.7t_2dF_{u2}$ 4.32 k

$P_{ns}/\Omega = 801$ # <- Controls

$P_{ss}/\Omega = 1045$ #

Tension: $P_{not} = 1.360$ k (screw pull-out strength)

$P_{not} = 0.85t_2dF_{u2}$

$P_{nov} = 2.759$ k (screw pull-over strength)

$t_c = \min(t_1, t_2)$

$P_{ts}/\Omega = 453$ # <- Controls

$P_{nov} = 1.5t_1d_wF_{u1}$

$P_{ts}/\Omega = 1220$ #

(full tensile screw capacity)

Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side: 1.696	2	0.85	801 #	2	6.00 in
Short side: 1.696	2	0.85	801 #	2	6.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.73 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0566 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.368$ in²


$A_{nv} = 0.347$ in² $A_{nt} = 0.032$ in²

$R_n/\Omega = 5.910$ k

$R_n = 0.6F_yA_{gv} + F_uA_{nt} \leq 0.6F_uA_{nv} + F_uA_{nt}$

BSR O.K.

(AISI Sect. E5.3)



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $[0.6-0.14S_{DS}]D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX}	1766 lbs	Shear _{MAX}	925 lbs
Compression _{SEISMIC}	2385 lbs	$= [F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$		
Tension _{SEISMIC}	1766 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb})$		
Compression _{WIND}	904 lbs	$= [F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} - F_{vertASD} \cdot w_{curb}/2] / w_{curb}$		
Tension _{WIND}	858 lbs	$= [F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} + F_{vertASD} \cdot w_{curb}/2] / w_{curb}$		
Longitudinal:	Uplift _{MAX}	1318 lbs	Shear _{MAX}	925 lbs
Compression _{SEISMIC}	1938 lbs	$= [F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$		
Tension _{SEISMIC}	1318 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb})$		
Compression _{WIND}	391 lbs	$= [F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} - F_{vertASD} \cdot L_{curb}/2] / L_{curb}$		
Tension _{WIND}	345 lbs	$= [F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} + F_{vertASD} \cdot L_{curb}/2] / L_{curb}$		

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

$T_{allmetal} = 946.67$ lbs

$V_{allmetal} = 1043.33$ lbs

Transverse:

$T_{allwood} = 1195.95$ lbs

$V_{allwood} = 1024$ lbs

of Screws Req'd for Uplift = 1.87

COMBINED LOADING: 0.595 O.K.

of Screws Req'd for Shear = 0.90

Screw Spacing = 24.3 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 24.3 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

of Screws Req'd for Uplift = 1.4

COMBINED LOADING: 0.501 O.K.

of Screws Req'd for Shear = 0.9

Screw Spacing = 14.3 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 14.3 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

Transverse:

$T_{allbolt} = 6903$ lbs

$V_{allbolt} = 3682$ lbs

of Bolts Req'd for Uplift = 0.26

COMBINED LOADING: 0.064 O.K.

of Bolts Req'd for Shear = 0.25

Bolt Spacing = 68.9 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 68.9 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.19

COMBINED LOADING: 0.051 O.K.

of Bolts Req'd for Shear = 0.25

Req'd Min Spacing = 39.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 39 in o.c. along short side of curb



For Concrete anchorage: SEISMIC $(0.6-0.14SDS)D + 0.7\Omega_o E$ ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

$$\begin{aligned} T_{all,LRFD} &= 1722 \text{ lbs} & V_{all,LRFD} &= 2032 \text{ lbs} & \alpha &= (1 + 0.2SDS)D + 2.5E = 1.87 \\ T_{all,ASD} &= T_{all,LRFD}/\alpha = 920.9 \text{ lbs} & V_{all,ASD} &= V_{all,LRFD}/\alpha = 1086.6 \text{ lbs} & (D = 0.465, E = 0.535) \\ \text{Transverse:} & & \text{Uplift}_{MAX} &= 3582 \text{ lbs} & \text{Shear}_{MAX} &= 2313 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 4201 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb} \\ \text{Tension}_{SEISMIC} &= 3582 \text{ lbs} & &= Comp_{SEISMIC} \cdot [0.6 - 0.14SDS] \cdot (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 2313 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD}/2 \\ \text{Min Bolts Req'd Uplift} &= 3.89 \text{ spacing} = 18.96 \text{ in o.c.} & \text{Applied} &= 597.0 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.13 \text{ spacing} = 28.4375 \text{ in o.c.} & \text{Applied} &= 385.5 \text{ lbs} \\ \text{Try using } 6 \text{ bolts} & & \text{COMBINED LOADING} &= \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.00 \\ \text{spaced at } 13.78 \text{ in o.c.} & & & & & \end{aligned}$$

Use 6 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 13.8 in o.c. max. along long side of curb w/ 4" embed

$$\begin{aligned} \text{Longitudinal:} & & \text{Uplift}_{MAX} &= 2464 \text{ lbs} & \text{Shear}_{MAX} &= 2313 \text{ lbs} \\ \text{Compression}_{SEISMIC} &= 3083 \text{ lbs} & &= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14SDS) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb} \\ \text{Tension}_{SEISMIC} &= 2464 \text{ lbs} & &= Comp_{SEISMIC} \cdot [0.6 - 0.14SDS] \cdot (WGT_{unit+curb}) \\ \text{Shear}_{SEISMIC} &= 2313 \text{ lbs} & &= 2.5 \cdot F_{pmaxASD}/2 \\ \text{Min Bolts Req'd Uplift} &= 2.68 \text{ spacing} = 13.5 \text{ in o.c.} & \text{Applied} &= 410.6 \text{ lbs} \\ \text{Min Bolts Req'd Shear} &= 2.13 \text{ spacing} = 13.5 \text{ in o.c.} & \text{Applied} &= 385.5 \text{ lbs} \\ \text{Try using } 6 \text{ bolts} & & \text{COMBINED LOADING} &= \frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.80 \\ \text{spaced at } 7.80 \text{ in o.c.} & & & & & \end{aligned}$$

Use 6 - 3/4" ϕ Hilti Hit-HY 200 adhesive anchors @ 7.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-80			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
CORNER CONNECTION: Use 2 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 24.29 in o.c.	2 @ 68.88 in o.c.	6 @ 13.78 in o.c.
SHORT DIRECTION	4 @ 14.33 in o.c.	2 @ 39 in o.c.	6 @ 7.8 in o.c.