




**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120

619-727-4800

**Structural Calculations**  
**for**  
**CBKD Series Roof Curbs**  
CBKD-160A (80-265-49)  
2020 Florida Building Code requirements



Exp. 02 / 28 / 2023


**Prepared for:**

**PROVENT**  
3847 Wabash Drive  
Mira Loma, CA 91725

**Date: May 19, 2021**  
**Project Number: PV2101**

**STEEL ATTACHMENT**

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



**WIND LOAD ROOF ANCHORAGE DETAIL**

Meets wind requirements for the following codes:  
FBC 2020  
based on ASCE 7-16.

**Wind:**  
190 mph exposure D category III or IV  
building, max BLDG height: 60 ft  
Kzt=1.00 max

**CONCRETE ATTACHMENT**

WELDED CURB  
CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THRD'D ROD IN HILTI HIT-HY 200 EPOXY, 4" MIN. EMBED INTO CONCRETE.




- NORMAL WEIGHT CONC SLAB
- f<sub>c</sub>=4000 PSI MIN
- 6" MIN THICK CONC.
- SPECIAL INSPECTION REQUIRED ( ESR-3187)

CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE *	
80-265-49	2 @ 34.5" o.c.	2 @ 19" o.c.	LXS
80-265-50	2 @ 34.5" o.c.	2 @ 29" o.c.	LXL
80-265-13	2 @ 61" o.c.	2 @ 25.25" o.c.	SUNLINE 3-6 TON
80-265-45	2 @ 58.38" o.c.	2 @ 28.19" o.c.	PRESTIGE SMALL
80-265-46	2 @ 72" o.c.	2 @ 41" o.c.	PRESTIGE LARGE
80-265-29	3 @ 34.69" o.c.	2 @ 39.5" o.c.	PREDATOR
80-265-19	3 @ 51.63" o.c.	2 @ 72" o.c.	SUNLINE ULTRA
80-265-18	3 @ 57.13" o.c.	2 @ 72" o.c.	SUNLINE MAGNA

CURB KIT	NO. OF ANCHORAGE BOLTS REQUIRED		UNIT
	LONG SIDE *	SHORT SIDE **	
80-265-49	5 @ 8.63" o.c.	3 @ 9.5" o.c.	LXS
80-265-50	5 @ 8.63" o.c.	4 @ 9.67" o.c.	LXL
80-265-13	5 @ 15.25" o.c.	3 @ 12.63" o.c.	SUNLINE 3-6 TON
80-265-45	5 @ 14.59" o.c.	3 @ 14.09" o.c.	PRESTIGE SMALL
80-265-46	5 @ 18" o.c.	4 @ 13.67" o.c.	PRESTIGE LARGE
80-265-29	9 @ 8.67" o.c.	5 @ 9.88" o.c.	PREDATOR
80-265-19	8 @ 14.75" o.c.	6 @ 14.4" o.c.	SUNLINE ULTRA
80-265-18	12 @ 10.39" o.c.	8 @ 10.29" o.c.	SUNLINE MAGNA

**WOOD ATTACHMENT**




CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø WOOD LAG SCREWS (3.5" MIN. EMBED. INTO WOOD FRAMING)

**STEEL AND CONCRETE ANCHORS ARE 6" FROM EACH CORNER EVENLY SPACED**


CURB KIT	NO. OF ANCHORAGE SCREWS REQUIRED		UNIT
	LONG SIDE	SHORT SIDE	
80-265-49	6 @ 7.7" o.c.	3 @ 11.5" o.c.	LXS
80-265-50	5 @ 9.63" o.c.	5 @ 8.25" o.c.	LXL
80-265-13	6 @ 13" o.c.	3 @ 14.63" o.c.	SUNLINE 3-6 TON
80-265-45	6 @ 12.48" o.c.	3 @ 16.09" o.c.	PRESTIGE SMALL
80-265-46	6 @ 15.2" o.c.	4 @ 15" o.c.	PRESTIGE LARGE
80-265-29	10 @ 8.15" o.c.	6 @ 8.7" o.c.	PREDATOR
80-265-19	8 @ 15.32" o.c.	6 @ 15.2" o.c.	SUNLINE ULTRA
80-265-18	14 @ 9.1" o.c.	8 @ 10.86" o.c.	SUNLINE MAGNA

FOUR INCHES FROM EACH CORNER EVENLY SPACED.

**CONCRETE OVER METAL DECK**



NOTE: FOR CONC OVER METAL DECK OVER STEEL FRAMING USE STEEL ATTACHMENT



1625 DIPLOMAT DRIVE  
CARROLTON, TX 75006

PHONE (972) 247-7447  
FAX (972) 243-0940

SUBMITTED TO: \_\_\_\_\_  
COMPANY: \_\_\_\_\_  
JOB NAME: \_\_\_\_\_  
EQUIPMENT: \_\_\_\_\_  
NOTES: \_\_\_\_\_

FORM NO:

CB-25A

DATE:  
3/29/2021

REV:  
2

DRAWN BY:  
ALL

**CALCULATED WIND  
ROOF CURBS FOR YORK UNITS**

ProVent P/N	A	WEIGHT
80-265-4914	14"	129 Lbs
80-265-4918	18"	153 Lbs


**P\*\*\*A ALL MODELS**

**Meets wind requirements for the following codes:**  
FBC 2020  
based on ASCE 7-16.




**Wind:**  
190 mph exposure D category III or IV building, max BLDG height: 60 ft  
Kzt=1.00 max

**For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-25A.**


Will conform to wind load code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)




**INTERIOR CURB SUPPORT**




**HOLD DOWN DETAIL**



**STUD STIFFENER**



**CORNER & END CLIP DETAIL**



**1625 DIPLOMAT DRIVE  
CARROLTON, TX 75006**

**PHONE (972) 247-7447  
FAX (972) 243-0940**

**SUBMITTED TO:** \_\_\_\_\_  
**COMPANY:** \_\_\_\_\_  
**JOB NAME:** \_\_\_\_\_  
**EQUIPMENT:** \_\_\_\_\_  
**NOTES:** \_\_\_\_\_

**FORM NO:**  
CBKD-160A

**DATE:**  
3/29/2021

**REV:**  
2

**PART NUMBER:**  
80-265-49

**DRAWN BY:**  
ALL




Client:	ProVent PV2101	Previous:	PV1807
Description:	CBKD-160	80-265-49**	
Unit:	P***A ALL MODELS		

**Curb Information**

Hcurb =	18	in	(Height of curb)
Lcurb =	46.5	in	(Length of curb)
wcurb =	31	in	(Width of curb)
WGTCurb =	153	lbs	(Weight of curb)
# Clips long side =	1		
# Clips short side =	1		

**Unit Information**

WGUnit =	367	lbs	(Weight of Unit)
Wtmax =	120	lbs	(Maximum corner weight)
Wtmin =	71	lbs	(Minimum corner weight)
Hunit =	49	in	(Height of unit above curb)
Hcm =	24.5	in	(Height to center of mass)
Lunit =	51.25	in	(Length of unit)
Wunit =	35.75	in	(Width of unit)



**Seismic Loading - 2020 FBC/2018 IBC**

Ss =	0.15	(Worst Case for state of Florida)
Fa =	2.4	(Worst case Site class E from Table 11.4-1 ASCE 7-16)
Sms =	0.360	(Fa*Ss)
Sds =	0.240	(2/3*Sms)
Ip =	1.5	(Importance Factor Category III or IV Building)
Fpmax =	0.576	WGUnit (1.6*Sds*Ip)*WGUnit (Eq 13.3-2 ASCE 7-16)
FpmaxASD =	148	lbs (0.7*Fpmax)
	(unit only)	
FpmaxASD =	210	lbs (unit and curb)

**Wind Loading - 2020 FBC/2018 IBC**

Kz =	1.31	(For 60 ft roof height, Exposure D - Table 26.10-1 ACSE 7-16)
Kzt =	1.00	(Max. assumed topographic factor)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
Ke =	1.00	(Ground Elevation Factor Table 26.9-1 ASCE 7-16)
V =	190	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat C, Fig 26.5-1D - ASCE7-16)
GCr <sub>(horiz)</sub> =	1.9	(Refer Sect 29.4.1 ASCE 7-16)
GCr <sub>(vert)</sub> =	1.5	(Refer Sect 29.4.1 ASCE 7-16)
qz =	102.9	psf = 0.00256*Kz*Kzt*Kd*Ke*V <sup>2</sup> (Eq. 26.10-1 ASCE 7-10)
F <sub>h ASD trans</sub> =	2797	lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.4-2)
F <sub>h ASD long</sub> =	1951	lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F <sub>vert ASD</sub> =	1178	lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.4-3)

**Curb Loading**

<b>Transverse:</b>		
Compression <sub>SEISMIC</sub> =	365	lbs = [FpmaxASD*Hcm+2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	157	lbs = Comp <sub>SEISMIC</sub> - (0.6-0.14S <sub>DS</sub> )*WGUnit
Compression <sub>WIND</sub> =	1766	lbs = [F <sub>h trans ASD</sub> *Hcm+2*0.6*Wtmax*wcurb-F <sub>vert ASD</sub> *wcurb/2]/wcurb
Tension <sub>WIND</sub> =	2724	lbs = Comp <sub>WIND</sub> +F <sub>vert</sub> -0.6*WGUnit

----> Negative values indicate opposite load.

<b>Longitudinal:</b>		
Compression <sub>SEISMIC</sub> =	326	lbs = [FpmaxASD*Hcm+2*(1+0.14*S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	118	lbs = Comp <sub>SEISMIC</sub> - (0.6-0.14S <sub>DS</sub> )*WGUnit
Compression <sub>WIND</sub> =	583	lbs = [F <sub>h trans ASD</sub> *Hcm+2*0.6*Wtmax*Lcurb-F <sub>vert ASD</sub> *Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	1541	lbs = Comp <sub>WIND</sub> +F <sub>vert</sub> -0.6*WGUnit

----> Negative values indicate opposite load.

**Governing Reactions:**

<b>Transverse:</b>			
(on long edge)	Comp <sub>MAX</sub> =	1766	lbs ----> Along long edge of curb.
	Tens <sub>MAX</sub> =	2724	lbs ----> Along long edge of curb.
<b>Longitudinal:</b>			
(on short edge)	Comp <sub>MAX</sub> =	583	lbs ----> Along short edge of curb.
	Tens <sub>MAX</sub> =	1541	lbs ----> Along short edge of curb.

----> Negative values indicate opposite load.




**Curb Design**

Fy = 50 ksi      Fu = 65 ksi      t = 0.0713 14 Gauge  
E = 29500 ksi

**Calculate Section Properties of Curb**

A' = <span style="border: 1px solid black; padding: 2px;">18.000</span> in	a = 17.644 in = A' - (2r+t)
B' = <span style="border: 1px solid black; padding: 2px;">1.000</span> in	a' = 17.929 in = A' - t
C' = <span style="border: 1px solid black; padding: 2px;">0.000</span> in [0 if no lips]	b = 0.822 in = B' - [r+t/2+a(r+t/2)]
α = <span style="border: 1px solid black; padding: 2px;">0.000</span> [0 - no Lip; 1 w/ lip]	b' = 0.964 in = B' - [t/2+αt/2]
R = 0.1069 [Inside bend radius]	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.047 in [Distance between centroid and web centerline]	
Ix = 44.614 in <sup>4</sup> [Moment of Inertia about X-Axis]	
Iy = 0.039 in <sup>4</sup> [Moment of Inertia about Y-Axis]	
A = 1.41 in <sup>2</sup>	
rx = 5.63 in	
ry = 0.168 in	
rmin = 0.168 in	



**Axial Compression**

Pu = 1.399 k	(Max Axial Comp)	Ωc = 1.80
Pn/Ωc = 4.049 k		
Fe = 5.91 ksi		
λc = 2.91		
Fn = 5.18 ksi		
Ly = 47 in	Lateral unbraced length	
kyLy/ry = 222	(assume k=0.8)	

$$\lambda_c = \frac{F_y}{F_e} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

$$P_n = F_n A \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\Omega_c = \frac{F_n A}{F_e} \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

**Compression Check = O.K.**

**Check Web Crippling**

h = 18 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 252.45 ≤ 200	CR = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	CN = 0.35	
Ωw = 1.75	N/h = 0.388889 ≤ 2.0	Ch = 0.02	
Pn = 2.296 k	R/t = 1.50 ≤ 9.0		

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$$

Long side: Pu<sub>Trans</sub> = 1.766 k **web stiffener REQ'D** # clips = 1

Short side: Pu<sub>Long</sub> = 0.583 k **O.K.** # clips = 1

**\*\*\*h/t > 200; use web stiffeners**

**Check Web Stiffener**

16Ga x 3/4" x 7" [C-channel]

width of stiffener = 7.000 in	ts = 0.0566 <span style="border: 1px solid black; padding: 2px;">16 Gauge</span>
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/Fys	Ωc = 1.70
w/ts = 118.675	
1.28√E/Fys = 31.091 --> w/ts over limit Use C3.7.2	
Pn = 0.7(Pwc + AeFy) ≥ Pwc	
Pwc = 2.296 k	Ae = 0.380 in <sup>2</sup>
Pn = 14.913 k	Pn/Ω = 8.773 k

**O.K.**

**Corner Connections**

**1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts**

Tcrnmax = 699 lbs	Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1362 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = <span style="border: 1px solid black; padding: 2px;">2480</span> lbs	Vall = <span style="border: 1px solid black; padding: 2px;">1096</span> lbs
Threaded Insert: Tall = <span style="border: 1px solid black; padding: 2px;">2860</span> lbs	Vall = <span style="border: 1px solid black; padding: 2px;">1714</span> lbs
# of Bolts required for Tension = 0.3	
# of Bolts required for Shear = 1.2	
# of Bolts Used = <span style="border: 1px solid black; padding: 2px;">2.0</span>	***If combined fails: USE --> 3.0
Check Combined Stress in Bolts & Inserts: 0.762 <b>O.K.</b>	StressComb = 0.508 <b>O.K.</b>

**Check 1/8" welded connection**

<--- USE WELD      Ω = 2.35

Assume L/t > 25*t = 1.783 in	$\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$	$L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$
Lreq'd = 0.921 in		



### Connection Unit to Curb Clip

#12 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$  in

$F_{u1} = 65$  ksi

$t_2 = 0.1017$  in (unit base rail thickness)

$F_{u2} = 65$  ksi

$d = 0.216$  in (screw diameter)

$d_w = 0.375$  in (nom. washer diameter)

$t_2/t_1 = 1.4$

For  $t_2/t_1 \leq 1.0$ :

**Shear:**  $P_{ns} = 4.2F_{u2} \sqrt{t_2^3 d}$  4.12 k

$P_{ns} = 2.7t_1 d F_{u1}$  2.70 k

$P_{ns} = 2.7t_2 d F_{u2}$  3.86 k

$P_{ns}/\Omega = 901$  #

$P_{ss}/\Omega = 840$  # <- Controls

**Tension:**  $P_{not} = 1.214$  k (screw pull-out strength)

$P_{nov} = 2.607$  k (screw pull-over strength)

$P_{ts}/\Omega = 405$  # <- Controls

$P_{ts}/\Omega = 845$  #

$P_{ns} = 2703$  #

For  $t_2/t_1 \geq 2.5$ :


$P_{ns} = 2.7t_1 d F_{u1}$  2.70 k

$P_{ns} = 2.7t_2 d F_{u2}$  3.86 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$



	Shear (k)	# clips	$V_{clip}$ (k)	$V_{allow}$ (lb)	# screws	spacing
--	-----------	---------	----------------	------------------	----------	---------

Long side: 0.976 1 0.98 840 # 2 6.00 in

Short side: 1.399 1 1.40 840 # 2 6.00 in

clip width (in) = 7.00

clip height = 2.5 in

min spacing = 0.65 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$  ksi

$\Omega = 2.22$  bolt/screw connection

$A_{gv} = 0.463$  in<sup>2</sup>

$A_{nv} = 0.440$  in<sup>2</sup>

$A_{nt} = 0.081$  in<sup>2</sup>

$R_n/\Omega = 8.647$  k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$   
(AISI Sect. E5.3)

**BSR O.K.**

### Connection of Curb to Supporting Structure

**Roof Loading**

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift <sub>MAX</sub> = 4268 lbs	Shear <sub>MAX</sub> = 1399 lbs
-------------	----------------------------------	---------------------------------

Compression<sub>SEISMIC</sub> = 556 lbs =  $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$

Tension<sub>SEISMIC</sub> = 262 lbs =  $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Compression<sub>WIND</sub> = 3402 lbs =  $[F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$

Tension<sub>WIND</sub> = 4268 lbs =  $[F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$

Longitudinal:	Uplift <sub>MAX</sub> = 2217 lbs	Shear <sub>MAX</sub> = 976 lbs
---------------	----------------------------------	--------------------------------

Compression<sub>SEISMIC</sub> = 460 lbs =  $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$

Tension<sub>SEISMIC</sub> = 166 lbs =  $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Compression<sub>WIND</sub> = 1350 lbs =  $[F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$

Tension<sub>WIND</sub> = 2217 lbs =  $[F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$

**Wood Attachment:**

Use 5/8"  $\phi$  wood lag screws

w/ 3.5" Min. Embed

$T_{all,metal} = 946.67$  lbs

$V_{all,metal} = 1043.33$  lbs

Transverse:  $T_{all,wood} = 1195.95$  lbs

$V_{all,wood} = 1024$  lbs

# of Screws Req'd for Uplift = 4.51

COMBINED LOADING: 0.903 O.K.

# of Screws Req'd for Shear = 1.37

Screw Spacing = 7.7 in o.c.

Total # of screws Required = 6

Use 5/8"  $\phi$  wood lag screws @ 7.7 in o.c. along long side of curb

Longitudinal:

# of Screws Req'd for Uplift = 2.3

COMBINED LOADING: 0.886 O.K.

# of Screws Req'd for Shear = 1.0

Screw Spacing = 11.5 in o.c.

Total # of screws Required = 3

Use 5/8"  $\phi$  wood lag screws @ 11.5 in o.c. along short side of curb

**Steel Deck Attachment:**

Use 5/8"  $\phi$  A307 Bolts attached to steel angle below deck

$T_{all,bolt} = 6903$  lbs

$V_{all,bolt} = 3682$  lbs

Transverse:  $T_{all,bolt} = 6903$  lbs

$V_{all,bolt} = 3682$  lbs

# of Bolts Req'd for Uplift = 0.62

COMBINED LOADING: 0.204 O.K.

# of Bolts Req'd for Shear = 0.38

Bolt Spacing = 34.5 in o.c.

Total # of Bolts Required = 2

Use 5/8"  $\phi$  A307 Bolts attached to steel angle below deck @ 34.5 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 0.32

COMBINED LOADING: 0.082 O.K.

# of Bolts Req'd for Shear = 0.27

Req'd Min Spacing = 19.0 in o.c.

Total # of Bolts Required = 2

Use 5/8"  $\phi$  A307 Bolts attached to steel angle below deck @ 19 in o.c. along short side of curb



**For Concrete anchorage:** SEISMIC (0.6-0.14SDS)D + 0.7Ω<sub>o</sub>E (Ω<sub>o</sub> = 2.5)

**Concrete Attachment:** 3/4" φ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

Tall<sub>LRFD</sub> = 1722 lbs Vall<sub>LRFD</sub> = 2032 lbs α = (1 + 0.2SDS)D + 2.5E = 1.87

Tall<sub>ASD</sub> = Tall<sub>LRFD</sub>/α = 920.9 lbs Vall<sub>ASD</sub> = Vall<sub>LRFD</sub>/α = 1086.6 lbs (D = 0.465, E = 0.535)

**Transverse:** Uplift<sub>MAX</sub> = 4268 lbs Shear<sub>MAX</sub> = 1399 lbs

Compression<sub>SEISMIC</sub> = 987 lbs = [2.5 \* FpmaxASD \* (Hcm + Hcurb) + (1 + 0.14SDS) \* (WGT<sub>unit+curb</sub>/2) \* wcurb] / wcurb

Tension<sub>SEISMIC</sub> = 693 lbs = Comp<sub>SEISMIC</sub> - (0.6 - 0.14SDS) \* (WGTunit + curb)

Shear<sub>SEISMIC</sub> = 262 lbs = 2.5 \* FpmaxASD / 2

Min Bolts Req'd Uplift = 4.64 spacing = 5.63 in o.c. TApplied = 853.7 lbs

Min Bolts Req'd Shear = 2.00 spacing = 22.5 in o.c. VApplied = 174.8 lbs

Try using 5 bolts spaced at 8.63 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.09$
--	--

Use 5 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 8.6 in o.c. max. along long side of curb w/ 4" embed

**Longitudinal:** Uplift<sub>MAX</sub> = 2217 lbs Shear<sub>MAX</sub> = 1399 lbs

Compression<sub>SEISMIC</sub> = 748 lbs = [2.5 \* FpmaxASD \* (Hcm + Hcurb) + (1 + 0.14SDS) \* (WGT<sub>unit+curb</sub>/2) \* Lcurb] / Lcurb

Tension<sub>SEISMIC</sub> = 453 lbs = Comp<sub>SEISMIC</sub> - (0.6 - 0.14SDS) \* (WGTunit + curb)

Shear<sub>SEISMIC</sub> = 262 lbs = 2.5 \* FpmaxASD / 2

Min Bolts Req'd Uplift = 2.41 spacing = 3.5 in o.c. TApplied = 738.9 lbs

Min Bolts Req'd Shear = 2.00 spacing = 7 in o.c. VApplied = 174.8 lbs

Try using 3 bolts spaced at 9.50 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.96$
--	--

Use 3 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 9.5 in o.c. max. along short side of curb w/ 4" embed

<b>CURB DESIGN SUMMARY:</b> CBKD-160 80-265-49**		<b>Unit:</b> P***A ALL MODELS	
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 2 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 2 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
<b>CURB ANCHORAGE</b>	<b>WOOD</b>	<b>STEEL</b>	<b>CONCRETE</b>
	5/8" φ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" φ A307 bolts to steel angle below	3/4" φ thr'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
<b>LONG DIRECTION</b>	6 @ 7.7 in o.c.	2 @ 34.5 in o.c.	5 @ 8.63 in o.c.
<b>SHORT DIRECTION</b>	3 @ 11.5 in o.c.	2 @ 19 in o.c.	3 @ 9.5 in o.c.