



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120


619-727-4800

Structural Calculations
for

CBKD-160 Roof Curb

Kit #80-266-49**

2017 Florida Building Code requirements



Prepared for:

PROVENT


3847 Wabash Drive
Mira Loma, CA 91725

Date: June 15, 2018

Project Number: PV1807

STEEL ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø A307 BOLTS ATTACHED TO STEEL ANGLE BELOW DECK AT EACH CONNECTION POINT.



CURB KIT	LONG SIDE *	SHORT SIDE *	UNIT
80-266-49	2 @ 34.5" o.c.	2 @ 19" o.c.	LXS
80-266-50	2 @ 34.5" o.c.	2 @ 29" o.c.	LXL
80-266-13	2 @ 61" o.c.	2 @ 25.3" o.c.	SUNLINE 3-6 TON
80-266-45	2 @ 58.4" o.c.	2 @ 28.2" o.c.	PRESTIGE SMALL
80-266-46	2 @ 72" o.c.	2 @ 41" o.c.	PRESTIGE LARGE
80-266-29	3 @ 34.7" o.c.	2 @ 39.5" o.c.	PREDATOR
80-266-19	3 @ 51.6" o.c.	2 @ 72" o.c.	ULTRA
80-266-18	4 @ 38.1" o.c.	3 @ 38" o.c.	SUNLINE 15-25 TON

WIND AND SEISMIC LOAD ROOF ANCHORAGE DETAIL

Meets wind, seismic requirements for the following codes:
 FBC 2017
 based on ASCE 7-10.

Wind:
 190 mph exposure D category III or IV building, max BLDG height: 60 ft
 Kzt=1.00 max

Seismic:
 Sds=0.30 max
 Sd1=0.187 max
 Site Class D
 Importance Factor: Ip=1.5

CONCRETE ATTACHMENT

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THRD'D ROD IN HILTI HIT-HY 200 EPOXY, 4" MIN. EMBED INTO CONCRETE.




- NORMAL WEIGHT CONC SLAB
- f'c=4000 PSI MIN
- 6" MIN THICK CONC.
- SPECIAL INSPECTION REQUIRED (ESR-3187)

CURB KIT	LONG SIDE *	SHORT SIDE **	UNIT
80-266-49	5 @ 8.6" o.c.	4 @ 6.3" o.c.	LXS
80-266-50	5 @ 8.6" o.c.	5 @ 7.25" o.c.	LXL
80-266-13	9 @ 7.63" o.c.	6 @ 5.1" o.c.	SUNLINE 3-6 TON
80-266-45	6 @ 11.7" o.c.	4 @ 9.4" o.c.	PRESTIGE SMALL
80-266-46	6 @ 14.4" o.c.	5 @ 10.25" o.c.	PRESTIGE LARGE
80-266-29	16 @ 4.63" o.c.	10 @ 4.4" o.c.	PREDATOR
80-266-19	15 @ 7.4" o.c.	12 @ 6.5" o.c.	ULTRA
80-266-18	22 @ 5.4" o.c.	17 @ 4.5" o.c.	SUNLINE 15-25 TON

WOOD ATTACHMENT


CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 5/8" Ø WOOD LAG SCREWS (3.5" MIN. EMBED. INTO WOOD FRAMING)



CURB KIT	LONG SIDE	SHORT SIDE	UNIT
80-266-49	5 @ 9.6" o.c.	3 @ 11.5" o.c.	LXS
80-266-50	5 @ 9.6" o.c.	5 @ 8.3" o.c.	LXL
80-266-13	8 @ 9.3" o.c.	4 @ 9.8" o.c.	SUNLINE 3-6 TON
80-266-45	6 @ 12.5" o.c.	3 @ 16.1" o.c.	PRESTIGE SMALL
80-266-46	6 @ 15.2" o.c.	4 @ 15" o.c.	PRESTIGE LARGE
80-266-29	14 @ 5.6" o.c.	7 @ 7.3" o.c.	PREDATOR
80-266-19	15 @ 7.7" o.c.	12 @ 6.9" o.c.	ULTRA
80-266-18	23 @ 5.4" o.c.	14 @ 5.8" o.c.	SUNLINE 15-25 TON

STEEL AND CONCRETE ANCHORS ARE 6" FROM EACH CORNER EVENLY SPACED

CONCRETE OVER METAL DECK



NOTE: FOR CONC OVER METAL DECK OVER STEEL FRAMING USE STEEL ATTACHMENT

FOUR INCHES FROM EACH CORNER EVENLY SPACED.

FORM NO: CB-25



3847 WABASH DR.
 MIRA LOMA, CA 91725
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

DATE: 06/06/18

REV: 7

DRAWN BY: ALL

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-26.

Will conform to wind load code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)

CALCULATED WIND AND SEISMIC ROOF CURBS FOR YORK UNITS








P*A ALL MODELS**

ProVent PN	A	WEIGHT	CALCULATED KIT PIN WEIGHT
80-268-4914	14"	101 Lbs	80-268-4914 28 Lbs
80-268-4918	18"	120 Lbs	80-268-4918 33 Lbs

Meets wind, seismic requirements for the following codes:
 FBC 2017
 based on ASCE 7-10.

Wind:
 190 mph exposure D category III or IV building, max BLDG height: 60 ft
 $Kz=1.00$ max

Seismic:
 $Sds=0.30$ max
 $Sd1=0.187$ max
 Site Class D
 Importance Factor: $I_p=1.5$



3847 WABASH DR.
 MIRA LOMA, CA 91725
 PHONE (951) 685-1101
 FAX (619) 872-9799

SUBMITTED TO: _____
 COMPANY: _____
 JOB NAME: _____
 EQUIPMENT: _____
 NOTES: _____

FORM NO: CBKD-160
 DATE: 6/12/18
 REV: 3

PART NUMBER: 80-268-49
 DRAWN BY: JG




Client:	ProVent	PV1807
Description:	CBKD-160	(80-266-49**)
Unit:	York - All P***A models	

Curb Information

Hcurb =	18	in	(Height of curb)
Lcurb =	46.5	in	(Length of curb)
wcurb =	31	in	(Width of curb)
WGTcurb =	153	lbs	(Weight of curb)

Unit Information

WGUnit =	367	lbs	(Weight of Unit)
Wtmax =	120	lbs	(Maximum corner weight)
Wtmin =	71	lbs	(Minimum corner weight)
Hunit =	49	in	(Height of unit above curb)
Hcm =	24.5	in	(Height to center of mass)
Lunit =	51.25	in	(Length of unit)
Wunit =	35.75	in	(Width of unit)



Seismic Loading - 2017 FBC/2015 IBC

Ss =	0.15	(Worst Case for state of Florida)
Fa =	2.5	(Worst case Site class E from Table 11.4-1 ASCE 7-10)
Sms =	0.375	(Fa*Ss)
Sds =	0.250	(2/3*Sms)
Ip =	1.5	(Importance Factor Category III or IV Building)
Fpmax =	0.6000	Wp
FpmaxASD =	154	lbs
	(unit only)	
FpmaxASD =	218	lbs
	(unit and curb)	

Wind Loading - 2017 FBC/2015 IBC

*** Exposure Category D ***

Kz =	1.31	(For 60 ft roof height, Exposure D - Table 29.3-1 ACSE 7-10)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-10)
V =	190	(Wind velocity, mph for Occupancy Cat III-IV bldgs Exp. Cat D)
GCr _(horiz) =	1.9	(Refer Sect 29.5.1 ASCE 7-10)
GCr _(vert) =	1.5	(Refer Sect 29.5.1 ASCE 7-10)
qz =	102.9	psf = 0.00256*Kz*Kzt*Kd*V ² (Eq. 29.3-1 ASCE 7-10)
F _{h ASD trans} =	2797	lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
F _{h ASD long} =	1951	lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	1178	lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:		
Compression _{SEISMIC} =	370	lbs = [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	163	lbs = Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGUnit
Compression _{WIND} =	1766	lbs = [F _{h trans ASD} *Hcm+2*0.6*Wtmax*wcurb-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	2724	lbs = Comp _{WIND} +F _{vert} -0.6*WGUnit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:		
Compression _{SEISMIC} =	330	lbs = [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	122	lbs = Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGUnit
Compression _{WIND} =	583	lbs = [F _{h trans ASD} *Hcm+2*0.6*Wtmax*Lcurb-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	1541	lbs = Comp _{WIND} +F _{vert} -0.6*WGUnit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:				
(on long edge)	Comp _{MAX} =	1766	lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} =	2724	lbs	----> Along long edge of curb.
Longitudinal:				
(on short edge)	Comp _{MAX} =	583	lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} =	1541	lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 18.000 in	a = 17.644 in = A' - (2r+t)
B' = 2.000 in	a' = 17.929 in = A' - t
C' = 0.000 in [0 if no lips]	b = 1.822 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 [0 - no Lip; 1 w/ lip]	b' = 1.964 in = B' - [t/2+at/2]
R = 0.1069 [Inside bend radius]	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.178 in [Distance between centroid and web centerline]	
Ix = 56.073 in ⁴ [Moment of Inertia about X-Axis]	
Iy = 0.311 in ⁴ [Moment of Inertia about Y-Axis]	
A = 1.55 in ²	
rx = 6.02 in	
ry = 0.448 in	
rmin = 0.448 in	



Axial Compression

Pu = 1.399 k	(Max Axial Comp)	Ωc = 1.80
Pn/Ωc = 24.287 k		
Fe = 36.56 ksi		
λc = 1.17		
Fn = 28.21 ksi		
Ly = 50 in	Lateral unbraced length	
kyLy/ry = 89	(assume k=0.8)	

$$\lambda_c = \frac{F_y}{F_e} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

$$F_n = \begin{cases} 0.658 \lambda_c^2 F_y & \text{If } \lambda_c \leq 1.5 \\ \frac{0.877}{\lambda_c^2} F_y & \text{If } \lambda_c > 1.5 \end{cases}$$

Compression Check = O.K.

Check Web Crippling

h = 18 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 252.45 ≤ 200	CR = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	CN = 0.35	
Ωw = 1.75	N/h = 0.388889 ≤ 2.0	Ch = 0.02	
Pn = 2.296 k	R/t = 1.50 ≤ 9.0		

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$$

Long side: Pu_{Trans} = 1.766 k **web stiffener REQ'D** # clips = 1

Short side: Pu_{Long} = 0.583 k **O.K.** # clips = 1

*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/Fys	Ωc = 1.70
w/ts = 118.675	
1.28√E/Fys = 31.091	--> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc	
Pwc = 2.296 k	Ae = 0.380 in ²
Pn = 14.913 k	Pn/Ω = 8.773 k

O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

Tcrnmax = 699 lbs	Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1362 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.3	
# of Bolts required for Shear = 1.2	
# of Bolts Used = 2.0	
Check Combined Stress in Bolts & Inserts: 0.762 O.K.	StressComb = 0.508 O.K.

***If combined fails: USE --> 3.0

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25*t = 1.783 in Pn/Ω = 1/Ω * 0.75tLu ≥ Vreq Lreq'd = VreqΩ / 0.75tFu

Lreq'd = 0.921 in



Connection Unit to Curb Clip

#12 SMS screw

$\Omega = 3.0$

$t_1 = 0.0713$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.216$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 4.12 k

$P_{ns} = 2.7t_1dF_{u1}$ 2.70 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.86 k

$P_{ns}/\Omega = 901$ #

$P_{ss}/\Omega = 840$ # <- Controls

Tension: $P_{not} = 1.214$ k (screw pull-out strength)

$P_{nov} = 2.607$ k (screw pull-over strength)

$P_{ts}/\Omega = 405$ # <- Controls

$P_{ts}/\Omega = 845$ #

$P_{ns} = 2703$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2703$ #

$P_{ns} = 2.7t_1dF_{u1}$ 2.70 k

$P_{ns} = 2.7t_2dF_{u2}$ 3.86 k

$P_{not} = 0.85t_c d F_{u2}$

$t_c = \min(t_1, t_2)$

$P_{nov} = 1.5t_1 d_w F_{u1}$

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	2.797	1	2.80	840 #	4	2.00 in
Short side:	1.951	1	1.95	840 #	3	3.00 in

clip width (in) = 7.00

clip height = 2.5 in

min spacing = 0.65 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0713 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.463$ in²


$A_{nv} = 0.410$ in²

$A_{nt} = 0.081$ in²

$R_n/\Omega = 8.647$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$
(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX}	4268 lbs	Shear _{MAX}	1399 lbs
Compression _{SEISMIC}	569 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*w _{curb}]/w _{curb}		
Tension _{SEISMIC}	275 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})		
Compression _{WIND}	3402 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*w _{curb} -F _{vertASD} *w _{curb}]/w _{curb}		
Tension _{WIND}	4268 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*w _{curb} +F _{vertASD} *w _{curb}]/w _{curb}		
Longitudinal:	Uplift _{MAX}	2217 lbs	Shear _{MAX}	976 lbs
Compression _{SEISMIC}	469 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*L _{curb}]/L _{curb}		
Tension _{SEISMIC}	175 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})		
Compression _{WIND}	1350 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*L _{curb} -F _{vertASD} *L _{curb}]/L _{curb}		
Tension _{WIND}	2217 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*L _{curb} +F _{vertASD} *L _{curb}]/L _{curb}		

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Tall _{metal}	946.67 lbs	Vall _{metal}	1043.33 lbs	
Transverse:	Tall _{wood}	1195.95 lbs	Vall _{wood}	1024 lbs
# of Screws Req'd for Uplift	4.51			
# of Screws Req'd for Shear	1.37			
Total # of screws Required	5			
		COMBINED LOADING:	0.987 O.K.	
		Screw Spacing	9.6 in o.c.	

Use 5/8" ϕ wood lag screws @ 9.6 in o.c. along long side of curb

Longitudinal:

# of Screws Req'd for Uplift	2.3		
# of Screws Req'd for Shear	1.0		
Total # of screws Required	3		
		COMBINED LOADING:	0.935 O.K.
		Screw Spacing	11.5 in o.c.

Use 5/8" ϕ wood lag screws @ 11.5 in o.c. along short side of curb

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall _{bolt}	6903 lbs	Vall _{bolt}	3682 lbs
Transverse:	6903 lbs	3682 lbs	
# of Bolts Req'd for Uplift	0.62		
# of Bolts Req'd for Shear	0.38		
Total # of Bolts Required	2		
		COMBINED LOADING:	0.204 O.K.
		Bolt Spacing	34.5 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 34.5 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift	0.32		
# of Bolts Req'd for Shear	0.27		
Total # of Bolts Required	2		
		COMBINED LOADING:	0.082 O.K.
		Req'd Min Spacing	19.0 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 19 in o.c. along short side of curb



For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_oE (Ω_o = 2.5)

Concrete Attachment: 3/4" φ Hilti Hit-HY 200 adhesive anchors w/ 4" embed

Tall_{LRFD} = 1722 lbs Vall_{LRFD} = 2032 lbs α = (1 + 0.2SDS)D + 2.5E = 1.87

Tall_{ASD} = Tall_{LRFD}/α = 920.9 lbs Vall_{ASD} = Vall_{LRFD}/α = 1086.6 lbs (D = 0.465, E = 0.535)

Transverse: Uplift_{MAX} = 4268 lbs Shear_{MAX} = 1399 lbs

Compression_{SEISMIC} = 1018 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*wcurb]/wcurb

Tension_{SEISMIC} = 724 lbs = Comp_{SEISMIC} - [0.6 - 0.14SDS]*(WGTunit+curb)

Shear_{SEISMIC} = 273 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 4.64 spacing = 5.63 in o.c. T_{applied} = 853.7 lbs

Min Bolts Req'd Shear = 2.00 spacing = 22.5 in o.c. V_{applied} = 279.7 lbs

Try using 5 bolts spaced at 8.63 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.18$
--	--

Use 5 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 8.6 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 2217 lbs Shear_{MAX} = 1399 lbs

Compression_{SEISMIC} = 768 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*Lcurb]/Lcurb

Tension_{SEISMIC} = 474 lbs = Comp_{SEISMIC} - [0.6 - 0.14SDS]*(WGTunit+curb)

Shear_{SEISMIC} = 273 lbs = 2.5*FpmaxASD/2

Min Bolts Req'd Uplift = 2.41 spacing = 3.5 in o.c. T_{applied} = 554.2 lbs

Min Bolts Req'd Shear = 2.00 spacing = 7 in o.c. V_{applied} = 349.7 lbs

Try using 4 bolts spaced at 6.33 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.92$
--	--

Use 4 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 6.3 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBKD-160			
CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 3 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 3 - 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" φ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" φ A307 bolts	3/4" φ thr'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	5 @ 9.63 in o.c.	2 @ 34.5 in o.c.	5 @ 8.63 in o.c.
SHORT DIRECTION	3 @ 11.5 in o.c.	2 @ 19 in o.c.	4 @ 6.33 in o.c.