

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-25A.

CALCULATED WIND ROOF CURBS FOR YORK UNITS SERIES 20/ LARGE SUNLINE- SHORT RAIL





ProVent P/N	A	WEIGHT
80-265-1914	14"	328 Lbs
80-265-1918	18"	426 Lbs

Will conform to wind load code requirements for knock-down or pre-assembled application. (Contact factory for assembled version.)


ZF 180

Meets wind requirements for the following codes:
FBC 2017
based on ASCE 7-10.


Wind:
185 mph exposure D category III or IV building, max BLDG height: 60 ft
Kzt=1.66max




HOLD DOWN DETAIL



STUD STIFFENER



CORNER & END CLIP DETAIL



RRS ROOFTOP SYSTEMS

1625 DIPLOMAT DRIVE
CARROLTON, TX 75006

PHONE (972) 247-7447
FAX (972) 243-0940

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBKD-92A

DATE:
01/07/19

REV:
-

PART NUMBER:
80-265-19

DRAWN BY:
FMM