



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBWC-115 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: July 29, 2019
Project Number: PV1806

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-60.

FEATURES

- Roof curb sides and ends are 16 ga. galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Pitched curbs and taller curbs are available.

NOTES




- Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR YORK UNITS


ZJ/ZR 180-300: ZF 210-300: XP 180-240

ProVent P/N	A	WEIGHT
CBWCSLM183008	8"	159 Lbs
CBWCSLM183011	11"	185 Lbs
CBWCSLM183014	14"	211 Lbs
CBWCSLM183024	24"	370 Lbs


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015




CURB DETAIL



HOLD DOWN DETAIL



DETAIL B



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBWC-115


DATE:
09/27/18

REV:
5

PART NUMBER:
CBWCSLM1830 SERIES

DRAWN BY:
ALL

STEEL ATTACHMENT



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT

CONCRETE ATTACHMENT


WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THREADED ROD IN HILTI HIT-HY 200 EPOXY WITH 4" EMBED



NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL




Client: ProVent PV1806
Description: CBWC-115 (CBWCSLM1830**)
Unit: ZJ,ZR 180-300; ZF 210-300; XP 180-240

Curb Information

Hcurb = 24 in (Height of curb)
Lcurb = 125.25 in (Length of curb)
wcurb = 83 in (Width of curb)
WGTcurb = 370 lbs (Weight of curb)
Clips long side = 3 # Clips short side = 3

Unit Information

WGTunit = 3061.3 lbs (Weight of Unit)
Wtmax = 908 lbs (Maximum corner weight)
Wtmin = 306 lbs (Minimum corner weight)
Hunit = 52.625 in (Height of unit above curb)
Hcm = 26.3125 in (Height to center of mass)
Lunit = 136.25 in (Length of unit)
Wunit = 92 in (Width of unit)



Seismic Loading - 2015 IBC/2014 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category U)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 8143 lbs (0.7*Fpmax)
FpmaxASD = 9127 lbs (unit and curb)

Wind Loading - 2015 IBC/2014 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 2688 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 1815 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 2548 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 4881 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 3858 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 668 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 1379 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 4010 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 2987 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 197 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 908 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 4881 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 3858 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 4010 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2987 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 **16 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 24.000 in a = 23.717 in = A' - (2r + t)
B' = 3.000 in a' = 23.943 in = A' - t
C' = 1.000 in [0 if no lips] b = 2.717 in = B' - (r + t/2 - a(r + t/2))
a = 1.000 in [0 - no Lip; 1 w/ lip] b' = 2.943 in = B' - (t/2 + at/2)
R = 0.0849 in (Inside bend radius) c = 0.859 in = a[C' - (r + t/2)]
t = 0.0566 in c' = 0.972 in = a[C' - t/2]
r = 0.113 in = R + t/2 u = 0.178 in = πr/2
x = 0.446 in (Distance between centroid and web centerline)
I_x = 125.486 in (Moment of Inertia about X-Axis)
I_y = 1.511 in (Moment of Inertia about Y-Axis)
A = 1.79 in²
r_x = 8.38 in
r_y = 0.919 in
r_{min} = 0.919 in



Axial Compression

P_u = 4.072 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 33.817 k
F_e = 54.49 ksi $\lambda_c = \frac{F_y}{F_e}$ $F_c = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 0.96 If λ_c ≤ 1.5; F_n = (0.658<sup>λ_c²) F_y
F_n = 34.06 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 84 in Lateral unbraced length (assume k=0.8)
k_yL_y/r_y = 73</sup>

Compression Check = O.K.

Check Web Crippling

h = 24 in -- Check limits: C = 4.00
t = 0.0566 in h/t = 424.03 ≤ 200 C_R = 0.14
N = 7.00 N/t = 123.67 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.291667 ≤ 2.0 C_h = 0.02
P_n = 1.366 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 0.780 k
Long side: P_{u,trans} = 1.627 k **web stiffener REQ'D** # clips = 3
Short side: P_{u,Long} = 1.337 k **web stiffener REQ'D** # clips = 3
***h/t > 200; use web stiffeners
 $P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

Check Web Stiffener

16Ga x 3/4" x 7" (C-channel)
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70
w/t_s = 118.675
1.28√E/F_y = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 1.366 k A_e = 0.380 in²
P_n = 14.262 k P_n/Ω = 8.390 k
O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crn}max = 2036 lbs Max(F_{pmaxASD/4} -OR- F_{HASDtrans/4} corner connections)
V_{crn}max = 1929 lbs (Max Ten/2 corner connections per side)
Bolt: T_{all} = 2480 lbs V_{all} = 1096 lbs
Threaded Insert: T_{all} = 2860 lbs V_{all} = 1714 lbs
of Bolts required for Tension = 0.8
of Bolts required for Shear = 1.8
of Bolts Used = 2.0
Check Combined Stress in Bolts & Inserts: 1.290 **N.G.** StressComb = 0.860 **O.K.**
***If combined fails: USE --> 3.0

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.415 in $\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$
L_{req'd} = 1.643 in



Connection Unit to Curb Clip

#12 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.216$ in (screw diameter)

$dw = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 2146$ #
4.12 k

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2146$ #

$P_{ns} = 2.7t_1dF_{u1}$

2.15 k

$P_{ns} = 2.7t_2dF_{u2}$

3.86 k

$P_{ns}/\Omega = 715$ # - Controls

$P_{ss}/\Omega = 840$ #

Tension: $P_{not} = 1.214$ k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$P_{nov} = 2.069$ k (screw pull-over strength)

$t_c = \min(t_1, t_2)$

$P_{ts}/\Omega = 405$ # - Controls

$P_{nov} = 1.5t_1 d_w F_{u1}$

$P_{ts}/\Omega = 845$ #

(full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	8.143	3	2.71	715 #	4	2.00 in
Short side:	8.143	3	2.71	715 #	4	2.00 in

clip width (in) = 7.00

clip height = 1.4 in

min spacing = 0.65 in

edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: O.K.

thinnest part = 0.0566 AISI BSR applies

$F_y = 50$ ksi

$\Omega = 2.22$ bolt/screw connection

$A_{gv} = 0.368$ in²

$A_{nv} = 0.325$ in²


$A_{nt} = 0.033$ in²

$R_n/\Omega = 5.932$ k

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$

(AISI Sect. E5.3)

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDS)D + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 6559 lbs	Shear _{MAX} = 4564 lbs
Compression _{SEISMIC} = 7705 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$	
Tension _{SEISMIC} = 6559 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$	
Compression _{WIND} = 1385 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$	
Tension _{WIND} = 1874 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$	
Longitudinal:	Uplift _{MAX} = 4692 lbs	Shear _{MAX} = 4564 lbs
Compression _{SEISMIC} = 5838 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$	
Tension _{SEISMIC} = 4692 lbs	$= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$	
Compression _{WIND} = 485 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb}/2) * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$	
Tension _{WIND} = 973 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb}/2) * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$	

Transverse:

Uplift_{MAX} = 6559 lbs

WIND: 0.6D + W

Compression_{SEISMIC} = 7705 lbs

Tension_{SEISMIC} = 6559 lbs

Compression_{WIND} = 1385 lbs

Tension_{WIND} = 1874 lbs

Longitudinal:

Compression_{SEISMIC} = 5838 lbs

Tension_{SEISMIC} = 4692 lbs

Compression_{WIND} = 485 lbs

Tension_{WIND} = 973 lbs

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Transverse:

Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Tall_{wood} = 1195.95 lbs

Vall_{wood} = 1024 lbs

of Screws Req'd for Uplift = 6.93

of Screws Req'd for Shear = 4.46

Total # of screws Required = 8

COMBINED LOADING: 1.243 NO GOOD

Screw Spacing = 16.8 in o.c.

Use 5/8" ϕ wood lag screws @ 16.8 in o.c. along long side of curb

Longitudinal:

of Screws Req'd for Uplift = 5.0

of Screws Req'd for Shear = 4.5

Total # of screws Required = 6

COMBINED LOADING: 1.397 NO GOOD

Screw Spacing = 15.0 in o.c.

Use 5/8" ϕ wood lag screws @ 15 in o.c. along short side of curb

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Transverse:

Tall_{bolt} = 6903 lbs

Vall_{bolt} = 3682 lbs

Tall_{wood} = 6903 lbs

Vall_{wood} = 3682 lbs

of Bolts Req'd for Uplift = 0.95

of Bolts Req'd for Shear = 1.24

Total # of Bolts Required = 2

COMBINED LOADING: 0.740 O.K.

Bolt Spacing = 113.3 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 113.3 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.68

of Bolts Req'd for Shear = 1.24

Total # of Bolts Required = 2

COMBINED LOADING: 0.616 O.K.

Req'd Min Spacing = 71.0 in o.c.

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 71 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ___ of ___

For Concrete anchorage: SEISMIC $[0.6-0.14S_{DS}]D + 0.7\Omega_o E$ ($\Omega_o = 2.5$)

Concrete Attachment: $3/4"$ ϕ Hilti HIT-HY 200 adhesive anchors w/ $4"$ embed

$T_{all,LRFD} = 1722 \text{ lbs}$ $V_{all,LRFD} = 2032 \text{ lbs}$ $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
 $T_{all,ASD} = T_{all,LRFD}/\alpha = 920.9 \text{ lbs}$ $V_{all,ASD} = V_{all,LRFD}/\alpha = 1086.6 \text{ lbs}$ ($D = 0.465, E = 0.535$)

Transverse: $Uplift_{MAX} = 14858 \text{ lbs}$ $Shear_{MAX} = 11409 \text{ lbs}$

Compression_{SEISMIC} = 16004 lbs $= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$
 Tension_{SEISMIC} = 14858 lbs $= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$
 Shear_{SEISMIC} = 11409 lbs $= 2.5 * F_{pmaxASD} / 2$

Min Bolts Req'd Uplift = 16.13 spacing = 6.33 in o.c. $T_{applied} = 825.4 \text{ lbs}$
 Min Bolts Req'd Shear = 10.50 spacing = 10.125 in o.c. $V_{applied} = 633.8 \text{ lbs}$

Try using 18 bolts spaced at 6.66 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.48$

Use $18 - 3/4"$ ϕ Hilti HIT-HY 200 adhesive anchors @ 6.7 in o.c. max. along long side of curb w/ $4"$ embed

Longitudinal: $Uplift_{MAX} = 10192 \text{ lbs}$ $Shear_{MAX} = 11409 \text{ lbs}$

Compression_{SEISMIC} = 11338 lbs $= [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$
 Tension_{SEISMIC} = 10192 lbs $= Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] * (WGT_{unit+curb})$
 Shear_{SEISMIC} = 11409 lbs $= 2.5 * F_{pmaxASD} / 2$

Min Bolts Req'd Uplift = 11.07 spacing = 5.363636 in o.c. $T_{applied} = 784.0 \text{ lbs}$
 Min Bolts Req'd Shear = 10.50 spacing = 5.9 in o.c. $V_{applied} = 877.6 \text{ lbs}$

Try using 13 bolts spaced at 5.92 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.66$

Use $13 - 3/4"$ ϕ Hilti HIT-HY 200 adhesive anchors @ 5.9 in o.c. max. along short side of curb w/ $4"$ embed

CURB DESIGN SUMMARY: CBWC-115			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 3 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 3 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 3 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	8 @ 16.75 in o.c.	2 @ 113.25 in o.c.	18 @ 6.66 in o.c.
SHORT DIRECTION	6 @ 15 in o.c.	2 @ 71 in o.c.	13 @ 5.92 in o.c.