



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBWC-119 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: July 29, 2019
Project Number: PV1806

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-60.

FEATURES

- Roof curb sides and ends are 16 ga. galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

NOTES




- Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.
- Thru the curbs utilities are available. Contact your York distributor or Provent directly.

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR YORK UNITS


P***B ALL MODELS

ProVent P/N	A	WEIGHT
CBWCLXL08	8"	74 Lbs
CBWCLXL11	11"	85 Lbs
CBWCLXL14	14"	97 Lbs
CBWCLXL24	24"	171 Lbs


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015



CURB DETAIL



HOLD DOWN DETAIL



DETAIL B



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBWC-119


DATE:
07/31/18

REV:
4

PART NUMBER:
CBWCLXL SERIES

DRAWN BY:
ALL

STEEL ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT


CONCRETE ATTACHMENT



ROOF ANCHORAGE DETAIL		
CBKD Series	CBWC Series	CBISC Series
LXS	LXS	LXS
LXL	LXL	LXL
SUN3672	SUN3672	SUN3672
PRD3715	PRD3715	PRD3715
PRS	PRS	PRS
PRL	PRL	PRL
	SLU180	SLU180
	SLM1830	SLM1830

NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL




Client: ProVent PV1806
Description: CBWC-119 (CBWCLXL**)
Unit: ALL YORK P***B MODELS

Curb Information

Hcurb = 24 in (Height of curb)
Lcurb = 46.5 in (Length of curb)
wcurb = 41 in (Width of curb)
WGTcurb = 171 lbs (Weight of curb)
Clips long side = 1 # Clips short side = 1

Unit Information

WGTunit = 420 lbs (Weight of Unit)
Wtmax = 141 lbs (Maximum corner weight)
Wtmin = 78 lbs (Minimum corner weight)
Hunit = 55 in (Height of unit above curb)
Hcm = 27.5 in (Height to center of mass)
Lunit = 51.25 in (Length of unit)
Wunit = 45.75 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 1117 lbs (0.7*Fpmax)
FpmaxASD = 1572 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² [Eq. 29.3-1 ASCE 7-10]
FhASDtrans = 1042 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) [Eq. 29.5-2]
FhASDlong = 930 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
FvertASD = 477 lbs = 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

Compression_{SEISMIC} = 1106 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 966 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 630 lbs = [FhtransASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 855 lbs = Comp_{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 1018 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 877 lbs = Comp_{SEISMIC} - [0.6-0.14S_{DS}]*WGTunit
Compression_{WIND} = 481 lbs = [FhlongASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 706 lbs = Comp_{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1106 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 966 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1018 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 877 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0566 16 Gauge

Calculate Section Properties of Curb

A' = 24.000 in	a = 23.717 in = A' - (2r + t)
B' = 3.000 in	a' = 23.943 in = A' - t
C' = 1.000 in (0 if no lips)	b = 2.717 in = B' - (r + t/2 + a(r + t/2))
o = 1.000 in (0 - no lip; 1 w/ lip)	b' = 2.943 in = B' - (t/2 + at/2)
R = 0.0849 (Inside bend radius)	c = 0.859 in = a[C' - (r + t/2)]
t = 0.0566 in	c' = 0.972 in = a[C' - t/2]
r' = 0.113 in = R + t/2	u = 0.178 in = nr/2
x = 0.446 in (Distance between centroid and web centerline)	
I _x = 125.486 in (Moment of Inertia about X-Axis)	
I _y = 1.511 in (Moment of Inertia about Y-Axis)	
A = 1.79 in ²	
r _x = 8.38 in	
r _y = 0.919 in	
r _{min} = 0.919 in	



Axial Compression

P _u = 0.559 k	(Max Axial Comp)	Ω _c = 1.80
P _n /Ω _c = 33.817 k		
F _e = 54.49 ksi	$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$	$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ _c = 0.96	If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$	
F _n = 34.06 ksi		
L _y = 84 in	Lateral unbraced length	
k _y L _y /r _y = 73	(assume k=0.8)	
Compression Check = 0.K.		

Check Web Crippling

h = 24 in	-- Check limits:	C = 4.00	[See table C3.4.1-2, fastened to support, one flange, end loading]
t = 0.0566 in	h/t = 424.03 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 123.67 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.291667 ≤ 2.0	C _h = 0.02	
P _n = 1.366 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 0.780 k			
Long side: P _u trans = 1.106 k	web stiffener REQ'D # clips = 1	$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$	
Short side: P _u Long = 1.018 k	web stiffener REQ'D # clips = 1		

***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]

width of stiffener = 7.000 in	t _s = 0.0566 16 Gauge
web of stiff. w = 6.717 in	R _s = 0.0849 in
***Check w/ts ≤ 1.28√E/F _y	Ω _c = 1.70
w/ts = 118.675	
1.28√E/F _y = 31.091	--> w/ts over limit Use C3.7.2
P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}	
P _{wc} = 1.366 k	A _e = 0.380 in ²
P _n = 14.262 k	P _n /Ω = 8.390 k
0.K.	

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{cn} max = 279 lbs	Max(F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections)
V _{cn} max = 483 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs	V _{all} = 1096 lbs
Threaded Insert: Tall = 2860 lbs	V _{all} = 1714 lbs
# of Bolts required for Tension = 0.1	
# of Bolts required for Shear = 0.4	
# of Bolts Used = 1.0	
Check Combined Stress in Bolts & Inserts: 0.553 0.K.	***if combined fails: USE --> 2.0
	StressComb = 0.277 0.K.

Check 1/8" welded connection

---- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.415 in	$\frac{P_n}{\Omega} = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$	$L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$
L _{req'd} = 0.411 in		



Connection Unit to Curb Clip

#10 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_u1 = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_u2 = 65$ ksi

$d = 0.190$ in (screw diameter)

$d_w = 0.375$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 1887$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 1887$ #

$P_{ns} = 2.7t_1dF_{u1}$

$P_{ns} = 2.7t_1dF_{u1}$

$P_{ns} = 2.7t_2dF_{u2}$

$P_{ns} = 2.7t_2dF_{u2}$

$P_{ns}/\Omega = 629$ #

$P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 1.068$ k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$P_{nov} = 2.069$ k (screw pull-over strength)

$t_c = \min(t_1, t_2)$

$P_{ts}/\Omega = 356$ # <- Controls

$P_{ts}/\Omega = 820$ #

[full tensile screw capacity]

Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side: 1.117	1	1.12	540 #	3	3.00 in
Short side: 1.117	1	1.12	540 #	3	3.00 in

clip width (in) = 7.00

min spacing = 0.57 in

clip height = 1.4 in

edge distance = 0.5 in (min. 1.5d)

thinnest part = 0.0566 AISI BSR applies

$\Omega = 2.22$ bolt/screw connection

$A_{nv} = 0.341$ in²

$A_{nt} = 0.034$ in²

Check Block shear rupture: O.K.

$F_y = 50$ ksi


$A_{gv} = 0.368$ in²

$R_n/\Omega = 5.954$ k

$R_n = 0.6F_yA_{gv} + F_uA_{nt} \leq 0.6F_uA_{nv} + F_uA_{nt}$

[AISI Sect. E5.3]

BSR O.K.



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $[0.6-0.14SDS]D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX}	2151 lbs	Shear _{MAX}	786 lbs
Compression _{SEISMIC}	2349 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + 1 + 0.14SDS] * [WGT_{unit+curb}/2] * w_{curb} / w_{curb}$		
Tension _{SEISMIC}	2151 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14SDS] * [WGT_{unit+curb}]$		
Compression _{WIND}	1248 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * [WGT_{unit+curb}/2] * w_{curb} - F_{vertASD} * w_{curb}/2] / w_{curb}$		
Tension _{WIND}	1370 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * [WGT_{unit+curb}/2] * w_{curb} + F_{vertASD} * w_{curb}/2] / w_{curb}$		
Longitudinal:	Uplift _{MAX}	1918 lbs	Shear _{MAX}	786 lbs
Compression _{SEISMIC}	2115 lbs	$= [F_{pmaxASD} * (H_{cm} + H_{curb}) + 1 + 0.14SDS] * [WGT_{unit+curb}/2] * L_{curb} / L_{curb}$		
Tension _{SEISMIC}	1918 lbs	$= Comp_{SEISMIC} - [0.6 - 0.14SDS] * [WGT_{unit+curb}]$		
Compression _{WIND}	970 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) + 0.6 * [WGT_{unit+curb}/2] * L_{curb} - F_{vertASD} * L_{curb}/2] / L_{curb}$		
Tension _{WIND}	1091 lbs	$= [F_{htransASD} * (H_{cm} + H_{curb}) - 0.6 * [WGT_{unit+curb}/2] * L_{curb} + F_{vertASD} * L_{curb}/2] / L_{curb}$		

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Tall_{screw} = 6133 lbs

$V_{allmetal} = 2744$ lbs

Transverse: Tall_{wood} = 1196 lbs

$V_{allwood} = 1024$ lbs

of Screws Req'd for Uplift = 1.80

COMBINED LOADING: 0.367 O.K.

of Screws Req'd for Shear = 0.77

Screw Spacing = 6.4 in o.c.

Total # of screws Required = 7

Use 5/8" ϕ wood lag screws @ 6.4 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

of Screws Req'd for Uplift = 1.6

COMBINED LOADING: 0.395 O.K.

of Screws Req'd for Shear = 0.8

Screw Spacing = 6.6 in o.c.

Total # of screws Required = 6

Use 5/8" ϕ wood lag screws @ 6.6 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Tall_{bolt} = 6903 lbs

$V_{allbolt} = 3682$ lbs

Transverse: Tall_{bolt} = 6903 lbs

$V_{allbolt} = 3682$ lbs

of Bolts Req'd for Uplift = 0.31

COMBINED LOADING: 0.069 O.K.

of Bolts Req'd for Shear = 0.21

Bolt Spacing = 34.5 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 34.5 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.28

COMBINED LOADING: 0.061 O.K.

of Bolts Req'd for Shear = 0.21

Req'd Min Spacing = 29.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 29 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
16191727-4800
Page ____ of ____

For Concrete anchorage: SEISMIC $(0.6-0.14S_{DS})D + 0.7Q_p E$ ($Q_p = 2.5$)

Concrete Attachment: $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors w/ $4"$ embed

Tall_{LRFD} = 1722 lbs Vall_{LRFD} = 2032 lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$

Tall_{ASD} = Tall_{LRFD}/ α = 920.9 lbs Vall_{ASD} = Vall_{LRFD}/ α = 1086.6 lbs ($D = 0.465, E = 0.535$)

Transverse: Uplift_{MAX} = 5113 lbs Shear_{MAX} = 1965 lbs

Compression_{SEISMIC} = 5311 lbs $= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 5113 lbs $= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$

Shear_{SEISMIC} = 1965 lbs $= 2.5 \cdot F_{pmaxASD}/2$

Min Bolts Req'd Uplift = 5.55 spacing = 4.50 in o.c. T_{applied} = 639.2 lbs

Min Bolts Req'd Shear = 2.00 spacing = 22.5 in o.c. V_{applied} = 245.6 lbs

Try using 8 bolts spaced at 4.93 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allowASD}} + \frac{V_{applied}}{V_{allowASD}} \leq 1.2 = 0.92$

Use 8 - $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors @ 4.9 in o.c. max. along long side of curb w/ $4"$ embed

Longitudinal: Uplift_{MAX} = 4529 lbs Shear_{MAX} = 1965 lbs

Compression_{SEISMIC} = 4727 lbs $= [2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 4529 lbs $= Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$

Shear_{SEISMIC} = 1965 lbs $= 2.5 \cdot F_{pmaxASD}/2$

Min Bolts Req'd Uplift = 4.92 spacing = 4.25 in o.c. T_{applied} = 647.1 lbs

Min Bolts Req'd Shear = 2.00 spacing = 17 in o.c. V_{applied} = 280.7 lbs

Try using 7 bolts spaced at 4.83 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allowASD}} + \frac{V_{applied}}{V_{allowASD}} \leq 1.2 = 0.96$

Use 7 - $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors @ 4.8 in o.c. max. along short side of curb w/ $4"$ embed

CURB DESIGN SUMMARY: CBWC-119			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 3 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x $3/4"$ x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 3 - #10 SMS screws each clip			
WEB STIFFENER: 16Ga x $3/4"$ x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 2 - $1/4"$ ϕ SAE Grade 8 bolts w/ $1/4$ -20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	$5/8"$ ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	$5/8"$ ϕ A307 bolts	$3/4"$ ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	7 @ 6.42 in o.c.	2 @ 34.5 in o.c.	8 @ 4.93 in o.c.
SHORT DIRECTION	6 @ 6.6 in o.c.	2 @ 29 in o.c.	7 @ 4.83 in o.c.