

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60.

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR YORK UNITS

PROVENT P/N	A	EST. WEIGHT
CBWCPRS08	8"	125 Lbs.
CBWCPRS11	11"	136 Lbs.
CBWCPRS14	14	147 Lbs.
CBWCPRS24	24"	186 Lbs.



ZX 04-07
ZY, ZQ, XY 04-06

- FEATURES**
- Roof curb sides and ends are 16 Ga. galvanized steel.
 - Gasketing package provided.
 - Heat treated wood nailer provided.
 - Pitched curbs and taller curbs are available.


Notes

Attached ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015




ATTACH TO CURB WITH
(6) #12X 3/4" @ 3 O.C. TEK SCREW,
EACH SIDE (LONG SIDE)
(3) #10X 3/4" @ 3 O.C. TEK SCREW
EACH SIDE (SHORT SIDE)



HOLD DOWN DETAIL



CURB DETAIL



DETAIL B



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CBWC-300

DATE:
9/27/2018

PART NUMBER:
CBWCPRS SERIES

REV:
6

DRAWN BY:
ALL