



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
619-727-4800

**Structural Calculations
for
CBWC-301 Series**



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: July 29, 2019
Project Number: PV1806

For wood, concrete and steel attachments see Roof Anchorage Detail, Form Nos. CB-60.

FEATURES

- Roof curb sides and ends are 16 Ga. galvanized steel.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.

Notes



- Attached ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.
- Through the curbs utilities are available. Contact your York distributor or ProVent directly.

STRUCTURALLY CALCULATED WELDED ROOF CURBS FOR YORK UNITS


ZX, 08-14; XX 12
ZY 07-12; XY 07-09

PROVENT P/N	A	EST. WEIGHT
CBWCPR08	8"	163 Lbs.
CBWCPR11	11"	177 Lbs.
CBWCPR614	14	192 Lbs.
CBWCPR24	24"	240 Lbs.


Meets seismic requirements for the following codes:
CBC 2016
IBC 2015




ATTACH TO CURB WITH
(3) # 12 x 3/4" @ 6 O.C. TEK SCREWS,
EACH SIDE (LONG SIDE)
(4) # 10 x 3/4" TEK SCREWS,
EACH SIDE (SHORT SIDE)



HOLD DOWN DETAIL



CURB DETAIL



DETAIL B



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO:
COMPANY:
JOB NAME:
EQUIPMENT:
NOTES:

FORM NO:
CBWC-301


PART NUMBER:
CBWCPR1 SERIES

DATE:
9/27/2018

REV:
5

DRAWN BY:
ALL

STEEL ATTACHMENT




NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	2 @ 34.5" O.C	XX @ 2 @ 19" O.C
LXL	2 @ 34.5" O.C.XX	2 @ 29" O.C
SUN3672	2 @ 60" O.C	2 @ 24.25" O.C
PRD3715	2 @ 68.38" O.C	2 @ 38.5" O.C
PRS	2 @ 58.38" O.C	2 @ 28.19" O.C.
PRL	2 @ 72" O.C	2 @ 41" O.C
SLU180	2 @ 102.25" O.C.	2 @ 71" O.C.
SLM1830	2 @ 113.25" O.C	2 @ 71" O.C.

* SIX INCHES FROM EACH CORNER EVENLY SPACED.
** CENTERED.

Meets seismic requirements for the following codes:
CBC 2016
IBC 2015

ASSUMES:
CONC SLAB
 $f'_c = 4000$ PSI MINIMUM
6" MIN THICKNESS
NORMAL WEIGHT CONCRETE
OR SAND LIGHT WEIGHT


CONCRETE ATTACHMENT



ROOF ANCHORAGE DETAIL		
CBKD Series	CBWC Series	CBISC Series
LXS	LXS	LXS
LXL	LXL	LXL
SUN3672	SUN3672	SUN3672
PRD3715	PRD3715	PRD3715
PRS	PRS	PRS
PRL	PRL	PRL
	SLU180	SLU180
	SLM1830	SLM1830

NO. OF ANCHORAGE BOLTS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	10 @ 3.73" O.C.	9 @ 2.38" O.C.
LXL	8 @ 4.93" O.C.	7 @ 4.83" O.C.
SUN3672	9 @ 7.5" O.C.	6 @ 4.85" O.C.
PRD3715	17 @ 4.27" O.C.	13 @ 3.21" O.C.
PRS	9 @ 7.3" O.C.	7 @ 4.7" O.C.
PRL	11 @ 7.2" O.C.	9 @ 5.13" O.C.
SLU180	16 @ 6.82" O.C.	13 @ 5.92" O.C.
SLM1830	18 @ 6.66" O.C.	13 @ 5.92" O.C.

WOOD ATTACHMENT



NO. OF ANCHORAGE SCREWS REQUIRED		
CURB	LONG SIDE	SHORT SIDE
LXS	7 @ 6.42" O.C.	4 @ 7.67" O.C.
LXL	7 @ 6.42" O.C.	6 @ 6.6" O.C.
SUN3672	4 @ 21.33" O.C.	3 @ 14.13" O.C.
PRD3715	8 @ 10.34" O.C.	6 @ 8.5" O.C.
PRS	4 @ 20.79" O.C.	3 @ 16.09" O.C.
PRL	4 @ 25.33" O.C.	3 @ 22.5" O.C.
SLU180	7 @ 17.71" O.C.	7 @ 12.5" O.C.
SLM1830	8 @ 16.75" O.C.	6 @ 15" O.C.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE
MIRA LOMA, CA 91725

PHONE (951) 685-1101
FAX (619) 872-9799

SUBMITTED TO: _____
COMPANY: _____
JOB NAME: _____
EQUIPMENT: _____
NOTES: _____

FORM NO:
CB-60

DATE:
07/31/18

REV:
3

DRAWN BY:
ALL




Client: ProVent PV1806
Description: CBWC-301 [CBWCPRL**]
Unit: ZX, ZY 08-12; ZX 14; ZY 07

Curb Information

Hcurb = 24 in (Height of curb)
Lcurb = 84 in (Length of curb)
wcurb = 53 in (Width of curb)
WGTcurb = 240 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 1

Unit Information

WGTunit = 1152 lbs (Weight of Unit)
Wtmax = 312 lbs (Maximum corner weight)
Wtmin = 212 lbs (Minimum corner weight)
Hunit = 32.53 in (Height of unit above curb)
Hcm = 16.265 in (Height to center of mass)
Lunit = 74.05 in (Length of unit)
Wunit = 48.88 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.85 (Worst case for majority of CA - Design Category D)
Fa = 1 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 3064 lbs (0.7*Fpmax)
FpmaxASD = 3703 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf
Fn ASD trans = 1078 lbs = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fn ASD long = 711 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fvert ASD = 736 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb) (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 1730 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 1346 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 337 lbs = [Fn trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 382 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 1383 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 999 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 144 lbs = [Fn trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 189 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1730 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 1346 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1383 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 999 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0566 16 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 24.000 in a = 23.717 in = A' - (2r + t)
B' = 3.000 in a' = 23.943 in = A' - t
C' = 1.000 in [0 if no lips] b = 2.717 in = B' - [r + t/2 + a(r + t/2)]
d = 1.000 in [0 - no Lip; 1 w/ lip] b' = 2.943 in = B' - (t/2 - at/2)
R = 0.0849 in [Inside bend radius] c = 0.859 in = a[C' - (r + t/2)]
t = 0.0566 in c' = 0.972 in = a[C' - t/2]
r' = 0.113 in = R + t/2 u = 0.178 in = πr/2
x = 0.446 in [Distance between centroid and web centerline]
Ix = 125.486 in [Moment of Inertia about X-Axis]
Iy = 1.511 in [Moment of Inertia about Y-Axis]
A = 1.79 in²
rx = 8.38 in
ry = 0.919 in
rmin = 0.919 in



Axial Compression

Pu = 1.532 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 33.817 k
Fe = 54.49 ksi
λc = 0.96
Fn = 34.06 ksi
Ly = 84 in
kyLy/ry = 73
λc = $\sqrt{\frac{F_y}{F_e}}$ Fe = $\frac{\pi^2 E}{(kl/r)^2}$
If λc ≤ 1.5: Fn = (0.658^{λc²}) Fy
If λc > 1.5: Fn = $\frac{0.877}{\lambda_c^2} F_y$
Lateral unbraced length (assume k=0.8)

Compression Check = **O.K.**

Check Web Crippling

h = 24 in -- Check limits: C = 4.00
t = 0.0566 in h/t = 424.03 ≤ 200 CR = 0.14
N = 7.00 N/t = 123.67 ≤ 210 CN = 0.35 (See table C3.4.1-2, fastened to support, one flange, end loading)
Qw = 1.75 N/h = 0.291667 ≤ 2.0 Cn = 0.02
Pn = 1.366 k
Pn/Ωw = 0.780 k
Long side: PuTrans = 0.865 k web stiffener REQ'D # clips = 2
Short side: PuLong = 1.383 k web stiffener REQ'D # clips = 1
***h/t > 200; use web stiffeners
Pn = Ct²Fy sin(90) $\left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_n \sqrt{\frac{h}{t}}\right)$

Check Web Stiffener

16Ga x 3/4" x 7" [C-channel]
width of stiffener = 7.000 in ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/Fys Ωc = 1.70
w/ts = 118.675
1.28√E/Fys = 31.091 --> w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc
Pwc = 1.366 k Ae = 0.380 in²
Pn = 14.262 k Pn/Ω = 8.390 k
O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
Tcrnmax = 766 lbs Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 673 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.3
of Bolts required for Shear = 0.6
of Bolts Used = 1.0
***If combined fails:
Check Combined Stress in Bolts & Inserts: 0.923 O.K. USE --> 2.0 StressComb = 0.461 O.K.

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.415 in Pn/Ω = $\frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ Lreq'd = $\frac{V_{req} \Omega}{0.75 t F_u}$
Lreq'd = 0.573 in



Connection Unit to Curb Clip

#14 SMS screw

$\Omega = 3.0$

$t_1 = 0.0566$ in

$F_{u1} = 65$ ksi

$t_2 = 0.1017$ in (unit base rail thickness)

$F_{u2} = 65$ ksi

$d = 0.242$ in (screw diameter)

$d_w = 0.500$ in (nom. washer diameter)

$t_2/t_1 = 1.8$

For $t_2/t_1 \leq 1.0$:

Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$

$P_{ns} = 2404$ #

For $t_2/t_1 \geq 2.5$:

$P_{ns} = 2404$ #

$P_{ns} = 2.7t_1dF_{u1}$

$P_{ns} = 2.7t_1dF_{u1}$

$P_{ns} = 2.7t_2dF_{u2}$

$P_{ns} = 2.7t_2dF_{u2}$

$P_{ns}/\Omega = 801$ # <- Controls

$P_{ss}/\Omega = 1045$ #

Tension: $P_{not} = 1.360$ k (screw pull-out strength)

$P_{not} = 0.85t_c d F_{u2}$

$P_{nov} = 2.759$ k (screw pull-over strength)

$t_c = \min(t_1, t_2)$

$P_{ts}/\Omega = 453$ # <- Controls

$P_{ts}/\Omega = 1220$ #

(full tensile screw capacity)

Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side: 3.064	2	1.53	801 #	2	6.00 in
Short side: 3.064	1	3.06	801 #	4	2.00 in

clip width (in) = 7.00

min spacing = 0.73 in

clip height = 1.4 in

edge distance = 0.5 in (min. 1.5d)

thinnest part = 0.0566 AISI BSR applies

$\Omega = 2.22$ bolt/screw connection

$\Omega = 0.320$ in²

$\Omega = 0.032$ in²

Check Block shear rupture: O.K.

$F_y = 50$ ksi


$A_{gv} = 0.368$ in²

$R_n/\Omega = 5.910$ k

BSR O.K.

$R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{gv} + F_u A_{nt}$

(AISI Sect. E5.3)



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6-0.14S_{DS})D + 0.7E$

WIND: $0.6D + W$

Transverse:	Uplift _{MAX} =	3229 lbs	Shear _{MAX} =	1851 lbs
Compression _{SEISMIC} =	3694 lbs	= $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$		
Tension _{SEISMIC} =	3229 lbs	= $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$		
Compression _{WIND} =	868 lbs	= $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} - F_{vertASD} \cdot w_{curb}/2] / w_{curb}$		
Tension _{WIND} =	769 lbs	= $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot w_{curb} + F_{vertASD} \cdot w_{curb}/2] / w_{curb}$		
Longitudinal:	Uplift _{MAX} =	2191 lbs	Shear _{MAX} =	1851 lbs
Compression _{SEISMIC} =	2656 lbs	= $[F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$		
Tension _{SEISMIC} =	2191 lbs	= $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) \cdot (WGT_{unit+curb})$		
Compression _{WIND} =	391 lbs	= $[F_{htransASD} \cdot (H_{cm} + H_{curb}) + 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} - F_{vertASD} \cdot L_{curb}/2] / L_{curb}$		
Tension _{WIND} =	291 lbs	= $[F_{htransASD} \cdot (H_{cm} + H_{curb}) - 0.6 \cdot (WGT_{unit+curb}/2) \cdot L_{curb} + F_{vertASD} \cdot L_{curb}/2] / L_{curb}$		

Wood Attachment:

Use 5/8" ϕ wood lag screws

w/ 3.5" Min. Embed

Transverse:

Tall_{metal} = 946.67 lbs

Vall_{metal} = 1043.33 lbs

Tall_{wood} = 1195.95 lbs

Vall_{wood} = 1024 lbs

of Screws Req'd for Uplift = 3.41

COMBINED LOADING: 0.786 O.K.

of Screws Req'd for Shear = 1.81

Screw Spacing = 25.3 in o.c.

Total # of screws Required = 4

Use 5/8" ϕ wood lag screws @ 25.3 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

of Screws Req'd for Uplift = 2.3

COMBINED LOADING: 0.870 O.K.

of Screws Req'd for Shear = 1.8

Screw Spacing = 22.5 in o.c.

Total # of screws Required = 3

Use 5/8" ϕ wood lag screws @ 22.5 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment:

Use 5/8" ϕ A307 Bolts attached to steel angle below deck

Transverse:

Tall_{bolt} = 6903 lbs

Vall_{bolt} = 3682 lbs

Tall_{bolt} = 6903 lbs

Vall_{bolt} = 3682 lbs

of Bolts Req'd for Uplift = 0.47

COMBINED LOADING: 0.189 O.K.

of Bolts Req'd for Shear = 0.50

Bolt Spacing = 72.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 72 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.32

COMBINED LOADING: 0.147 O.K.

of Bolts Req'd for Shear = 0.50

Req'd Min Spacing = 41.0 in o.c.

Total # of Bolts Required = 2

Use 5/8" ϕ A307 Bolts attached to steel angle below deck @ 41 in o.c. along short side of curb



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.

San Diego, CA 92120

(619)727-4800

Page ____ of ____

For Concrete anchorage: SEISMIC $0.6-0.14S_{DS}$ + $0.7\Omega_e E$ ($\Omega_e = 2.5$)

Concrete Attachment: $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors w/ $4"$ embed

Tall_{LRFD} = 1722 lbs

Vall_{LRFD} = 2032 lbs

$\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$

Tall_{ASD} = Tall_{LRFD}/ α = 920.9 lbs

Vall_{ASD} = Vall_{LRFD}/ α = 1086.6 lbs

($D = 0.465, E = 0.535$)

Transverse: Uplift_{MAX} = 7449 lbs Shear_{MAX} = 4628 lbs

Compression_{SEISMIC} = 7914 lbs = $[2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 7449 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb})$

Shear_{SEISMIC} = 4628 lbs = $2.5 \cdot F_{pmaxASD}/2$

Min Bolts Req'd Uplift = 8.09 spacing = 7.50 in o.c.

T_{applied} = 677.2 lbs

Min Bolts Req'd Shear = 4.26 spacing = 15 in o.c.

V_{applied} = 420.8 lbs

Try using 11 bolts

spaced at 7.20 in o.c.

COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.12$

Use 11 - $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors @ 7.2 in o.c. max. along long side of curb w/ $4"$ embed

Longitudinal: Uplift_{MAX} = 4853 lbs Shear_{MAX} = 4628 lbs

Compression_{SEISMIC} = 5318 lbs = $[2.5 \cdot F_{pmaxASD} \cdot (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) \cdot (WGT_{unit+curb}/2) \cdot L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 4853 lbs = $Comp_{SEISMIC} - [0.6 - 0.14S_{DS}] \cdot (WGT_{unit+curb})$

Shear_{SEISMIC} = 4628 lbs = $2.5 \cdot F_{pmaxASD}/2$

Min Bolts Req'd Uplift = 5.27 spacing = 5.8 in o.c.

T_{applied} = 539.3 lbs

Min Bolts Req'd Shear = 4.26 spacing = 7.25 in o.c.

V_{applied} = 514.3 lbs

Try using 9 bolts

spaced at 5.13 in o.c.

COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.06$

Use 9 - $3/4"$ ϕ Hilti Hit-HY 200 adhesive anchors @ 5.1 in o.c. max. along short side of curb w/ $4"$ embed

CURB DESIGN SUMMARY: CBWC-301			
CURB RAIL THICKNESS: 0.0566 in 16 Gauge			
UNIT CLIP THICKNESS: 0.0566 in 16 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 2 - #14 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #14 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4" x 7" (C-channel) stiffener at each clip			
CORNER CONNECTION: Use 2 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	5/8" ϕ lag screw w/ min. 3.5" embed (SGmin=0.43)	5/8" ϕ A307 bolts	3/4" ϕ thrd'd rod in Hilti HIT-HY 200 epoxy, min. 4" embed
LONG DIRECTION	4 @ 25.33 in o.c.	2 @ 72 in o.c.	11 @ 7.2 in o.c.
SHORT DIRECTION	3 @ 22.5 in o.c.	2 @ 41 in o.c.	9 @ 5.13 in o.c.