



MOUR GROUP
ENGINEERING + DESIGN

Structural Calculations
for
CBISC-02 Series



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 22, 2018
Project Number: PV1805




Client: ProVent PV1805
Project: CBISC-02 Iso Curb [CBISCLX]** Upper curb rail
Unit: ALL YORK P***B CABINETS

Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	46.5 in	(Length of curb)
wcurb =	41 in	(Width of curb)
WGTcurb =	239 lbs	(Weight of curb)
# Clips long side =	1	# Clips short side = 1

Unit Information

WGTunit =	420 lbs	(Weight of Unit)
Wtmax =	141 lbs	(Maximum corner weight)
Wtmin =	78 lbs	(Minimum corner weight)
Hunit =	55 in	(Height of unit above curb)
Hcm =	27.5 in	(Height to center of mass)
Lunit =	51.25 in	(Length of unit)
Wunit =	45.75 in	(Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss =	2.850	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-10)
Sms =	2.850	[Fa*Ss]
Sds =	1.900	[2/3*Sms]
Ip =	1.25	(Importance Factor Category III Building)
Fpmax =	3.800 Wp	[1.6*Sds*Ip]*Wp
FpmaxASD =	1117 lbs	[0.7*Fpmax]
	(unit only)	FpmaxASD = 1753 lbs
		(unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz =	1.13	[For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10]
Kzt =	1.0	[No topographic effects assumed for rooftop mounted units]
Kd =	0.85	[Directionality factor Table 26.6-1 ASCE 7-10]
V =	115	[Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C]
GCr [horiz] =	1.9	[Refer Sect 29.5.1 ASCE 7-10]
GCr [vert] =	1.5	[Refer Sect 29.5.1 ASCE 7-10]
qz	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² [Eq. 29.3-1 ASCE 7-10]
Fh ASD trans =	798 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) [Eq. 29.5-2]
Fh ASD long =	713 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
Fvert ASD =	477 lbs	= 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

Compression _{SEISMIC} =	1106 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	966 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	466 lbs	= [Fh trans ASD * Hcm + 2*0.6*Wtmax*wcurb - Fvert ASD * wcurb/2]/wcurb
Tension _{WIND} =	691 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	1018 lbs	= [FpmaxASD*Hcm + 2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	877 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	352 lbs	= [Fh trans ASD * Hcm + 2*0.6*Wtmax*Lcurb - Fvert ASD * Lcurb/2]/Lcurb
Tension _{WIND} =	577 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1106 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 966 lbs	----> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 1018 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 877 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.000 in [0 if no lips]	b = 1.322 in = B' - [r+t/2 + a(r+t/2)]
α = 0.000 [0 - no Lip; 1 w/ lip]	b' = 1.464 in = B' - [t/2 + αt/2]
R = 0.1069 [Inside bend radius]	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.261 in [Distance between centroid and web centerline]	
Ix = 2.424 in [Moment of Inertia about X-Axis]	
Iy = 0.109 in [Moment of Inertia about Y-Axis]	
A = 0.59 in ²	
rx = 2.03 in	
ry = 0.432 in	
rmin = 0.432 in	



Axial Compression

Pu = 0.559 k (Max Axial Comp) Ωc = 1.80
Pn/Ωc = 9.561 k
Fe = 39.18 ksi
λc = 1.13
Fn = 29.31 ksi
Ly = 46.50 in
kjLy/ry = 86

$\lambda_c = \frac{F_y}{F_e}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

If $\lambda_c \leq 1.5$; $F_n = (0.658\lambda_c^2) F_y$
If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$

Lateral unbraced length [assume k=0.8]

Compression Check = O.K.

Check Web Crippling

h = 5.5 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 77.14 ≤ 200 CR = 0.08
N = 7.00 N/t = 98.18 ≤ 210 CN = 0.12
Ωw = 1.75 N/h = 1.273 ≤ 2.0 CN = 0.048
Pn = 1.947 k R/t = 1.50 ≤ 12.0
Pn/Ωw = 1.112 k
Long side: PuTrans = 1.106 k
Short side: PuLong = 1.018 k

$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

O.K. # clips = 1
O.K. # clips = 1

[See table C3.4.1-2, fastened to support, two flange, end loading]

Check Web Stiffener

N/A
width of stiffener = 7.000 in ts = 0.0713 14 Gauge
web of stiff. w = 6.644 in Rs = 0.1069 in
***Check w/ts ≤ 1.28√E/Fys Ωc = 1.70
w/ts = 93.178
1.28√E/Fys = 31.091 → w/ts over limit Use C3.7.2
Pn = 0.7(Pwc + AeFy) ≥ Pwc
Pwc = 1.947 k Ae = 0.474 in²
Pn = 17.942 k
Pn/Ωc = 10.554 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
Tcrnmax = 279 lbs Max{FpmaxASD/4 -OR- FhASDtrans/4 corner connections}
Vcrnmax = 483 lbs [Max Ten/2 corner connections per side]
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.1
of Bolts required for Shear = 0.4
of Bolts Used = 1.0
Check Combined Stress in Bolts & Inserts: 0.553 **O.K.** StressComb = 0.277 **O.K.**
***If combined fails: USE --> 2.0

Check 1/8" welded connection

<--- USE WELD Ω = 2.35
Assume L/t > 25: 25*t = 1.783 in Pn/Ω = 1/Ω 0.75tLFu ≥ Vreq Lreq'd = VreqΩ / 0.75tFu
Lreq'd = 0.327 in



Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$


$t_1 = 0.0713$ in (clip thickness) $F_u1 = 65$ ksi
 $t_2 = 0.1017$ in (unit base rail thickness) $F_u2 = 65$ ksi
 $d = 0.190$ in (screw diameter) $dw = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.4$

For $t_2/t_1 \leq 1.0$: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 2377$ # $P_{ns} = 3.86$ k
 For $t_2/t_1 \geq 2.5$: $P_{ns} = 2.7t_1dF_{u1}$ $P_{ns} = 2377$ # $P_{ns} = 2.38$ k
 $P_{ns} = 2.7t_2dF_{u2}$ $P_{ns} = 3.39$ k $P_{ns} = 2.7t_2dF_{u2}$ $P_{ns} = 3.39$ k

$P_{ns}/\Omega = 792$ #
 $P_{ss}/\Omega = 540$ # <- Controls
Tension: $P_{not} = 1.068$ k (screw pull-out strength) $P_{not} = 0.85t_e d F_{u2}$
 $P_{nov} = 2.607$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ts}/\Omega = 356$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	1.117	1	1.12	540 #	4	2.00 in
Short side:	1.117	1	1.12	540 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in
 min spacing = 0.57 in edge distance = 0.5 in [min. 1.5d]
 thinnest part = 0.0713 AISI BSR applies
 Check Block shear rupture: O.K. $\Omega = 2.22$ bolt/screw connection
 $F_y = 50$ ksi $An_v = 0.416$ in² $Ant = 0.082$ in²
 $Ag_v = 0.463$ in² $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ [AISI Sect. E5.3]
 $R_n/\Omega = 8.674$ k **BSR O.K.**




Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 1106 lbs
	Tens _{MAX} = 966 lbs
	Shear _{MAX} = 559 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1018 lbs
	Tens _{MAX} = 877 lbs
	Shear _{MAX} = 559 lbs

Loads at each Isolator Type: JQA

Transverse loading: (on long edge)	Comp _{MAX} = 1106.4 lbs
	Tens _{MAX} = 966.1 lbs
	Shear _{MAX} = 558.6 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1017.7 lbs
	Tens _{MAX} = 877.4 lbs
	Shear _{MAX} = 558.6 lbs

Max compression force on isolator: 1.106 k ≤ 1.660 k **O.K.**
 Max uplift on isolator: 0.966 k ≤ 1.660 k **O.K.**
 Max shear on isolator: 0.559 k ≤ 0.800 k **O.K.**



Forces on top bolt:

$d_b = 0.375$ in
 upper rail, $t = 0.1017$ in
 Tension = 0.966 k
 Shear = 0.559 k

Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ [Appendix A, Section E3.1 AISI]
 $P_n/\Omega = 6.611$ k $e = 1.0$ in **Shear O.K.**

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ [Appendix A, Section E3.2 AISI]
 $P_n/\Omega = 7.117$ k $A_n = 0.165$ in $F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ [Section E3.3.1 AISI]
 $P_n/\Omega = 2.975$ k $d/t = 3.69$ $C = 3.00$ $m_f = 1.00$ **Bearing O.K.**

Shear and tension in bolt: [Appendix A, Section E3.4 AISI]
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega t = 2.25$ [Table E3.4-1, AISI]
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega v = 2.40$ [Table E3.4-1, AISI]
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 5.06$ ksi **O.K.**
 $F'_{nt} = 32.17$ ksi $F_{nv}/\Omega = 10.00$ ksi

Combined Not Applicable




Client: ProVent PV1805
Project: CBISC-02 Iso Curb (CBISCLXL**) Base curb
Unit: ALL YORK P***B CABINETS

Curb Information

Hcurb = 25 in (Height of curb)
Lcurb = 50.5 in (Length of curb)
wcurb = 45 in (Width of curb)
WGTcurb = 239 lbs (Weight of curb)
Clips long side = 1 # Clips short side = 1

Unit Information

WGTunit = 420 lbs (Weight of Unit)
Wtmax = 141 lbs (Maximum corner weight)
Wtmin = 78 lbs (Minimum corner weight)
Hunit = 55 in (Height of unit above curb)
Hcm = 27.5 in (Height to center of mass)
Lunit = 51.25 in (Length of unit)
Wunit = 45.75 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 1117 lbs (0.7*Fpmax) FpmaxASD = 1753 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 1056 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 942 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 477 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 1040 lbs = [FpmaxASD*Hcm+2*(1+0.14SDS)*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 899 lbs = Comp_{SEISMIC}-(0.6-0.14SDS)*WGTunit
Compression_{WIND} = 576 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*wcurb-FvertASD*wcurb/2]/wcurb
Tension_{WIND} = 800 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 965 lbs = [FpmaxASD*Hcm+2*(1+0.14*SDS)*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 825 lbs = Comp_{SEISMIC}-(0.6-0.14SDS)*WGTunit
Compression_{WIND} = 444 lbs = [Fh transASD*Hcm+2*0.6*Wtmax*Lcurb-FvertASD*Lcurb/2]/Lcurb
Tension_{WIND} = 669 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = <u>1040</u> lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = <u>899</u> lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = <u>965</u> lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = <u>825</u> lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 **14 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r+t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - [t/2+at/2]
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I _x = 128.737 in ⁴ (Moment of Inertia about X-Axis)	
I _y = 0.218 in ⁴ (Moment of Inertia about Y-Axis)	
A = 2.01 in ²	
r _x = 8.00 in	
r _y = 0.329 in	
r _{min} = 0.329 in	



Axial Compression

P_u = 0.559 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 18.917 k
F_e = 19.29 ksi $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
λ_c = 1.61 $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$ If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$ λ_c = $\sqrt{\frac{F_y}{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
F_n = 16.91 ksi Lateral unbraced length
L_y = 50.50 in (assume k=0.8)
k_yL_y/r_y = 123

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 350.63 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.35	
Ω _w = 1.75	N/h = 0.28 ≤ 2.0	C _n = 0.02	
P _n = 2.105 k	R/t = 1.50 ≤ 9.0		
P _n /Ω _w = 1.203 k	O.K. # clips = 1	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$	
Long side: P _{u,trans} = 1.040 k	O.K. # clips = 1		
Short side: P _{u,long} = 0.965 k			

*****h/t > 200; use web stiffeners**

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28√E/F_y Ω_c = 1.70
w/t_s = 118.675
1.28√(E/F_y) = 31.091 → w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.380 in²
P_{wc} = 2.105 k
P_n = 14.780 k
P_n/Ω_c = 8.694 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{cnmax} = 279 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{cnmax} = 450 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.1
of Bolts required for Shear = 0.4
of Bolts Used = **1.0** ***If combined fails: USE → 4.0

Check Combined Stress in Bolts & Inserts: 0.523 **O.K.** StressComb = 0.131 **O.K.**



Check 1/8" welded connection

<--- USE WELD

$\Omega = 2.35$

Assume $L/t > 25$: $25 \cdot t = 1.783$ in
 $L_{req'd} = 0.304$ in

$$P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req} \quad L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$

Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 1106 lbs Tens _{MAX} = 966 lbs Shear _{MAX} = 559 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 1018 lbs Tens _{MAX} = 877 lbs Shear _{MAX} = 559 lbs

Loads at each Isolator Type: JQA

Transverse loading: (on long edge)	Comp _{MAX} = 1106.4 lbs Tens _{MAX} = 966.1 lbs # isolators: 1 Shear _{MAX} = 558.6 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1017.7 lbs Tens _{MAX} = 877.4 lbs # isolators: 1 Shear _{MAX} = 558.6 lbs

Max compression force on isolator: 1.106 k ≤ 1.660 k **O.K.**
Max uplift on isolator: 0.966 k ≤ 1.660 k **O.K.**
Max shear on isolator: 0.559 k ≤ 0.800 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
base curb, $t = 0.0713$ in
Tension = 0.483 k / bolt
Shear = 0.279 k / bolt

Shear on base curb: $P_n = t F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 4.635$ k $e = 1.0$ in
Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 5.909$ k $A_n = 0.107$ in
N.S.R. O.K. $F_t = (0.1 + 3d/s) F_u \leq F_u = 55.250$ ksi



Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 2.781$ k $d/t = 7.01$
Bearing O.K. $C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega_t = 2.25$
Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega_v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** *****[Table E3.4-1, AISI]*****

$$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt} \quad f_v = 1.42 \text{ ksi} \quad \text{O.K.}$$

$$F'_{nt} = 45.0 \text{ ksi} \quad F_{nv} / \Omega = 11.25 \text{ ksi}$$

Combined Not Applicable



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: $(0.6 - 0.14 S_{DS}) D + 0.7 E$

WIND: $0.6 D + W$

Transverse:	Uplift _{MAX} = 2242 lbs	Shear _{MAX} = 876 lbs
Compression _{SEISMIC} = 2462 lbs	= $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * (WGT_{unit+curb} / 2) * w_{curb}] / w_{curb}$	
Tension _{SEISMIC} = 2242 lbs	= $Comp_{SEISMIC} - (0.6 - 0.14 S_{DS}) * (WGT_{unit+curb})$	
Compression _{WIND} = 1191 lbs	= $[F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * w_{curb} - F_{vertASD} * w_{curb} / 2] / w_{curb}$	
Tension _{WIND} = 1272 lbs	= $[F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * w_{curb} + F_{vertASD} * w_{curb} / 2] / w_{curb}$	
Longitudinal:	Uplift _{MAX} = 2019 lbs	Shear _{MAX} = 876 lbs
Compression _{SEISMIC} = 2240 lbs	= $[F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14 S_{DS}) * (WGT_{unit+curb} / 2) * L_{curb}] / L_{curb}$	
Tension _{SEISMIC} = 2019 lbs	= $Comp_{SEISMIC} - (0.6 - 0.14 S_{DS}) * (WGT_{unit+curb})$	
Compression _{WIND} = 939 lbs	= $[F_{h transASD} * (H_{cm} + H_{curb}) + 0.6 * (WGT_{unit+curb} / 2) * L_{curb} - F_{vertASD} * L_{curb} / 2] / L_{curb}$	
Tension _{WIND} = 1020 lbs	= $[F_{h transASD} * (H_{cm} + H_{curb}) - 0.6 * (WGT_{unit+curb} / 2) * L_{curb} + F_{vertASD} * L_{curb} / 2] / L_{curb}$	

Wood Attachment:

1/4" ϕ wood lag screws

w/ 3.5" Min. Embed (SGmin = 0.43)

Transverse: $T_{all metal} = 946.67$ lbs
 $T_{all wood} = 671.25$ lbs
of Screws Req'd for Uplift = 3.34
of Screws Req'd for Shear = 3.91
Total # of screws required = 8

$V_{all metal} = 1043.33$ lbs
 $V_{all wood} = 224$ lbs
COMBINED LOADING: 0.907 O.K.
Req'd Min Spacing = 6.1 in o.c.

Use 8 - 1/4" ϕ wood lag screws @ 6.1 in o.c. along long side of curb w/ 3.5" Min. Embed



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
(619)727-4800
Page ___ of ___

Longitudinal:

of Screws Req'd for Uplift = 3.01 COMBINED LOADING: 0.865 O.K.
of Screws Req'd for Shear = 3.91 Screw Spacing = 5.3 in o.c.
Total # of screws required = 8

Use 8 - 1/4" ϕ wood lag screws @ 5.3 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Tall_{bolt} = 6903 lbs Vall_{bolt} = 3682 lbs
Transverse: 6903 lbs 3682 lbs
of Bolts Req'd for Uplift = 0.32 COMBINED LOADING: 0.281 O.K.
of Bolts Req'd for Shear = 0.24 Bolt Spacing = 38.5 in o.c.
Total # of bolts required = 2

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 38.5 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.29 COMBINED LOADING: 0.265 O.K.
of Bolts Req'd for Shear = 0.24 Bolt Spacing = 33.0 in o.c.
Total # of bolts required = 2

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 33 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7 Ω_o E (Ω_o = 2.5)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs Vall_{LRFD} = 3188 lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
Tall_{ASD} = Tall_{LRFD}/ α = 1026.2 lbs Vall_{ASD} = Vall_{LRFD}/ α = 1704.8 lbs ($D = 0.465, E = 0.535$)
Transverse: Uplift_{MAX} = 5310 lbs Shear_{MAX} = 2191 lbs
Compression_{SEISMIC} = 5530 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*wcurb]/wcurb
Tension_{SEISMIC} = 5310 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})
Shear_{SEISMIC} = 2191 lbs = 2.5*FpmaxASD/2
Min Bolts Req'd Uplift = 5.17 spacing = 5.30 in o.c. T_{applied} = 885.0 lbs
Min Bolts Req'd Shear = 1.29 spacing = 26.5 in o.c. V_{applied} = 365.2 lbs

Try using 6 bolts spaced at 7.70 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.08$

Use 6 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 7.7 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 4753 lbs Shear_{MAX} = 2191 lbs
Compression_{SEISMIC} = 4973 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*Lcurb]/Lcurb
Tension_{SEISMIC} = 4753 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGT_{unit+curb})
Shear_{SEISMIC} = 2191 lbs = 2.5*FpmaxASD/2
Min Bolts Req'd Uplift = 4.63 spacing = 5.25 in o.c. T_{applied} = 792.2 lbs
Min Bolts Req'd Shear = 1.29 spacing = 21 in o.c. V_{applied} = 365.2 lbs

Try using 6 bolts spaced at 6.60 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.99$

Use 6 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.6 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: (CBISCLXL** (CBISCLXL** Unit: ALL YORK P***B CABINETS			
UPPER CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: JQA		Top stud diameter: 3/8	
Anchor bolt diameter: 1/2		Anchor hole diameter: 9/16	
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" ϕ wood lag screws w/ 3.5" Min. Embed (SGmin = 0.43)	1/2" ϕ A307 Bolts to steel angle below deck	3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	8 @ 6.07 in o.c.	2 @ 38.5 in o.c.	6 @ 7.7 in o.c.
SHORT DIRECTION	8 @ 5.29 in o.c.	2 @ 33 in o.c.	6 @ 6.6 in o.c.