



MOUR GROUP
ENGINEERING + DESIGN

Structural Calculations
for
CBISC-01 Series



Prepared for:
PROVENT / RRS
3847 Wabash Drive
Mira Loma, CA 91725

Date: August 22, 2018
Project Number: PV1805




Client: ProVent PV1805
Project: CBISC-01 Iso Curb [CBISCLXS**] Upper curb rail
Unit: ALL YORK P***A CABINETS

Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	46.5 in	(Length of curb)
wcurb =	31 in	(Width of curb)
WGTcurb =	210 lbs	(Weight of curb)
# Clips long side =	1	# Clips short side = 1

Unit Information

WGTunit =	367 lbs	(Weight of Unit)
Wtmax =	120 lbs	(Maximum corner weight)
Wtmin =	71 lbs	(Minimum corner weight)
Hunit =	49 in	(Height of unit above curb)
Hcm =	24.5 in	(Height to center of mass)
Lunit =	51.25 in	(Length of unit)
Wunit =	35.75 in	(Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss =	2.850	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-10)
Sms =	2.850	(Fa*Ss)
Sds =	1.900	(2/3*Sms)
Ip =	1.25	(Importance Factor Category III Building)
Fpmax =	3.800 Wp	(1.6*Sds*Ip)*Wp
FpmaxASD =	976 lbs	(0.7*Fpmax)
	(unit only)	FpmaxASD = 1535 lbs
		(unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-10)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) =	1.9	(Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) =	1.5	(Refer Sect 29.5.1 ASCE 7-10)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² [Eq. 29.3-1 ASCE 7-10]
Fh ASD trans =	719 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) [Eq. 29.5-2]
Fh ASD long =	502 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
Fvert ASD =	372 lbs	= 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:		
Compression _{SEISMIC} =	1075 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	953 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	526 lbs	= [Fh trans ASD * Hcm + 2*0.6*Wtmax*wcurb - Fvert ASD * wcurb/2]/wcurb
Tension _{WIND} =	678 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:		
Compression _{SEISMIC} =	818 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	696 lbs	= Comp _{SEISMIC} - (0.6-0.14S _{DS})*WGTunit
Compression _{WIND} =	222 lbs	= [Fh trans ASD * Hcm + 2*0.6*Wtmax*Lcurb - Fvert ASD * Lcurb/2]/Lcurb
Tension _{WIND} =	374 lbs	= Comp _{WIND} + Fvert - 0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 1075 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 953 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 818 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 696 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 [14 Gauge]
E = 29500 ksi

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - (2r+t)
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.000 in [0 if no lips]	b = 1.322 in = B' - [r+t/2 + a(r+t/2)]
o = 0.000 [0 - no Lip; 1 w/ lip]	b' = 1.464 in = B' - [t/2 + at/2]
R = 0.1069 [Inside bend radius]	c = 0.000 in = a[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = a[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.261 in [Distance between centroid and web centerline]	
I _x = 2.424 in ⁴ [Moment of Inertia about X-Axis]	
I _y = 0.109 in ⁴ [Moment of Inertia about Y-Axis]	
A = 0.59 in ²	
r _x = 2.03 in	
r _y = 0.432 in	
r _{min} = 0.432 in	



Axial Compression

P _u = 0.488 k	(Max Axial Comp)	Ω _c = 1.80
P _n /Ω _c = 9.561 k		
F _e = 39.18 ksi		
λ _c = 1.13		
F _n = 29.31 ksi		
L _y = 46.50 in		
k _y L _y /r _y = 86		

Lateral unbraced length (assume k=0.8)

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c \leq 1.5; F_n = (0.658^{\lambda_c^2}) F_y$$

$$\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c} \quad \text{If } \lambda_c > 1.5; F_n = \frac{0.877}{\lambda_c^2} F_y$$

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

Compression Check = O.K.

Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	} (See table C3.4.1-2, fastened to support, two flange, end loading)
t = 0.0713 in	h/t = 77.14 ≤ 200	C _R = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.12	
Q _w = 1.75	N/h = 1.273 ≤ 2.0	C _n = 0.048	
P _n = 1.947 k	R/t = 1.50 ≤ 12.0		

Long side: P_u / P_n = 1.075 k

Short side: P_u / P_n = 0.818 k

$$P_n = C t^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_n \sqrt{\frac{h}{t}} \right)$$

O.K. # clips = 1

O.K. # clips = 1

Check Web Stiffener

N/A

width of stiffener = 7.000 in t_s = 0.0566 [16 Gauge]

web of stiff. w = 6.717 in R_s = 0.0849 in

***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70

w/ts = 118.675

1.28√E/F_y = 31.091 → w/ts over limit Use C3.7.2

P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}

P_{wc} = 1.947 k A_e = 0.380 in²

P_n = 14.669 k

P_n/Ω_c = 8.629 k

Not Req'd

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crn}max = 244 lbs Max[F_{prmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections]

V_{crn}max = 476 lbs [Max Ten/2 corner connections per side]

Bolt: Tall = 2480 lbs Vall = 1096 lbs

Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs

of Bolts required for Tension = 0.1

of Bolts required for Shear = 0.4

of Bolts Used = 1.0

***If combined fails: USE → 2.0

Check Combined Stress in Bolts & Inserts: 0.533 **O.K.** StressComb = 0.267 **O.K.**

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in P_n/Ω = 1/Ω * 0.75tL F_u ≥ V_{req} L_{req'd} = V_{req}Ω / 0.75tF_u

L_{req'd} = 0.322 in



Connection Unit to Curb Clip #10 SMS screw $\Omega = 3.0$

$t_1 = 0.0713$ in (clip thickness) $F_{u1} = 65$ ksi
 $t_2 = 0.1017$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $dw = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.4$


For $t_2/t_1 \leq 1.0$: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 2377$ #
 For $t_2/t_1 \geq 2.5$: $P_{ns} = 2.7t_1dF_{u1}$ $P_{ns} = 2377$ #
 $P_{ns} = 2.7t_2dF_{u2}$ $P_{ns} = 2.7t_2dF_{u2}$ 3.39 k

$P_{ns}/\Omega = 792$ #
 $P_{ss}/\Omega = 540$ # <- Controls
Tension: $P_{not} = 1.068$ k (screw pull-out strength) $P_{not} = 0.85t_c d F_{u2}$
 $P_{nov} = 2.607$ k (screw pull-over strength) $t_c = \min(t_1, t_2)$
 $P_{ts}/\Omega = 356$ # <- Controls $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	0.976	1	0.98	540 #	4	2.00 in
Short side:	0.976	1	0.98	540 #	4	2.00 in

clip width (in) = 7.00
 min spacing = 0.57 in
 clip height = 2.5 in
 edge distance = 0.5 in (min. 1.5d)
 thinnest part = 0.0713 in AISI BSR applies
 $\Omega = 2.22$ bolt/screw connection
 $Anv = 0.416$ in² $Ant = 0.082$ in²
 $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ [AISI Sect. E5.3]

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $Agv = 0.463$ in²
 $Rn/\Omega = 8.674$ k
BSR O.K.




Curb Loads (copied from above)

Transverse: (on long edge)	Comp _{MAX} = 1075 lbs
	Tens _{MAX} = 953 lbs
	Shear _{MAX} = 488 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 818 lbs
	Tens _{MAX} = 696 lbs
	Shear _{MAX} = 488 lbs

Loads at each Isolator Type: JOA

Transverse loading: (on long edge)	# isolators: 1	Comp _{MAX} = 1075.4 lbs
		Tens _{MAX} = 952.8 lbs
		Shear _{MAX} = 488.1 lbs
Longitudinal loading: (on short edge)	# isolators: 1	Comp _{MAX} = 818.2 lbs
		Tens _{MAX} = 695.6 lbs
		Shear _{MAX} = 488.1 lbs

Max compression force on isolator: 1.075 k ≤ 1.660 k **O.K.**
 Max uplift on isolator: 0.953 k ≤ 1.660 k **O.K.**
 Max shear on isolator: 0.488 k ≤ 0.800 k **O.K.**



Forces on top bolt:

$d_b = 0.375$ in
 upper rail, $t = 0.1017$ in
 Tension = 0.953 k
 Shear = 0.488 k

Shear on curb rail:

$P_n = teF_u$ $\Omega = 2.00$ [Appendix A, Section E3.1 AISI]
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture:

$P_n = A_n F_t$ $\Omega = 2.22$ [Appendix A, Section E3.2 AISI]
 $P_n/\Omega = 7.117$ k $A_n = 0.165$ in

N.S.R. O.K.

Bolt Bearing Strength:

$P_n = C m_f d t F_u$ $\Omega = 2.50$ [Section E3.3.1 AISI]
 $P_n/\Omega = 2.975$ k $d/t = 3.69$
 $C = 3.00$ $m_f = 1.00$

Bearing O.K.

Shear and tension in bolt:

[Appendix A, Section E3.4 AISI]

Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega_t = 2.25$ [Table E3.4-1, AISI]
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 24.0$ ksi $\Omega_v = 2.40$ [Table E3.4-1, AISI]
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 4.42$ ksi **O.K.**
Combined Not Applicable $F'_{nt} = 34.75$ ksi $F_{nv}/\Omega = 10.00$ ksi




Client: ProVent PV1805
Project: CBISC-01 Iso Curb (CBISCLXS**) Base curb
Unit: ALL YORK P***A CABINETS

Curb Information

Hcurb = 25 in (Height of curb)
Lcurb = 50.5 in (Length of curb)
wcurb = 35 in (Width of curb)
WGTcurb = 210 lbs (Weight of curb)
Clips long side = 1 # Clips short side = 1

Unit Information

WGUnit = 367 lbs (Weight of Unit)
Wtmax = 120 lbs (Maximum corner weight)
Wtmin = 71 lbs (Minimum corner weight)
Hunit = 49 in (Height of unit above curb)
Hcm = 24.5 in (Height to center of mass)
Lunit = 51.25 in (Length of unit)
Wunit = 35.75 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 976 lbs (0.7*Fpmax) FpmaxASD = 1535 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 976 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 681 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 372 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 987 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 865 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGUnit
Compression_{WIND} = 641 lbs = [Fh trans ASD *Hcm+2*0.6*Wtmax*wcurb-Fvert ASD *wcurb/2]/wcurb
Tension_{WIND} = 793 lbs = Comp_{WIND}+Fvert-0.6*WGUnit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 777 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 655 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGUnit
Compression_{WIND} = 288 lbs = [Fh trans ASD *Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD *Lcurb/2]/Lcurb
Tension_{WIND} = 440 lbs = Comp_{WIND}+Fvert-0.6*WGUnit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse: (on long edge)	Comp _{MAX} = <u>987</u> lbs	---> Along long edge of curb.
	Tens _{MAX} = <u>865</u> lbs	---> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} = <u>777</u> lbs	---> Along short edge of curb.
	Tens _{MAX} = <u>655</u> lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 **14 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r + t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r + t/2 + a(r + t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.714 in = B' - (t/2 + αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r + t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R + t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I _x = 128.737 in (Moment of Inertia about X-Axis)	
I _y = 0.218 in (Moment of Inertia about Y-Axis)	
A = 2.01 in ²	
r _x = 8.00 in	
r _y = 0.329 in	
r _{min} = 0.329 in	



Axial Compression

P_u = 0.488 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 8.960 k
F_e = 9.14 ksi $\lambda_c = \frac{\sqrt{F_y}}{\sqrt{F_e}}$ F_e = $\frac{\pi^2 E}{(kl/r)^2}$
λ_c = 2.34 If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 8.01 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 73.38 in Lateral unbraced length
k_yL_y/r_y = 179 [assume k=0.8]

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} [See table C3.4.1-2, fastened to support, one flange, end loading]
t = 0.0713 in	h/t = 350.63 ≤ 200	C _R = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C _M = 0.35	
Ω _w = 1.75	N/h = 0.28 ≤ 2.0	C _h = 0.02	
P _n = 2.105 k	R/t = 1.50 ≤ 9.0		

P_n = C t² F_y sin(90) (1 - C_R √(R/t)) (1 + C_M √(N/t)) (1 - C_h √(h/t))

Long side: P_{uTrans} = 0.987 k **O.K.** # clips = 1
Short side: P_{uLong} = 0.777 k **O.K.** # clips = 1

***h/t > 200; use web stiffeners

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in t_s = 0.0713 **14 Gauge**
web of stiff. w = 6.644 in R_s = 0.1069 in
***Check w/ts ≤ 1.28√E/F_y Ω_c = 1.70
w/ts = 93.178
1.28√(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc} A_e = 0.474 in²
P_{wc} = 2.105 k
P_n = 18.052 k
P_n/Ω_c = 10.619 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T_{crnmax} = 244 lbs Max(F_{pmaxASD}/4 -OR- F_{HASDtrans}/4 corner connections)
V_{crnmax} = 432 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs

of Bolts required for Tension = 0.1
of Bolts required for Shear = 0.4
of Bolts Used = 1.0

***If combined fails:
USE --> 4.0

Check Combined Stress in Bolts & Inserts: 0.493 **O.K.** StressComb = 0.123 **O.K.**



Check 1/8" welded connection

<--- USE WELD

$\Omega = 2.35$

Assume $L/t > 25$: $25 \cdot t = 1.783$ in
Req'd = 0.292 in

$$P_n / \Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$$

$$L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$$

Curb Loads [copied from upper rail calcs]

Transverse: (on long edge)	Comp _{MAX} = 1075 lbs
	Tens _{MAX} = 953 lbs
	Shear _{MAX} = 488 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 818 lbs
	Tens _{MAX} = 696 lbs
	Shear _{MAX} = 488 lbs


Loads at each Isolator Type: **JOA**

Transverse loading: (on long edge)	Comp _{MAX} = 1075.4 lbs
	Tens _{MAX} = 952.8 lbs
	Shear _{MAX} = 488.1 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 818.2 lbs
	Tens _{MAX} = 695.6 lbs
	Shear _{MAX} = 488.1 lbs

Max compression force on isolator: 1.075 k \leq 1.660 k **O.K.**
Max uplift on isolator: 0.953 k \leq 1.660 k **O.K.**
Max shear on isolator: 0.488 k \leq 0.800 k **O.K.**

Forces on bottom bolts:

$d_b = 0.5$ in
base curb, $t = 0.0713$ in
Tension = 0.476 k / bolt
Shear = 0.244 k / bolt



Shear on base curb:

$P_n = t e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n / \Omega = 4.635$ k $e = 1.0$ in
Shear O.K.

Net section rupture:


$P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n / \Omega = 5.909$ k $A_n = 0.107$ in
N.S.R. O.K.

Bolt Bearing Strength:

$P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n / \Omega = 2.781$ k $d/t = 7.01$
Bearing O.K.

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)
Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt} / \Omega = 3.927$ k **Bolt tension O.K.** $\Omega_t = 2.25$
Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega_v = 2.40$
 $P_{nv} / \Omega = 2.209$ k **Bolt shear O.K.** ***** (Table E3.4-1, AISI) *****
 $F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 1.24$ ksi
Combined Not Applicable $F'_{nt} = 45.0$ ksi $F_{nv} / \Omega = 11.25$ ksi



Connection of Curb to Supporting Structure

Roof Loading

SEISMIC: (0.6-0.14SDSID) + 0.7E

WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 2343 lbs	Shear _{MAX} = 767 lbs
Compression _{SEISMIC} =	2536 lbs	= [FpmaxASD * (Hcm + Hcurb) + (1 + 0.14SDS) * (WGT _{unit+curb} / 2) * wcurb] / wcurb
Tension _{SEISMIC} =	2343 lbs	= Comp _{SEISMIC} - (0.6 - 0.14SDS) * (WGT _{unit+curb})
Compression _{WIND} =	1368 lbs	= [F _{h transASD} * (Hcm + Hcurb) + 0.6 * (WGT _{unit+curb} / 2) * wcurb - F _{vertASD} * wcurb / 2] / wcurb
Tension _{WIND} =	1394 lbs	= [F _{h transASD} * (Hcm + Hcurb) - 0.6 * (WGT _{unit+curb} / 2) * wcurb + F _{vertASD} * wcurb / 2] / wcurb
Longitudinal:	Uplift _{MAX} = 1677 lbs	Shear _{MAX} = 767 lbs
Compression _{SEISMIC} =	1870 lbs	= [FpmaxASD * (Hcm + Hcurb) + (1 + 0.14SDS) * (WGT _{unit+curb} / 2) * Lcurb] / Lcurb
Tension _{SEISMIC} =	1677 lbs	= Comp _{SEISMIC} - (0.6 - 0.14SDS) * (WGT _{unit+curb})
Compression _{WIND} =	654 lbs	= [F _{h transASD} * (Hcm + Hcurb) + 0.6 * (WGT _{unit+curb} / 2) * Lcurb - F _{vertASD} * Lcurb / 2] / Lcurb
Tension _{WIND} =	681 lbs	= [F _{h transASD} * (Hcm + Hcurb) - 0.6 * (WGT _{unit+curb} / 2) * Lcurb + F _{vertASD} * Lcurb / 2] / Lcurb

Wood Attachment:

1/4" ϕ wood lag screws

w/ 3.5" Min. Embed (SGmin = 0.43)

Transverse:	Tall _{metal} = 946.67 lbs	Tall _{wood} = 671.25 lbs	Vall _{metal} = 1043.33 lbs	Vall _{wood} = 224 lbs
# of Screws Req'd for Uplift =	3.49		COMBINED LOADING: 0.865 O.K.	
# of Screws Req'd for Shear =	3.43		Req'd Min Spacing = 6.1 in o.c.	
Total # of screws required =	8			

Use 8 - 1/4" ϕ wood lag screws @ 6.1 in o.c. along long side of curb w/ 3.5" Min. Embed



Longitudinal:

of Screws Req'd for Uplift = 2.50 COMBINED LOADING: 0.846 O.K.
 # of Screws Req'd for Shear = 3.43 Screw Spacing = 4.5 in o.c.
 Total # of screws required = 7

Use 7 - 1/4" ϕ wood lag screws @ 4.5 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Tall_{bol} = 6903 lbs Vall_{bol} = 3682 lbs
 Transverse: 6903 lbs 3682 lbs
 # of Bolts Req'd for Uplift = 0.34 COMBINED LOADING: 0.274 O.K.
 # of Bolts Req'd for Shear = 0.21 Bolt Spacing = 38.5 in o.c.
 Total # of bolts required = 2

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 38.5 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.24 COMBINED LOADING: 0.226 O.K.
 # of Bolts Req'd for Shear = 0.21 Bolt Spacing = 23.0 in o.c.
 Total # of bolts required = 2

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 23 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7 Ω_o E (Ω_o = 2.5)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall_{LRFD} = 1919 lbs Vall_{LRFD} = 3188 lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
 Tall_{ASD} = Tall_{LRFD}/ α = 1026.2 lbs Vall_{ASD} = Vall_{LRFD}/ α = 1704.8 lbs (D = 0.465, E = 0.535)
 Transverse: Uplift_{MAX} = 5599 lbs Shear_{MAX} = 1919 lbs
 Compression_{SEISMIC} = 5792 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*wcurb]/wcurb
 Tension_{SEISMIC} = 5599 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGTunit+curb)
 Shear_{SEISMIC} = 1919 lbs = 2.5*FpmaxASD/2
 Min Bolts Req'd Uplift = 5.46 spacing = 5.30 in o.c. T_{applied} = 799.9 lbs
 Min Bolts Req'd Shear = 1.13 spacing = 26.5 in o.c. V_{applied} = 274.1 lbs

Try using 7 bolts spaced at 6.42 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.94$

Use 7 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 6.4 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 3934 lbs Shear_{MAX} = 1919 lbs

Compression_{SEISMIC} = 4126 lbs = [2.5*FpmaxASD*(Hcm+Hcurb)+(1+0.14SDS)*(WGT_{unit+curb}/2)*Lcurb]/Lcurb
 Tension_{SEISMIC} = 3934 lbs = Comp_{SEISMIC} - (0.6-0.14SDS)*(WGTunit+curb)
 Shear_{SEISMIC} = 1919 lbs = 2.5*FpmaxASD/2
 Min Bolts Req'd Uplift = 3.83 spacing = 3.66667 in o.c. T_{applied} = 786.7 lbs
 Min Bolts Req'd Shear = 1.13 spacing = 11 in o.c. V_{applied} = 383.7 lbs

Try using 5 bolts spaced at 5.75 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 0.99$

Use 5 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 5.8 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: (CBISCLXS* (CBISCLXS** Unit: ALL YORK P***A CABINETS			
UPPER CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
# OF CLIPS (SHORT SIDE) - 1 clips with 4 - #10 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED			
VIBRATION ISOLATOR TYPE: JQA Top stud diameter: 3/8			
Anchor bolt diameter: 1/2 Anchor hole diameter: 9/16			
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" ϕ wood lag screws w/ 3.5" Min. Embed (SGmin = 0.43)	1/2" ϕ A307 Bolts to steel angle below deck	3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	8 @ 6.07 in o.c.	2 @ 38.5 in o.c.	7 @ 6.42 in o.c.
SHORT DIRECTION	7 @ 4.5 in o.c.	2 @ 23 in o.c.	5 @ 5.75 in o.c.