



MOUR GROUP
ENGINEERING + DESIGN

Structural Calculations
for
CBISC-04 Series



Prepared for:

PROVENT / RRS

3847 Wabash Drive
Mira Loma, CA 91725

Date: August 22, 2018

Project Number: PV1805




Client: ProVent PV1805
Project: CBISC-04 Iso Curb [CBISCPD3715**] Upper curb rail
Unit: ZT,ZR,ZJ 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150

Curb Information

Hcurb upper =	5.5 in	(Height of upper curb rail)
Lcurb =	80.375 in	(Length of curb)
wcurb =	50.5 in	(Width of curb)
WGTcurb =	370 lbs	(Weight of curb)
# Clips long side =	2	# Clips short side = 2

Unit Information

WGUnit =	1700 lbs	(Weight of Unit)
Wtmax =	329 lbs	(Maximum corner weight)
Wtmin =	191 lbs	(Minimum corner weight)
Hunit =	50.75 in	(Height of unit above curb)
Hcm =	25.375 in	(Height to center of mass)
Lunit =	89 in	(Length of unit)
Wunit =	59 in	(Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss =	2.850	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-10)
Sms =	2.850	[Fa*Ss]
Sds =	1.900	[2/3*Sms]
Ip =	1.25	(Importance Factor Category III Building)
Fpmax =	3.800 Wp	[1.6*Sds*Ip]*Wp
FpmaxASD =	4522 lbs	[0.7*Fpmax]
	(unit only)	FpmaxASD = 5506 lbs
		(unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz =	1.13	[For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10]
Kzt =	1.0	[No topographic effects assumed for rooftop mounted units]
Kd =	0.85	[Directionality factor Table 26.6-1 ASCE 7-10]
V =	115	[Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C]
GCr(horiz) =	1.9	[Refer Sect 29.5.1 ASCE 7-10]
GCr(vert) =	1.5	[Refer Sect 29.5.1 ASCE 7-10]
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V ² [Eq. 29.3-1 ASCE 7-10]
Fh ASD trans =	1289 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) [Eq. 29.5-2]
Fh ASD long =	854 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
Fvert ASD =	1067 lbs	= 0.6*qz*GCr*Lunit*Wunit [Eq. 29.5-3]

Curb Loading

Transverse:

Compression _{SEISMIC} =	3105 lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	2537 lbs	= Comp _{SEISMIC} -[0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	509 lbs	= [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension _{WIND} =	556 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	2261 lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	1693 lbs	= Comp _{SEISMIC} -[0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	131 lbs	= [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension _{WIND} =	178 lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse: (on long edge)	Comp _{MAX} =	3105 lbs	----> Along long edge of curb.
	Tens _{MAX} =	2537 lbs	----> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} =	2261 lbs	----> Along short edge of curb.
	Tens _{MAX} =	1693 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 14 Gauge
E = 29500 ksi

Calculate Section Properties of Curb

A' = 5.500 in	a = 5.144 in = A' - [2r+t]
B' = 1.500 in	a' = 5.429 in = A' - t
C' = 0.000 in [0 if no lips]	b = 1.322 in = B' - [r+t/2 + a[r+t/2]]
α = 0.000 [0 - no Lip; 1 w/ lip]	b' = 1.464 in = B' - [t/2 + αt/2]
R = 0.1069 [Inside bend radius]	c = 0.000 in = α[C' - [r+t/2]]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.261 in [Distance between centroid and web centerline]	
I _x = 2.424 in ⁴ [Moment of Inertia about X-Axis]	
I _y = 0.109 in ⁴ [Moment of Inertia about Y-Axis]	
A = 0.59 in ²	
r _x = 2.03 in	
r _y = 0.432 in	
r _{min} = 0.432 in	



Axial Compression

P _u = 2.261 k	[Max Axial Comp]	Ω _c = 1.80
P _n /Ω _c = 4.894 k		
F _e = 17.11 ksi		
λ _c = 1.71		
F _n = 15.00 ksi		
L _y = 70.38 in		
k _y L _y /r _y = 130		

Lateral unbraced length [assume k=0.8]

$$\lambda_c = \frac{F_y}{F_e} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

$$F_n = \begin{cases} (0.658^{\lambda_c^2}) F_y & \text{if } \lambda_c \leq 1.5 \\ \frac{0.877}{\lambda_c^2} F_y & \text{if } \lambda_c > 1.5 \end{cases}$$

Compression Check = O.K.

Check Web Crippling

h = 5.5 in	-- Check limits:	C = 7.50	[See table C3.4.1-2, fastened to support, two flange, end loading]
t = 0.0713 in	h/t = 77.14 ≤ 200	C _R = 0.08	
N = 7.00	N/t = 98.18 ≤ 210	C _N = 0.12	
Ω _w = 1.75	N/h = 1.273 ≤ 2.0	C _h = 0.048	
P _n = 1.947 k	R/t = 1.50 ≤ 12.0		

Long side: P_utrans = 1.553 k **web stiffener REQ'D** # clips = 2
Short side: P_uLong = 1.130 k **web stiffener REQ'D** # clips = 2

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

Check Web Stiffener

16Ga x 3/4in x 7in [C-channel]

width of stiffener = 7.000 in	t _s = 0.0566 16 Gauge
web of stiff. w = 6.717 in	R _s = 0.0849 in
***Check w/t _s ≤ 1.28vE/F _y	Ω _c = 1.70
w/t _s = 118.675	
1.28v(E/F _y) = 31.091	--> w/t _s over limit Use C3.7.2
P _n = 0.7(P _{wc} + A _e F _y) ≥ P _{wc}	
P _{wc} = 1.947 k	A _e = 0.380 in ²
P _n = 14.669 k	
P _n /Ω _c = 8.629 k	O.K.

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T _{crnmax} = 1131 lbs	Max[F _{pmaxASD} /4 -OR- F _{hASDtrans} /4 corner connections]
V _{crnmax} = 1269 lbs	[Max Ten/2 corner connections per side]
Bolt: Tall = 2480 lbs	Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs	Vall = 1714 lbs
# of Bolts required for Tension = 0.5	
# of Bolts required for Shear = 1.2	
# of Bolts Used = 2.0	
Check Combined Stress in Bolts & Inserts: 0.807 O.K.	StressComb = 0.538 O.K.

***If combined fails: USE --> 3.0

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 1.783 in P_n/Ω = 1/Ω * 0.75tL_f ≥ V_{req} L_{req'd} = V_{req}Ω / 0.75tF_u
L_{req'd} = 0.858 in



Connection Unit to Curb Clip #12 SMS screw $\Omega = 3.0$

$t_1 = 0.0713$ in (clip thickness) $F_{u1} = 65$ ksi
 $t_2 = 0.0713$ in (unit base rail thickness) $F_{u2} = 65$ ksi
 $d = 0.216$ in (screw diameter) $d_w = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.0$


For $t_2/t_1 \leq 1.0$: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ $P_{ns} = 2416$ # **For $t_2/t_1 \geq 2.5$:** $P_{ns} = 2703$ #
Shear: $P_{ns} = 2.7t_1dF_{u1}$ 2.70 k $P_{ns} = 2.7t_2dF_{u1}$ 2.70 k
 $P_{ns} = 2.7t_2dF_{u2}$ 2.70 k $P_{ns} = 2.7t_1dF_{u2}$ 2.70 k
 $P_{ns}/\Omega = 805$ # <- Controls
 $P_{ss}/\Omega = 840$ #

Tension: $P_{not} = 0.851$ k (screw pull-out strength) $t_c = \min(t_1, t_2)$
 $P_{nov} = 2.607$ k (screw pull-over strength) $P_{nov} = 1.5t_1d_wF_{u1}$
 $P_{ts}/\Omega = 284$ # <- Controls
 $P_{ts}/\Omega = 845$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (lb)	# screws	spacing
Long side:	4.522	2	2.26	805 #	4	2.00 in
Short side:	4.522	2	2.26	805 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in
 min spacing = 0.65 in edge distance = 0.5 in (min. 1.5d)
 thinnest part = 0.0713 AISI BSR applies
 $\Omega = 2.22$ bolt/screw connection
 $A_{nv} = 0.410$ in² $A_{nt} = 0.081$ in²
 $R_n = 0.6F_yA_{gv} + F_uA_{nt} \leq 0.6F_uA_{nv} + F_uA_{nt}$ [AISI Sect. E5.3]

Check Block shear rupture: O.K.
 $F_y = 50$ ksi
 $A_{gv} = 0.463$ in²
 $R_n/\Omega = 8.647$ k



Curb Loads [copied from above]

Transverse: (on long edge)	Comp _{MAX} = 3105 lbs
	Tens _{MAX} = 2537 lbs
	Shear _{MAX} = 2261 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2261 lbs
	Tens _{MAX} = 1693 lbs
	Shear _{MAX} = 2261 lbs


Loads at each Isolator Type: JQA

Transverse loading: (on long edge)	Comp _{MAX} = 1552.6 lbs
	Tens _{MAX} = 1268.7 lbs
	Shear _{MAX} = 565.3 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1130.3 lbs
	Tens _{MAX} = 846.4 lbs
	Shear _{MAX} = 565.3 lbs

Max compression force on isolator: 1.553 k < 1.660 k **O.K.**
 Max uplift on isolator: 1.269 k < 1.660 k **O.K.**
 Max shear on isolator: 0.565 k < 0.800 k **O.K.**

Forces on top bolt:

$d_b = 0.375$ in
 upper rail, $t = 0.0713$ in
 Tension = 1.269 k
 Shear = 0.565 k



Shear on curb rail: $P_n = teF_u$ $\Omega = 2.00$ [Appendix A, Section E3.1 AISI]
 $P_n/\Omega = 4.635$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_nF_t$ $\Omega = 2.22$ [Appendix A, Section E3.2 AISI]
 $P_n/\Omega = 4.989$ k $A_n = 0.116$ in

N.S.R. O.K.

Bolt Bearing Strength: $P_n = Cm_ydtF_u$ $\Omega = 2.50$ [Section E3.3.1 AISI]
 $P_n/\Omega = 2.086$ k $d/t = 5.26$
 $C = 3.00$ $mf = 1.00$

Bearing O.K.

Shear and tension in bolt: [Appendix A, Section E3.4 AISI]

Tension $P_{nt} = A_bF_{nt}$ $F_{nt} = 40.5$ ksi $A_b = 0.1104$ in²
 $P_{nt}/\Omega = 1.988$ k **Bolt tension O.K.** $\Omega_t = 2.25$ [Table E3.4-1, AISI]
 Shear $P_{nv} = A_bF_{nv}$ $F_{nv} = 24.0$ ksi $\Omega_v = 2.40$ [Table E3.4-1, AISI]
 $P_{nv}/\Omega = 1.104$ k **Bolt shear O.K.**

Combined Not Applicable
 $F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 5.12$ ksi **O.K.**
 $F'_{nt} = 31.92$ ksi $F_{nv}/\Omega = 10.00$ ksi



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120
6191727-4800
Page ___ of ___


Client: ProVent PV1805
Project: CBISC-04 Iso Curb (CBISCPRD3715**) Base curb
Unit: ZT,ZR,ZJ 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150

Curb Information

Hcurb = 25 in (Height of curb)
Lcurb = 83.375 in (Length of curb)
wcurb = 53.5 in (Width of curb)
WGTcurb = 370 lbs (Weight of curb)
Clips long side = 2 # Clips short side = 2

Unit Information

WGTunit = 1700 lbs (Weight of Unit)
Wtmax = 329 lbs (Maximum corner weight)
Wtmin = 191 lbs (Minimum corner weight)
Hunit = 50.75 in (Height of unit above curb)
Hcm = 25.375 in (Height to center of mass)
Lunit = 89 in (Length of unit)
Wunit = 59 in (Width of unit)



Seismic Loading - 2015 IBC/2016 CBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 4522 lbs (0.7*Fpmax) FpmaxASD = 5506 lbs (unit and curb)

Wind Loading - 2015 IBC/2016 CBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.85 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) = 1.9 (Refer Sect 29.5.1 ASCE 7-10)
GCr(vert) = 1.5 (Refer Sect 29.5.1 ASCE 7-10)
qz = 32.5 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
Fh ASD trans = 1736 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long = 1151 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD = 1067 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 2978 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2410 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 684 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*wcurb-Fvert ASD*wcurb/2]/wcurb
Tension_{WIND} = 732 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2209 lbs = [FpmaxASD*Hcm+2*(1+0.14*S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 1641 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 211 lbs = [Fh trans ASD*Hcm+2*0.6*Wtmax*Lcurb-Fvert ASD*Lcurb/2]/Lcurb
Tension_{WIND} = 259 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse:	Comp _{MAX} = 2978 lbs	---> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2410 lbs	---> Along long edge of curb.
Longitudinal:	Comp _{MAX} = 2209 lbs	---> Along short edge of curb.
(on short edge)	Tens _{MAX} = 1641 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 **14 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

A' = 25.000 in	a = 24.644 in = A' - (2r+t)
B' = 1.750 in	a' = 24.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.572 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 [0 - no Lip; 1 w/ lip]	b' = 1.714 in = B' - [t/2+αt/2]
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.104 in (Distance between centroid and web centerline)	
I _x = 128.737 in (Moment of Inertia about X-Axis)	
I _y = 0.218 in (Moment of Inertia about Y-Axis)	
A = 2.01 in ²	
r _x = 8.00 in	
r _y = 0.329 in	
r _{min} = 0.329 in	



Axial Compression

P_u = 2.261 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 8.960 k
F_e = 9.14 ksi $\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$
λ_c = 2.34 If λ_c ≤ 1.5; F_n = (0.658λ_c²) F_y
F_n = 8.01 ksi If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$
L_y = 73.38 in Lateral unbraced length
k_yL_y/r_y = 179 (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 25 in -- Check limits: C = 4.00
t = 0.0713 in h/t = 350.63 ≤ 200 C_R = 0.14
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.35
Ω_w = 1.75 N/h = 0.28 ≤ 2.0 C_n = 0.02
P_n = 2.105 k R/t = 1.50 ≤ 9.0
P_n/Ω_w = 1.203 k
Long side: P_{uTrans} = 1.489 k **web stiffener REQ'D** # clips = 2
Short side: P_{uLong} = 1.105 k **O.K.** # clips = 2

*****h/t > 200; use web stiffeners**

$$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$$

(See table C3.4.1-2, fastened to support, one flange, end loading)

Check Web Stiffener

16Ga x 1.5in x 7in (C-channel)
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/t_s ≤ 1.28V_e/F_{ys} Ω_c = 1.70
w/t_s = 118.675
1.28V_e/F_{ys} = 31.091 --> w/t_s over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 2.105 k A_e = 0.380 in²
P_n = 14.780 k
P_n/Ω_c = 8.694 k **O.K.**

Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts
T_{crnmax} = 1131 lbs Max(F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections)
V_{crnmax} = 1205 lbs (Max Ten/2 corner connections per side)
Bolt: Tall = 2480 lbs Vall = 1096 lbs
Threaded Insert: Tall = 2860 lbs Vall = 1714 lbs
of Bolts required for Tension = 0.5
of Bolts required for Shear = 1.1
of Bolts Used = 2.0 ***If combined fails: USE --> 4.0
Check Combined Stress in Bolts & Inserts: 0.778 **O.K.** StressComb = 0.389 **O.K.**



Check 1/8" welded connection

Assume L/t > 25: 25*t = 1.783 in $P_n/\Omega = \frac{1}{\Omega} 0.75 t L F_u \geq V_{req}$ $\Omega = 2.35$
 Lreq'd = 0.815 in $L_{req'd} = \frac{V_{req} \Omega}{0.75 t F_u}$

Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} = 3105 lbs Tens _{MAX} = 2537 lbs Shear _{MAX} = 2261 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2261 lbs Tens _{MAX} = 1693 lbs Shear _{MAX} = 2261 lbs

Loads at each Isolator Type: **IOBX**

Transverse loading: (on long edge)	Comp _{MAX} = 1552.6 lbs Tens _{MAX} = 1268.7 lbs # isolators: 2 Shear _{MAX} = 565.3 lbs
Longitudinal loading: (on short edge)	Comp _{MAX} = 1130.3 lbs Tens _{MAX} = 846.4 lbs # isolators: 2 Shear _{MAX} = 565.3 lbs

Max compression force on isolator: 1.553 k ≤ 2.000 k **O.K.**
 Max uplift on isolator: 1.269 k ≤ 2.000 k **O.K.**
 Max shear on isolator: 0.565 k ≤ 1.500 k **O.K.**

Forces on bottom bolts:

$d_b = 0.625$ in
 base curb, t = 0.0713 in
 Tension = 0.634 k / bolt
 Shear = 0.283 k / bolt

Shear on base curb: $P_n = t e F_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 4.635$ k e = 1.0 in
Shear O.K.



Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 6.372$ k $A_n = 0.098$ in
 $F_t = (0.1 + 3d/s) F_u \leq F_u = 65.000$ ksi
N.S.R. O.K.

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 3.476$ k d/t = 8.77
 C = 3.00 m_f = 1.00
Bearing O.K.

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)
 Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.3068$ in²
 $P_{nt}/\Omega = 6.136$ k **Bolt tension O.K.** $\Omega t = 2.25$
 Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$
 $P_{nv}/\Omega = 3.451$ k **Bolt shear O.K.** *** (Table E3.4-1, AISI) ***

$F'_{nt} = 1.3 F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$ $f_v = 0.92$ ksi
 $F'_{nt} = 45.0$ ksi $F_{nv}/\Omega = 11.25$ ksi

Combined Not Applicable



Connection of Curb to Supporting Structure

Roof Loading	SEISMIC: (0.6-0.14SDS)D + 0.7E	WIND: 0.6D + W
Transverse:	Uplift _{MAX} = 5804 lbs	Shear _{MAX} = 2753 lbs
Compression _{SEISMIC} = 6495 lbs	= [F _{pmaxASD} * (H _{cm} + H _{curb}) + (1 + 0.14S _{DS}) * (WGT _{unit+curb} /2) * w _{curb}] / w _{curb}	
Tension _{SEISMIC} = 5804 lbs	= Comp _{SEISMIC} - (0.6 - 0.14S _{DS}) * (WGT _{unit+curb})	
Compression _{WIND} = 1722 lbs	= [F _{h transASD} * (H _{cm} + H _{curb}) + 0.6 * (WGT _{unit+curb} /2) * w _{curb} - F _{vertASD} * w _{curb}] / w _{curb}	
Tension _{WIND} = 1547 lbs	= [F _{h transASD} * (H _{cm} + H _{curb}) - 0.6 * (WGT _{unit+curb} /2) * w _{curb} + F _{vertASD} * w _{curb}] / w _{curb}	
Longitudinal:	Uplift _{MAX} = 3946 lbs	Shear _{MAX} = 2753 lbs
Compression _{SEISMIC} = 4637 lbs	= [F _{pmaxASD} * (H _{cm} + H _{curb}) + (1 + 0.14S _{DS}) * (WGT _{unit+curb} /2) * L _{curb}] / L _{curb}	
Tension _{SEISMIC} = 3946 lbs	= Comp _{SEISMIC} - (0.6 - 0.14S _{DS}) * (WGT _{unit+curb})	
Compression _{WIND} = 783 lbs	= [F _{h transASD} * (H _{cm} + H _{curb}) + 0.6 * (WGT _{unit+curb} /2) * L _{curb} - F _{vertASD} * L _{curb}] / L _{curb}	
Tension _{WIND} = 608 lbs	= [F _{h transASD} * (H _{cm} + H _{curb}) - 0.6 * (WGT _{unit+curb} /2) * L _{curb} + F _{vertASD} * L _{curb}] / L _{curb}	

Wood Attachment:	1/4" φ wood lag screws	w/ 3.5" Min. Embed (SG _{min} = 0.43)
Transverse:	Tall _{metal} = 946.67 lbs	Vall _{metal} = 1043.33 lbs
	Tall _{wood} = 671.25 lbs	Vall _{wood} = 224 lbs
	# of Screws Req'd for Uplift = 8.65	COMBINED LOADING: 0.952 O.K.
	# of Screws Req'd for Shear = 12.29	Req'd Min Spacing = 3.6 in o.c.
	Total # of screws required = 22	

Use 22 - 1/4" φ wood lag screws @ 3.6 in o.c. along long side of curb w/ 3.5" Min. Embed



MOUR GROUP

ENGINEERING + DESIGN

6593 Riverdate St.
San Diego, CA 92120

(619)727-4800

Page ___ of ___

Longitudinal:

of Screws Req'd for Uplift = 5.88
 # of Screws Req'd for Shear = 12.29
 Total # of screws required = 19

COMBINED LOADING: 0.956 O.K.
 Screw Spacing = 2.5 in o.c.

Use 19 - 1/4" ϕ wood lag screws @ 2.5 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" ϕ A307 Bolts to steel angle below deck

Transverse:
 $T_{all\ bolt} = 6903$ lbs
 $V_{all\ bolt} = 3682$ lbs
 # of Bolts Req'd for Uplift = 0.84
 # of Bolts Req'd for Shear = 0.75
 Total # of bolts required = 2

COMBINED LOADING: 0.794 O.K.
 Bolt Spacing = 71.4 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 71.4 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 0.57
 # of Bolts Req'd for Shear = 0.75
 Total # of bolts required = 2

COMBINED LOADING: 0.660 O.K.
 Bolt Spacing = 41.5 in o.c.

Use 2 - 1/2" ϕ A307 Bolts to steel angle below deck @ 41.5 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7 Ω_o E ($\Omega_o = 2.5$)

Concrete Attachment: 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

$T_{all\ LRFD} = 1919$ lbs $V_{all\ LRFD} = 3188$ lbs $\alpha = (1 + 0.2SDS)D + 2.5E = 1.87$
 $T_{all\ ASD} = T_{all\ LRFD}/\alpha = 1026.2$ lbs $V_{all\ ASD} = V_{all\ LRFD}/\alpha = 1704.8$ lbs ($D = 0.465, E = 0.535$)

Transverse: Uplift_{MAX} = 13580 lbs Shear_{MAX} = 6883 lbs

Compression_{SEISMIC} = 14272 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$

Tension_{SEISMIC} = 13580 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Shear_{SEISMIC} = 6883 lbs = $2.5 * F_{pmaxASD} / 2$

Min Bolts Req'd Uplift = 13.23 spacing = 4.57 in o.c. $T_{applied} = 905.4$ lbs

Min Bolts Req'd Shear = 4.04 spacing = 14.84375 in o.c. $V_{applied} = 458.9$ lbs

Try using 15 bolts spaced at 5.10 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$

Use 15 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 5.1 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift_{MAX} = 8936 lbs Shear_{MAX} = 6883 lbs

Compression_{SEISMIC} = 9627 lbs = $[2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14S_{DS}) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$

Tension_{SEISMIC} = 8936 lbs = $Comp_{SEISMIC} - (0.6 - 0.14S_{DS}) * (WGT_{unit+curb})$

Shear_{SEISMIC} = 6883 lbs = $2.5 * F_{pmaxASD} / 2$

Min Bolts Req'd Uplift = 8.71 spacing = 3.6875 in o.c. $T_{applied} = 812.4$ lbs

Min Bolts Req'd Shear = 4.04 spacing = 7.375 in o.c. $V_{applied} = 625.7$ lbs

Try using 11 bolts spaced at 4.15 in o.c. COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$

Use 11 - 3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy @ 4.2 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: CBISC-04 (CBISCPRD3: Unit: ZT,ZR,ZI 037-150; ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP 078-150)			
UPPER CURB RAIL THICKNESS: 0.0713 in 14 Gauge			
UNIT CLIP THICKNESS: 0.0713 in 14 Gauge			
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip			
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #12 SMS screws each clip			
WEB STIFFENER: 16Ga x 3/4in x 7in (C-channel) stiffener at each clip			
VIBRATION ISOLATOR TYPE: JQBX Top stud diameter: 3/8			
Anchor bolt diameter: 5/8 Anchor hole diameter: 11/16			
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 4 - 1/4" ϕ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" ϕ wood lag screws w/ 3.5" Min. Embed (SGmin = 0.43)	1/2" ϕ A307 Bolts to steel angle below deck	3/4" ϕ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	22 @ 3.59 in o.c.	2 @ 71.38 in o.c.	15 @ 5.1 in o.c.
SHORT DIRECTION	19 @ 2.53 in o.c.	2 @ 41.5 in o.c.	11 @ 4.15 in o.c.