



MOUR GROUP
ENGINEERING + DESIGN

6593 Riverdale St.
San Diego, CA 92120

619-727-4800

Structural Calculations
for
Vibration Isolation Roof Curb CBISC-07



Prepared for:

PROVENT

3847 Wabash Drive
Mira Loma, CA 91725

Date: February 9, 2018

Project Number: PV1802



Client: ProVent PV1802
Project: CBISC-07 curb for ZF180 Unit
Description: Upper curb rail design

Curb Information

Hcurb = 6 in (Height from spring isolator to top of upper rail curb)
Lcurb = 114.75 in (Length of curb)
wcurb = 83.5 in (Width of curb)
WGTcurb = 599.5 lbs (Weight of curb+10% for pitched roof)

Unit Information

WGTunit = 2281 lbs (Weight of Unit + accessories)
Wtmax = 613 lbs (Maximum corner weight)
Wtmin = 528 lbs (Minimum corner weight)
Hunit = 48.625 in (Height of unit above curb)
Hcm = 24.3125 in (Height from top of curb to center of mass of unit)
Lunit = 125.25 in (Length of unit)
Wunit = 92 in (Width of unit)

Seismic Loading - 2015 IBC

Ss = 2.850 (Worst case for majority of CA - Design Category D)
Fa = 1.000 (Interpolated from Table 11.4-1 ASCE 7-10)
Sms = 2.850 (Fa*Ss)
Sds = 1.900 (2/3*Sms)
Ip = 1.25 (Importance Factor Category III Building)
Fpmax = 3.800 Wp (1.6*Sds*Ip)*Wp
FpmaxASD = 6067 lbs (unit only) (0.7*Fpmax) FpmaxASD = 7662 lbs (unit and curb)

Wind Loading - 2015 IBC

*** Exposure Category C ***

Kz = 1.13 (For 60 ft roof height, Exposure C - Table 29.3-1 ACSE 7-10)
Kzt = 1.0 (No topographic effects assumed for rooftop mounted units)
Kd = 0.90 (Directionality factor Table 26.6-1 ASCE 7-10)
V = 115 (Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr_(horiz) = 1.9 (Refer pg. 309 ASCE 7-10)
GCr_(vert) = 1.5 (Refer pg. 309 ASCE 7-10)
qz = 34.4 psf = 0.00256*Kz*Kzt*Kd*V² (Eq. 29.3-1 ASCE 7-10)
F_{h ASD trans} = 1865 lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
F_{h ASD long} = 1370 lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F_{vert ASD} = 2480 lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression_{SEISMIC} = 3319 lbs = [FpmaxASD*Hcm+2*(1+0.14S_{DS})*Wtmax*wcurb]/wcurb
Tension_{SEISMIC} = 2557 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = 39 lbs = [F_{h transASD}*Hcm+2*0.6*Wtmax*wcurb-F_{vertASD}*wcurb/2]/wcurb
Tension_{WIND} = 1150 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression_{SEISMIC} = 2838 lbs = [FpmaxASD*Hcm+2*(1+0.14*S_{DS})*Wtmax*Lcurb]/Lcurb
Tension_{SEISMIC} = 2076 lbs = Comp_{SEISMIC}-(0.6-0.14S_{DS})*WGTunit
Compression_{WIND} = -214 lbs = [F_{h transASD}*Hcm+2*0.6*Wtmax*Lcurb-F_{vertASD}*Lcurb/2]/Lcurb
Tension_{WIND} = 897 lbs = Comp_{WIND}+Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

<u>Transverse:</u>	Comp _{MAX} = 3319 lbs	----> Along long edge of curb.
(on long edge)	Tens _{MAX} = 2557 lbs	----> Along long edge of curb.
<u>Longitudinal:</u>	Comp _{MAX} = 2838 lbs	----> Along short edge of curb.
(on short edge)	Tens _{MAX} = 2076 lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.

Curb Design

F_y = 50 ksi F_u = 65 ksi t = 0.0713 **14 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

(curb assumed to be symmetric C-Section without Lips)

A' = 6.000 in	a = 5.644 in = A' - (2r+t)
B' = 1.500 in	a' = 5.929 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.322 in = B' - [r+t/2+a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.464 in = B' - (t/2+αt/2)
R = 0.1069 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α[C' - t/2]
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.246 in (Distance between centroid and web centerline)	
I _x = 2.996 in (Moment of Inertia about X-Axis)	
I _y = 0.112 in (Moment of Inertia about Y-Axis)	
A = 0.62 in ²	
r _x = 2.19 in	
r _y = 0.423 in	
r _{min} = 0.423 in	

Axial Compression

P_u = 3.034 k (Max Axial Comp) Ω_c = 1.80
P_n/Ω_c = 3.549 k
F_e = 11.70 ksi
λ_c = 2.07
F_n = 10.26 ksi
L_y = 83.5 in
k_yL_y/r_y = 158

If λ_c ≤ 1.5; F_n = (0.658λ_c²)F_y
If λ_c > 1.5; F_n = $\frac{0.877}{\lambda_c^2} F_y$

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$ $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Lateral unbraced length (assume k=0.8)

Compression Check = O.K.

Check Web Crippling

h = 6 in -- Check limits: C = 7.50
t = 0.0713 in h/t = 84.15 ≤ 200 C_R = 0.08
N = 7.00 N/t = 98.18 ≤ 210 C_N = 0.12
Ω_w = 1.75 N/h = 1.167 ≤ 2.0 C_h = 0.048
P_n = 1.883 k R/t = 1.50 ≤ 12.0
P_n/Ω_w = 1.076 k

Long side: P_{uTrans} = 1.106 k **web stiffener REQ'D** # clips = 3
Short side: P_{uLong} = 0.946 k **O.K.** # clips = 3

$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \frac{R}{t} \right) \left(1 + C_N \frac{N}{t} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$

(See table C3.4.1-2, fastened to support, two flange, end loading)

Check Web Stiffener

16Ga x 3/4in x 7in [C-channel]
width of stiffener = 7.000 in t_s = 0.0566 **16 Gauge**
web of stiff. w = 6.717 in R_s = 0.0849 in
***Check w/ts ≤ 1.28VE/F_y Ω_c = 1.70
w/ts = 118.675
1.28v(E/F_y) = 31.091 --> w/ts over limit Use C3.7.2
P_n = 0.7(P_{wc} + A_eF_y) ≥ P_{wc}
P_{wc} = 1.883 k A_e = 0.380 in²
P_n = 14.625 k
P_n/Ω_c = 8.603 k **O.K.**

Corner Connections

(Use 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded insert)

T_{crnmax} = 1517 lbs Max[F_{pmaxASD}/4 -OR- F_{hASDtrans}/4 corner connections]
V_{crnmax} = 1278 lbs (Max Ten/2 corner connections per side)
Bolt: T_{all} = 5000 lbs V_{all} = 4470 lbs
Threaded Insert: T_{all} = 4289 lbs V_{all} = 661 lbs
of Bolts required for Tension = 0.4 **(By Inspection, Threaded Inserts Control)**
of Bolts required for Shear = 1.9 ***If combined fails:
of Bolts Used = 2.0 USE --> 3.0
Check Combined Stress in Bolts & Inserts: 1.144 **N.G.** StressComb = 0.763 **O.K.**

Check 1/8" welded connection

---- USE WELD Ω = 2.35
Assume L/t > 25*t = 1.783 in P_n/Ω = $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ L_{req'd} = $\frac{V_{req}\Omega}{0.75tF_u}$
L_{req'd} = 0.864 in



Connection Curb Clip to Upper Rail #10 SMS screws $\Omega = 3.0$

$t_1 = 0.0713$ in (hold down clip thickness - 14 Ga) $F_{u1} = 65$ ksi
 $t_2 = 0.0713$ in (upper rail thickness) $F_{u2} = 65$ ksi
 $d = 0.190$ in (screw diameter) $dw = 0.375$ in (nom. washer diameter)
 $t_2/t_1 = 1.0$

For $t_2/t_1 \leq 1.0$: $P_{ns} = 2266$ # For $t_2/t_1 \geq 2.5$: $P_{ns} = 2377$ #
Shear: $P_{ns} = 4.2F_{u2}\sqrt{t_2^3d}$ 2.27 k $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k
 $P_{ns} = 2.7t_1dF_{u1}$ 2.38 k $P_{ns} = 2.7t_2dF_{u2}$ 2.38 k
 $P_{ns}/\Omega = 755$ #
 $P_{ss}/\Omega = 540$ # <- Controls

Tension: $P_{not} = 0.748$ k (screw pull-out strength) $P_{not} = 0.85t_c d F_{u2}$; $t_c = \min(t_1, t_2)$
 $P_{nov} = 2.607$ k (screw pull-over strength) $P_{nov} = 1.5t_1 d_w F_{u1}$
 $P_{ts}/\Omega = 249$ # <- Controls
 $P_{ts}/\Omega = 820$ # (full tensile screw capacity)

	Shear (k)	# clips	V_{clip} (k)	V_{allow} (k)	# screws	spacing		
Long side:	3.03	3	1.01	2.160	4	2.0 in	3 clips w/ 4 - #10 SMS screws	O.K.
Short side:	3.03	3	1.01	2.160	4	2.0 in	3 clips w/ 4 - #10 SMS screws	O.K.

clip width = 7.00 in clip height = 2.5 in
min spacing = 0.57 in O.K. edge distance = 0.5 in (min. 1.5d)

Check Block shear rupture: $F_y = 50$ ksi $\Omega = 2.22$ bolt/screw connection
 $A_{gv} = 0.428$ in² $A_{nv} = 0.380$ in² $A_{nt} = 0.082$ in²
 $R_n/\Omega = 8.192$ k $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{nv} + F_u A_{nt}$ (AISI Sect. E5.3)
BSR O.K.

Curb Loads (copied from above)

Transverse: (on long edge)	Comp _{MAX} = 3319 lbs
	Tens _{MAX} = 2557 lbs
	Shear _{MAX} = 3034 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2838 lbs
	Tens _{MAX} = 2076 lbs
	Shear _{MAX} = 3034 lbs

Max compression force on isolator: 1.106 k ≤ 1.660 k **O.K.**

Max uplift on isolator: 0.852 k

Max shear on isolator: 1.011 k

Forces on top bolt:

$d_b = 0.375$ in

upper rail, $t = 0.0713$ in

Tension = 0.852 k

Shear = 1.011 k

Shear on curb rail:

$P_n = teF_u$

$P_n/\Omega = 4.635$ k

$\Omega = 2.00$ (Appendix A, Section E3.1 AISI)

$e = 1.0$ in

Shear O.K.

Net section rupture:

$P_n = A_n F_t$

$P_n/\Omega = 4.989$ k

$\Omega = 2.22$ (Appendix A, Section E3.2 AISI)

$A_n = 0.116$ in

N.S.R. O.K.

$F_t = (0.1 + 3d/s)F_u \leq F_u = 43.063$ ksi

Bolt Bearing Strength:

$P_n = C m_f d t F_u$

$P_n/\Omega = 2.086$ k

$\Omega = 2.50$ (Section E3.3.1 AISI)

$d/t = 5.26$

Bearing O.K.

$C = 3.00$ $mf = 1.00$

Shear and tension in bolt:

(Appendix A, Section E3.4 AISI)

Tension $P_{nt} = A_b F_{nt}$

$F_{nt} = 40.5$ ksi

$A_b = 0.1104$ in²

$P_{nt}/\Omega = 1.988$ k

Bolt tension O.K.

$\Omega_t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$

$F_{nv} = 24.0$ ksi

$\Omega_v = 2.40$ (Table E3.4-1, AISI)

$P_{nv}/\Omega = 1.104$ k

Bolt shear O.K.


$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$

$f_v = 9.16$ ksi **O.K.**

Combined Not Applicable

$F'_{nt} = 15.57$ ksi

$F_{nv}/\Omega = 10.00$ ksi





Client:	ProVent PV1802
Project:	CBISC-07 curb for ZF180 Unit
Description:	Base curb design

Curb Information

Hcurb =	25	in	(Height from support structure to top of curb)
Lcurb =	115.25	in	(Length of curb)
wcurb =	84	in	(Width of curb)
WGTcurb =	599.5	lbs	(Weight of curb+10% for pitched roof)

Unit Information

WGTunit =	2281	lbs	(Weight of Unit + accessories)
Wtmax =	613	lbs	(Maximum corner weight)
Wtmin =	528	lbs	(Minimum corner weight)
Hunit =	48.625	in	(Height of unit above curb)
Hcm =	34.3125	in	(Height from top of curb to center of mass of unit)
Lunit =	125.25	in	(Length of unit)
Wunit =	92	in	(Width of unit)

Seismic Loading - 2015 IBC

Ss =	2.850	(Worst case for majority of CA - Design Category D)
Fa =	1.000	(Interpolated from Table 11.4-1 ASCE 7-10)
Sms =	2.850	(Fa*Ss)
Sds =	1.900	(2/3*Sms)
Ip =	1.25	(Importance Factor Category III Building)
Fpmax =	3.800	Wp
FpmaxASD =	6067	lbs
	(unit only)	FpmaxASD = 7662
		(unit and curb)

Wind Loading - 2015 IBC

*** Exposure Category C ***

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 29.3-1 ACSE 7-10)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.90	(Directionality factor Table 26.6-1 ASCE 7-10)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr _(horiz) =	1.9	(Refer pg. 309 ASCE 7-10)
GCr _(vert) =	1.5	(Refer pg. 309 ASCE 7-10)
qz	34.4	psf = 0.00256*Kz*Kzt*Kd*V ² (Eq. 29.3-1 ASCE 7-10)
F _{h ASD trans} =	2514	lbs = 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
F _{h ASD long} =	1846	lbs = 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
F _{vert ASD} =	2480	lbs = 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

Curb Loading

Transverse:

Compression _{SEISMIC} =	4031	lbs	= [FpmaxASD*Hcm+2*(1+0.14S _{DS})*Wtmax*wcurb]/wcurb
Tension _{SEISMIC} =	3269	lbs	= Comp _{SEISMIC} - [0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	523	lbs	= [F _{h trans ASD} *Hcm+2*0.6*Wtmax*wcurb-F _{vert ASD} *wcurb/2]/wcurb
Tension _{WIND} =	1634	lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Longitudinal:

Compression _{SEISMIC} =	3359	lbs	= [FpmaxASD*Hcm+2*(1+0.14*S _{DS})*Wtmax*Lcurb]/Lcurb
Tension _{SEISMIC} =	2597	lbs	= Comp _{SEISMIC} - [0.6-0.14S _{DS}]*WGTunit
Compression _{WIND} =	45	lbs	= [F _{h trans ASD} *Hcm+2*0.6*Wtmax*Lcurb-F _{vert ASD} *Lcurb/2]/Lcurb
Tension _{WIND} =	1157	lbs	= Comp _{WIND} +Fvert-0.6*WGTunit

----> Negative values indicate Compression load rather than Tension.

Governing Reactions:

Transverse: (on long edge)	Comp _{MAX} =	4031	lbs	----> Along long edge of curb.
	Tens _{MAX} =	3269	lbs	----> Along long edge of curb.
Longitudinal: (on short edge)	Comp _{MAX} =	3359	lbs	----> Along short edge of curb.
	Tens _{MAX} =	2597	lbs	----> Along short edge of curb.

----> Negative values indicate Compression load rather than Tension.



Curb Design

Fy = 50 ksi Fu = 65 ksi t = 0.1017 **12 Gauge**
E = 29500 ksi

Calculate Section Properties of Curb

(curb assumed to be symmetric C-Section without Lips)

A' = 25.000 in	a = 24.492 in = A' - (2r+t)
B' = 2.000 in	a' = 24.898 in = A' - t
C' = 0.000 in (0 if no lips)	b = 1.746 in = B' - [r+t/2 + a(r+t/2)]
α = 0.000 (0 - no Lip; 1 w/ lip)	b' = 1.949 in = B' - (t/2 + αt/2)
R = 0.1525 (Inside bend radius)	c = 0.000 in = α[C' - (r+t/2)]
t = 0.1017 in	c' = 0.000 in = α[C' - t/2]
r' = 0.203 in = R+t/2	u = 0.319 in = πr/2
x = 0.133 in (Distance between centroid and web centerline)	
Ix = 189.589 in (Moment of Inertia about X-Axis)	
Iy = 0.451 in (Moment of Inertia about Y-Axis)	
A = 2.91 in ²	
rx = 8.07 in	
ry = 0.393 in	
rmin = 0.393 in	

Axial Compression

Pu = 3.034 k	(Max Axial Comp)	Ωc = 1.80
Pn/Ωc = 7.266 k		
Fe = 5.12 ksi		
λc = 3.12		
Fn = 4.49 ksi		
Ly = 117.25 in		
kyLy/ry = 238		

Lateral unbraced length
[assume k=0.8]

$$\lambda_c = \sqrt{\frac{F_y}{F_e}} \quad F_e = \frac{\pi^2 E}{(kl/r)^2}$$

If $\lambda_c \leq 1.5$; $F_n = (0.658^{\lambda_c^2}) F_y$
If $\lambda_c > 1.5$; $F_n = \frac{0.877}{\lambda_c^2} F_y$

Compression Check = O.K.

Check Web Crippling

h = 25 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.1017 in	h/t = 245.82 ≤ 200	CR = 0.14	
N = 7.00	N/t = 68.83 ≤ 210	CN = 0.35	
Ωw = 1.75	N/h = 0.28 ≤ 2.0	Ch = 0.02	
Pn = 4.106 k	R/t = 1.50 ≤ 9.0		
Pn/Ωw = 2.346 k			
Long side: PuTrans = 1.344 k	O.K. # clips = 3	$P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}} \right) \left(1 + C_N \sqrt{\frac{N}{t}} \right) \left(1 - C_h \sqrt{\frac{h}{t}} \right)$	
Short side: PuLong = 1.679 k	O.K. # clips = 2		

***h/t > 200; use web stiffeners

Check Web Stiffener

N/A

width of stiffener = 7.000 in	ts = 0.0566 16 Gauge
web of stiff. w = 6.717 in	Rs = 0.0849 in
***Check w/ts ≤ 1.28√E/Fys	Ωc = 1.70
w/ts = 118.675	
1.28√(E/Fys) = 31.091	--> w/ts over limit Use C3.7.2
$P_n = 0.7(P_{wc} + A_e F_y) \geq P_{wc}$	
Pwc = 4.106 k	Ae = 0.380 in ²
Pn = 16.181 k	
Pn/Ωc = 9.518 k	O.K.

Corner Connections

(Use 1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded insert)

Tcrnmax = 1517 lbs	Max(FpmaxASD/4 -OR- FhASDtrans/4 corner connections)
Vcrnmax = 1634 lbs	(Max Ten/2 corner connections per side)
Bolt: Tall = 5000 lbs	Vall = 4470 lbs
Threaded Insert: Tall = 4289 lbs	Vall = 661 lbs
# of Bolts required for Tension = 0.4	(By Inspection, Threaded Inserts Control)
# of Bolts required for Shear = 2.5	***If combined fails:
# of Bolts Used = 3.0	USE --> 4.0
Check Combined Stress in Bolts & Inserts: 0.942 O.K.	StressComb = 0.707 O.K.

Check 1/8" welded connection

<--- USE WELD Ω = 2.35

Assume L/t > 25: 25*t = 2.543 in $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$ $L_{req}'d = \frac{V_{req}\Omega}{0.75tF_u}$
Lreq'd = 0.775 in



Curb Loads (copied from upper rail calcs)

Transverse: (on long edge)	Comp _{MAX} = 3319 lbs Tens _{MAX} = 2557 lbs Shear _{MAX} = 3034 lbs
Longitudinal: (on short edge)	Comp _{MAX} = 2838 lbs Tens _{MAX} = 2076 lbs Shear _{MAX} = 3034 lbs

Max compression force on isolator: 1.106 k ≤ 1.660 k **O.K.**
Max uplift on isolator: 0.852 k
Max shear on isolator: 1.011 k

Forces on bottom bolts:

$d_b = 0.5$ in
base curb, $t = 0.1017$ in
Tension = 0.426 k / bolt
Shear = 0.506 k / bolt

Shear on base curb: $P_n = teF_u$ $\Omega = 2.00$ (Appendix A, Section E3.1 AISI)
 $P_n/\Omega = 6.611$ k $e = 1.0$ in

Shear O.K.

Net section rupture: $P_n = A_n F_t$ $\Omega = 2.22$ (Appendix A, Section E3.2 AISI)
 $P_n/\Omega = 8.428$ k $A_n = 0.153$ in

N.S.R. O.K.

$$F_t = (0.1 + 3d/s)F_u \leq F_u = 55.250 \text{ ksi}$$

Bolt Bearing Strength: $P_n = C m_f d t F_u$ $\Omega = 2.50$ (Section E3.3.1 AISI)
 $P_n/\Omega = 3.966$ k $d/t = 4.92$

Bearing O.K.

$C = 3.00$ $m_f = 1.00$

Shear and tension in bolt: (Appendix A, Section E3.4 AISI)


Tension $P_{nt} = A_b F_{nt}$ $F_{nt} = 45.0$ ksi $A_b = 0.1963$ in²
 $P_{nt}/\Omega = 3.927$ k **Bolt tension O.K.** $\Omega t = 2.25$ (Table E3.4-1, AISI)

Shear $P_{nv} = A_b F_{nv}$ $F_{nv} = 27.0$ ksi $\Omega v = 2.40$ (Table E3.4-1, AISI)
 $P_{nv}/\Omega = 2.209$ k **Bolt shear O.K.**

$$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$$

$f_v = 2.58$ ksi **O.K.**
 $F'_{nt} = 45.00$ ksi $F_{nv}/\Omega = 11.25$ ksi

Combined Not Applicable



Connection of Curb to Supporting Structure

Roof Loading SEISMIC: (0.6-0.14SDS)D + 0.7E WIND: 0.6D + W

Transverse:	Uplift _{MAX} = 6272 lbs	Shear _{MAX} = 3831 lbs
Compression _{SEISMIC} =	7234 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*w _{curb}]/w _{curb}
Tension _{SEISMIC} =	6272 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND} =	1399 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*w _{curb} -F _{vertASD} *w _{curb}]/w _{curb}
Tension _{WIND} =	2151 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*w _{curb} +F _{vertASD} *w _{curb}]/w _{curb}
Longitudinal:	Uplift _{MAX} = 4805 lbs	Shear _{MAX} = 3831 lbs
Compression _{SEISMIC} =	5767 lbs	= [F _{pmaxASD} *(H _{cm} +H _{curb})+(1+0.14S _{DS})*(WGT _{unit+curb} /2)*L _{curb}]/L _{curb}
Tension _{SEISMIC} =	4805 lbs	= Comp _{SEISMIC} -(0.6-0.14S _{DS})*(WGT _{unit+curb})
Compression _{WIND} =	574 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})+0.6*(WGT _{unit+curb} /2)*L _{curb} -F _{vertASD} *L _{curb}]/L _{curb}
Tension _{WIND} =	1326 lbs	= [F _{h transASD} *(H _{cm} +H _{curb})-0.6*(WGT _{unit+curb} /2)*L _{curb} +F _{vertASD} *L _{curb}]/L _{curb}

Wood Attachment: **1/4" φ Simpson SDS screws** **w/ 3.5" Min. Embed**

Transverse: $T_{all\ metal} = 324$ lbs $V_{all\ metal} = 1020$ lbs
 $T_{all\ wood} = 642$ lbs $V_{all\ wood} = 272$ lbs

of Screws Req'd for Uplift = 19.36 # of Bolts Required = 20
of Screws Req'd for Shear = 14.08 Req'd Min Spacing = 5.6 in o.c.

Use 20 - 1/4" φ Simpson SDS screws @ 5.6 in o.c. along long side of curb w/ 3.5" Min. Embed

Longitudinal:

of Screws Req'd for Uplift = 14.83 # of Bolts Required = 15
of Screws Req'd for Shear = 14.08 Req'd Min Spacing = 5.4 in o.c.

Use 15 - 1/4" φ Simpson SDS screws @ 5.4 in o.c. along short side of curb w/ 3.5" Min. Embed

Steel Deck Attachment: 1/2" φ A307 Bolts attached to steel angle below deck

Transverse: $T_{all\ steel} = 4417$ lbs $V_{all\ steel} = 2316$ lbs
 $T_{all\ bolt} = 1325$ lbs $V_{all\ bolt} = 1325$ lbs

of Bolts Req'd for Uplift = 4.73 # of Bolts Required = 5
of Bolts Req'd for Shear = 2.89 Req'd Min Spacing = 25.8 in o.c.

Use 5 - 1/2" φ A307 Bolts attached to steel angle below deck @ 25.8 in o.c. along long side of curb

Longitudinal:

of Bolts Req'd for Uplift = 3.63 # of Bolts Required = 4
of Bolts Req'd for Shear = 2.89 Req'd Min Spacing = 24.0 in o.c.

Use 4 - 1/2" φ A307 Bolts attached to steel angle below deck @ 24 in o.c. along long side of curb



For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω_oE (Ω_o = 2.5)

Concrete Attachment: 3/4" φ Hilti Hit-HY 200 adhesive anchors **w/ 6" embed**

$$T_{all,LRFD} = 1919 \text{ lbs} \quad V_{all,LRFD} = 3188 \text{ lbs} \quad \alpha = (1 + 0.2SDS)D + 2.5E = 1.87$$

$$T_{all,ASD} = T_{all,LRFD}/\alpha = 1026.2 \text{ lbs} \quad V_{all,ASD} = V_{all,LRFD}/\alpha = 1704.8 \text{ lbs} \quad (D = 0.465, E = 0.535)$$

Transverse:	Uplift _{MAX} = 14387 lbs	Shear _{MAX} = 9578 lbs
--------------------	-----------------------------------	---------------------------------

$$\text{Compression}_{SEISMIC} = 15349 \text{ lbs} = [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * w_{curb}] / w_{curb}$$

$$\text{Tension}_{SEISMIC} = 14387 \text{ lbs} = \text{Comp}_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 9578 \text{ lbs} = 2.5 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 14.02 \text{ spacing} = 6.52 \text{ in o.c.} \quad T_{applied} = 846.3 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 5.62 \text{ spacing} = 18.25 \text{ in o.c.} \quad V_{applied} = 563.4 \text{ lbs}$$

Try using 17 bolts spaced at 6.45 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.16$
--	--

Use 17 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 6.5 in o.c. max. along long side of curb w/ 6" embed

Longitudinal:	Uplift _{MAX} = 10719 lbs	Shear _{MAX} = 9578 lbs
----------------------	-----------------------------------	---------------------------------

$$\text{Compression}_{SEISMIC} = 11681 \text{ lbs} = [2.5 * F_{pmaxASD} * (H_{cm} + H_{curb}) + (1 + 0.14SDS) * (WGT_{unit+curb}/2) * L_{curb}] / L_{curb}$$

$$\text{Tension}_{SEISMIC} = 10719 \text{ lbs} = \text{Comp}_{SEISMIC} - (0.6 - 0.14SDS) * (WGT_{unit+curb})$$

$$\text{Shear}_{SEISMIC} = 9578 \text{ lbs} = 2.5 * F_{pmaxASD} / 2$$

$$\text{Min Bolts Req'd Uplift} = 10.45 \text{ spacing} = 6 \text{ in o.c.} \quad T_{applied} = 765.7 \text{ lbs}$$

$$\text{Min Bolts Req'd Shear} = 5.62 \text{ spacing} = 12 \text{ in o.c.} \quad V_{applied} = 684.1 \text{ lbs}$$

Try using 14 bolts spaced at 5.54 in o.c.	COMBINED LOADING = $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.15$
--	--

Use 14 - 3/4" φ Hilti Hit-HY 200 adhesive anchors @ 5.5 in o.c. max. along short side of curb w/ 6" embed