



**MOUR GROUP**  
ENGINEERING + DESIGN

6593 Riverdale St.  
San Diego, CA 92120

619-727-4800

**Structural Calculations**  
**for**  
**Sunline Magna Series**  
**ISCALPRD3715\*\* Roof Curb**  
**Form No. ISCAL-127**



**Prepared for:**

**PROVENT**

**3847 Wabash Drive**  
**Mira Loma, CA 91725**

**Date: November 14, 2019**

**Project Number: PV1908**

**STRUCTURALLY CALCULATED VIBRATION ISOLATION CURBS FOR YORK UNITS**

ZT, ZH, ZJ, ZR, 037, 049, 061  
ZF, ZH, ZJ, ZR, XP, DH, DM, DF, DR, BP 078-150

For wood, concrete and steel attachments see Roof Anchorage Detail, Form No. CB-24A.




Welded isolation spring housings are standard. For bolted spring housings, neoprene pads and spring cups see Weldment and Bolting Detail, Form No. ISCAL-131.

**FEATURES**

- Roof curb sides and ends are 14 ga. galvanized steel.
- Fully welded construction.
- Gasketing package provided.
- Heat treated wood nailer provided.
- Insulated deck pans provided.
- Pitched curbs and taller curbs are available.
- CalDyn OSHPD pre-approved 2" or 3" deflection seismic restraints. (OPA-0070), (JQB).

**NOTES**


- Attach ductwork to roof curb. Flanges of duct rest on top of curb. Support ductwork below the curb.
- Thru the curb utilities are available. Contact your York distributor or ProVent directly.



ProVent P/N (2" Deflection)	A	B	WL	ProVent P/N (3" Deflection)	A	B	WL
ISCALPRD371519**	8"	19"	494 Lbs	ISCALPRD3715193**	8"	19"	494 Lbs
ISCALPRD371522**	11"	22"	511 Lbs	ISCALPRD3715223**	11"	22"	511 Lbs
ISCALPRD371525**	14"	25"	528 Lbs	ISCALPRD3715253**	14"	25"	528 Lbs
ISCALPRD371531**	20"	31"	754 Lbs				

Meets seismic requirements for the following codes:  
CBC 2019  
IBC 2018

\*\*Note: Spring configuration must be added to part number at time of order.



**PROFILE DETAIL**

\*\* UNITS UNDER 1260 LBS (2) ISOLATOR RESTRAINTS, OVER 1260 LBS (3) ISOLATOR RESTRAINTS

3847 WABASH DRIVE  
MIRA LOMA, CA 91725  
PHONE (951) 685-1101  
FAX (619) 872-8799




SUBMITTED TO:  
COMPANY:  
JOB NAME:  
EQUIPMENT:  
NOTES:

FORM NO: ISCAL-127	PART NUMBER: ISCALPRD3715 SERIES
DATE: 11/13/19	REV: 4
	DRAWN BY: ALL

**STEEL ATTACHMENT**

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/2" Ø A307 BOLTS TO STEEL ANGLE BELOW.



CURB	LONG SIDE	SHORT SIDE
SUN3672	2 @ 62.13 in o.c.	2 @ 24.75 in o.c.
PRD3715	2 @ 68.38 in o.c.	2 @ 38.50 in o.c.
SLM1830	3 @ 56.88 in o.c.	3 @ 35.75 in o.c.

L5x5x3/8 BY OTHERS

Meets seismic requirements for the following codes:  
CBC 2019  
IBC 2018


ASSUMES:  
CONC SLAB  
f<sub>c</sub> = 4000PSI MINIMUM

5 1/2" MIN THICKNESS  
NORMAL WEIGHT CONCRETE  
OR SAND LIGHT WEIGHT

**CONCRETE ATTACHMENT**

WELDED CURB

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 3/4" Ø THRD'D RODS IN HILTI HIT-HY 200 EPOXY W/ 4" EMBED INTO CONCRETE.



CURB	LONG SIDE	SHORT SIDE
SUN3672	13 @ 5.18 in o.c.	8 @ 3.54 in o.c.
PRD3715	19 @ 3.8 in o.c.	14 @ 2.96 in o.c.
SLM1830	23 @ 5.17 in o.c.	17 @ 4.47 in o.c.

\* SIX INCHES FROM EACH CORNER EVENLY SPACED.  
\*\* CENTERED.


**WOOD ATTACHMENT**

CENTER ON CURB FLANGE. SEE TABLE FOR QUANTITY OF EVENLY SPACED 1/4" Ø SIMPSON SDS SCREWS W/3" MIN. EMBED INTO WOOD (SG MIN = 0.43)



CURB	LONG SIDE	SHORT SIDE
SUN3672	14 @ 5.09 in o.c.	10 @ 3.19 in o.c.
PRD3715	17 @ 4.52 in o.c.	12 @ 3.86 in o.c.
SLM1830	19 @ 6.54 in o.c.	16 @ 5.03 in o.c.

FOUR INCHES FROM EACH CORNER EVENLY SPACED



3847 WABASH DRIVE  
MIRA LOMA, CA 91725  
PHONE (951) 685-1101  
FAX (619) 872-9799

SUBMITTED TO:  
COMPANY:  
JOB NAME:  
EQUIPMENT:  
NOTES:

FORM NO:  
CB-24A

DATE:  
11/15/19

REV:  
15

DRAWN BY:  
ALL




Client:	ProVent PV1908	Upper curb tube
Curb:	ISCAL-127 Iso Curb	(ISCALPRD3715**)
Unit:	ZT,ZJ,ZH,ZR037,049,061;ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP078-150	

**Curb Information**

Hcurb upper =	6 in	(Height of upper curb tube)
Lcurb =	80.375 in	(Length of curb)
wcurb =	50.5 in	(Width of curb)
WGTcurb top =	161 lbs	(Weight of upper curb)
# Clips long side =	3	
# Clips short side =	2	

**Unit Information**

WGTunit =	2095 lbs	(Weight of Unit)
Wtmax =	719 lbs	(Maximum corner weight)
Wtmin =	293 lbs	(Minimum corner weight)
Hunit =	50.75 in	(Height of unit above curb)
Hcm =	25.375 in	(Height to center of mass)
Lunit =	119.5 in	(Length of unit)
Wunit =	59 in	(Width of unit)



**Seismic Loading - 2018 IBC/2019 CBC**

Ss =	2.000	(Conservative for majority of CA - Design Category D)
Fa =	1.000	(From Table 11.4-1 ASCE 7-10)
Sms =	2.000	(Fa*Ss)
Sds =	1.333	(2/3*Sms)
Ip =	1.50	(Importance Factor Category IV Building)
Fpmax =	3.200 Wp	(1.6*Sds*p)*Wp
FpmaxASD =	4693 lbs	(0.7*Fpmax)
	(unit only)	
FpmaxASD =	5053 lbs	(unit and upper curb)

**Wind Loading - 2018 IBC/2019 CBC**

\*\*\* Exposure Category C \*\*\*

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 29.3-1 ACSE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) =	1.9	(Refer Sect 29.5.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.5.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V <sup>2</sup> (Eq. 29.3-1 ASCE 7-16)
Fh ASD trans =	1746 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb upper) (Eq. 29.5-2)
Fh ASD long =	862 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb upper)
Fvert ASD =	1433 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

**Curb Loading**

<b>Transverse:</b>		
Compression <sub>SEISMIC</sub> =	4064 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	3199 lbs	= Comp <sub>SEISMIC</sub> - (0.6 - 0.14S <sub>DS</sub> )*WGTunit
Compression <sub>WIND</sub> =	1024 lbs	= [Fh transASD*Hcm + 2*0.6*Wtmax*wcurb - FvertASD*wcurb/2]/wcurb
Tension <sub>WIND</sub> =	1200 lbs	= Comp <sub>WIND</sub> + Fvert - 0.6*WGTunit
---> Negative values indicate Compression load rather than Tension.		

<b>Longitudinal:</b>		
Compression <sub>SEISMIC</sub> =	3188 lbs	= [FpmaxASD*Hcm + 2*(1+0.14*S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	2322 lbs	= Comp <sub>SEISMIC</sub> - (0.6 - 0.14S <sub>DS</sub> )*WGTunit
Compression <sub>WIND</sub> =	418 lbs	= [Fh transASD*Hcm + 2*0.6*Wtmax*Lcurb - FvertASD*Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	594 lbs	= Comp <sub>WIND</sub> + Fvert - 0.6*WGTunit
---> Negative values indicate Compression load rather than Tension.		

**Governing Reactions:**

<b>Transverse:</b>		
(on long edge) Comp <sub>MAX</sub> =	4064 lbs	---> Along long edge of curb.
(on long edge) Tens <sub>MAX</sub> =	3199 lbs	---> Along long edge of curb.
<b>Longitudinal:</b>		
(on short edge) Comp <sub>MAX</sub> =	3188 lbs	---> Along short edge of curb.
(on short edge) Tens <sub>MAX</sub> =	2322 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.



### Curb Design

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi      t = 0.1242 **10 Gauge**  
E = 29500 ksi

### Tube Curb Design

#### Section Properties of Tube - 6.5x1.5x10Ga

F<sub>y</sub> = 55 ksi      F<sub>u</sub> = 65 ksi      A<sub>g</sub> = 1.871 in<sup>2</sup>      R = 0.1875      d = 5.625  
E = 29500 ksi      I<sub>x</sub> = 3.742 in<sup>4</sup>      I<sub>y</sub> = 0.412 in<sup>4</sup>      wt = 135.723  
height = 6 in      S<sub>x</sub> = 1.247 in<sup>3</sup>      S<sub>y</sub> = 0.550 in<sup>3</sup>  
width = 1.5 in      r<sub>x</sub> = 1.414 in      r<sub>y</sub> = 0.469 in      b/t = 12.07729  
t = 0.1242 in      Z<sub>x</sub> = 1.625 in<sup>3</sup>      Z<sub>y</sub> = 0.595 in<sup>3</sup>      d/t = 45.28986

### Check weak axis bending of tube:

<u>Long side</u>		<u>Short side</u>	
# clips = <b>3</b>		# clips = <b>2</b>	
compression = 58.386 lb/in		compression = 92.927 lb/in	
clip spacing = 36.19 in		clip spacing = 35.50 in	
Mmax = 9.6 k-in		Mmax = 14.64 k-in	
Yielding      M <sub>y</sub> = 30.24 k-in		M <sub>py</sub> /Ω = 18.11 k-in	<b>O.K.</b>
Flange local buckling      M <sub>n</sub> = 30.24 k-in	<--Section is compact, FLB does not apply		
Web local buckling      M <sub>n</sub> = 30.24 k-in	<--Section is compact, WLB does not apply		

### Axial Compression

P<sub>a</sub> = 2.346 k      (Max Axial Comp)      Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 8.272 k  
F<sub>e</sub> = 16.01 ksi  
λ<sub>c</sub> = 1.767  
F<sub>n</sub> = 14.04 ksi  
L<sub>y</sub> = 70.13 in  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 135

If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>) F<sub>y</sub>  
If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$

Lateral unbraced length  
(assume k=0.8)

$\lambda_c = \sqrt{\frac{F_y}{F_e}}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$

Compression Check = **O.K.**

### Check Web Crippling

h = 6 in      -- Check limits:      C = 7.50  
t = 0.1242 in      h/t = 48.31 ≤ 200      C<sub>R</sub> = 0.08  
N = 7.00      N/t = 56.36 ≤ 210      C<sub>N</sub> = 0.12  
Ω<sub>w</sub> = 1.75      N/h = 1.167 ≤ 2.0      C<sub>h</sub> = 0.048  
P<sub>n</sub> = 5.907 k  
P<sub>n</sub>/Ω<sub>w</sub> = 3.375 k  
Long side: P<sub>aTrans</sub> = 1.355 k  
Short side: P<sub>aLong</sub> = 1.594 k

[See table C3.4.1-2, fastened to support, two flange, end loading]

$P_n = Ct^2 F_y \sin(90) \left( 1 - C_R \frac{R}{t} \right) \left( 1 + C_N \frac{N}{t} \right) \left( 1 - C_h \frac{h}{t} \right)$

**O.K.** # clips = 3  
**O.K.** # clips = 2

### Check Web Stiffener

N/A  
width of stiffener = 7.000 in      t<sub>s</sub> = 0.0566 **16 Gauge**  
web of stiff. w = 6.717 in      R<sub>s</sub> = 0.0849 in  
\*\*\*Check w/ts ≤ 1.28VE/F<sub>y</sub>      Ω<sub>c</sub> = 1.70  
w/ts = 118.675  
1.28v(E/F<sub>y</sub>) = 31.091      --> w/ts over limit      Use C3.7.2  
P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>v</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>  
P<sub>wc</sub> = 5.907 k      A<sub>e</sub> = 0.380 in<sup>2</sup>  
P<sub>n</sub> = 17.441 k  
P<sub>n</sub>/Ω<sub>c</sub> = 10.259 k      Not Req'd

### Corner Connections

1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts  
T<sub>crnmax</sub> = 1173 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>nASDtrans</sub>/4 corner connections)  
V<sub>crnmax</sub> = 1599 lbs      (Max Ten/2 corner connections per side)  
Bolt: Tall = **2480** lbs      Vall = **1096** lbs  
Threaded Insert: Tall = **2860** lbs      Vall = **1714** lbs  
# of Bolts required for Tension = 0.5  
# of Bolts required for Shear = 1.5  
# of Bolts Used = **2.0**      \*\*\*If combined fails:      USE --> 3.0  
Check Combined Stress in Bolts & Inserts: 0.966 **O.K.**      StressComb = 0.644 **O.K.**

### Check 1/8" welded connection

<--- USE WELD      Ω = 2.35  
Assume L/t > 25: 25\*t = 3.105 in      P<sub>n</sub>/Ω =  $\frac{1}{\Omega} 0.75tLF_u \geq V_{req}$       L<sub>req'd</sub> =  $\frac{V_{req}\Omega}{0.75tF_u}$   
L<sub>req'd</sub> = 0.621 in




**Connection Unit to Curb Clip** #14 SMS screw  $\Omega = 3.0$   
 $t_1 = 0.1017$  in (clip thickness)  $F_{u1} = 65$  ksi  
 $t_2 = 0.1242$  in (unit base rail thickness)  $F_{u2} = 65$  ksi  
 $d = 0.242$  in (screw diameter)  $d_w = 0.500$  in (nom. washer diameter)

For  $t_2/t_1 \leq 1.0$ :  $P_{ns} = 4319 \#$  For  $t_2/t_1 \geq 2.5$ :  $P_{ns} = 4319 \#$   
**Shear:**  $P_{ns} = 4.2F_{u2}\sqrt{t_2^3 d}$   $5.88$  k  $P_{ns} = 2.7t_1 d F_{u1}$   $4.32$  k  
 $P_{ns} = 2.7t_2 d F_{u2}$   $5.27$  k  $P_{ns} = 2.7t_2 d F_{u2}$   $5.27$  k  
 $P_{ns}/\Omega = 1440 \#$   
**Tension:**  $P_{not} = 1.661$  k (screw pull-out strength)  $P_{not} = 0.85t_c d F_{u2}$   
 $P_{nov} = 4.958$  k (screw pull-over strength)  $t_c = \min(t_1, t_2)$   
 $P_{ts}/\Omega = 554 \#$  <- Controls  $P_{nov} = 1.5t_1 d_w F_{u1}$   
 $P_{ts}/\Omega = 1220 \#$  (full tensile screw capacity)

	Shear (k)	# clips	V <sub>clip</sub> (k)	V <sub>allow</sub> (lb)	# screws	spacing
Long side:	4.693	2	2.35	1045 #	4	2.00 in
Short side:	4.693	2	2.35	1045 #	4	2.00 in

clip width (in) = 7.00 clip height = 2.5 in  
 min spacing = 0.73 in edge distance = 0.5 in (min. 1.5d)

**Check Block shear rupture:** O.K.  
 $F_y = 50$  ksi  $\Omega = 2.22$  bolt/screw connection  
 $A_{gv} = 0.661$  in<sup>2</sup>  $A_{nt} = 0.115$  in<sup>2</sup>  
 $R_n/\Omega = 12.295$  k  $R_n = 0.6F_y A_{gv} + F_u A_{nt} \leq 0.6F_u A_{gv} + F_u A_{nt}$   
 BSR O.K. (AISI Sect. E5.3)



**Curb Loads** (copied from above)


Transverse: (on long edge)	Comp <sub>MAX</sub> = 4064 lbs
	Tens <sub>MAX</sub> = 3199 lbs
	Shear <sub>MAX</sub> = 2346 lbs
Longitudinal: (on short edge)	Comp <sub>MAX</sub> = 3188 lbs
	Tens <sub>MAX</sub> = 2322 lbs
	Shear <sub>MAX</sub> = 2346 lbs

**Loads at each Isolator** Type: JQB

Transverse loading: (on long edge)*	Comp <sub>MAX</sub> = 1016.1 lbs
	Tens <sub>MAX</sub> = 799.6 lbs
	Shear <sub>MAX</sub> = 335.2 lbs
Longitudinal loading: (on short edge)*	Comp <sub>MAX</sub> = 1062.7 lbs
	Tens <sub>MAX</sub> = 774.0 lbs
	Shear <sub>MAX</sub> = 335.2 lbs

Max compression force on isolator: 1.063 k  $\leq 1.600$  k O.K.  
 Max uplift on isolator: 0.800 k  $\leq 1.600$  k O.K.  
 Max shear on isolator: 0.335 k  $\leq 1.000$  k O.K.

\*each case utilizes half capacity of isolators at end of adjacent edge.



**Forces on top bolt:**

$d_b = 0.5$  in  
 upper rail,  $t = 0.1242$  in  
 Tension = 0.800 k  
 Shear = 0.335 k

Shear on curb rail:  $P_n = teF_u$   $\Omega = 2.00$  [Appendix A, Section E3.1 AISI]  
 $P_n/\Omega = 8.073$  k  $e = 1.0$  in  
 Shear O.K.

Net section rupture:  $P_n = A_n F_t$   $\Omega = 2.22$  [Appendix A, Section E3.2 AISI]  
 $P_n/\Omega = 10.293$  k  $A_n = 0.186$  in  
 N.S.R. O.K.  $F_t = (0.1 + 3d/s)F_u \leq F_u = 55.250$  ksi

Bolt Bearing Strength:  $P_n = C m_f d t F_u$   $\Omega = 2.50$  [Section E3.3.1 AISI]  
 $P_n/\Omega = 4.844$  k  $d/t = 4.03$   
 Bearing O.K.  $C = 3.00$   $m_f = 1.00$

**Shear and tension in bolt:** [Appendix A, Section E3.4 AISI]

Tension  $P_{nt} = A_b F_{nt}$   $F_{nt} = 45.0$  ksi  $A_b = 0.1963$  in<sup>2</sup>  
 $P_{nt}/\Omega = 3.927$  k Bolt tension O.K.  $\Omega t = 2.25$  [Table E3.4-1, AISI]  
 Shear  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega v = 2.40$  [Table E3.4-1, AISI]  
 $P_{nv}/\Omega = 2.209$  k Bolt shear O.K.

$F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_v = 1.71$  ksi O.K.  
 Combined Not Applicable  $F'_{nt} = 45.00$  ksi  $F_{nv}/\Omega = 11.25$  ksi




Client:	ProVent PV1908	Base curb
Project:	ISCAL-127 Iso Curb (ISCALPRD3715**)	
Unit:	ZT,ZJ,ZH,ZR037,049,061,ZF,ZH,ZJ,ZR,XP,DH,DM,DF,DR,BP078-150	

**Curb Information**

Hcurb =	24 in	(Height of curb)
Lcurb =	80.375 in	(Length of curb)
wcurb =	50.5 in	(Width of curb)
WGTcurb =	593 lbs	(Weight of curb)
# springs long side =	3	# springs short side = 2

**Unit Information**

WGTunit =	2095 lbs	(Weight of Unit)
Wtmax =	719 lbs	(Maximum corner weight)
Wtmin =	293 lbs	(Minimum corner weight)
Hunit =	50.75 in	(Height of unit above curb)
Hcm =	36.375 in	(Ht to ctr mass + 11")
Lunit =	119.5 in	(Length of unit)
Wunit =	59 in	(Width of unit)



**Seismic Loading - 2018 IBC/2019 CBC**

Ss =	2.000	(Conservative for majority of CA - Design Category D)
Fa =	1.000	(From Table 11.4-1 ASCE 7-16)
Sms =	2.000	(Fa*Ss)
Sds =	1.333	(2/3*Sms)
Ip =	1.50	(Importance Factor Category IV Building)
Fpmax =	3.200 Wp	(1.6*Sds*Ip)*Wp
FpmaxASD =	5053 lbs	(0.7*Fpmax)
FpmaxASD =	6021 lbs	(unit and curb)

(unit + upper curb only - from upper rail calc)

**Wind Loading - 2018 IBC/2019 CBC**

\*\*\* Exposure Category C \*\*\*

Kz =	1.13	(For 60 ft roof height, Exposure C - Table 29.3-1 ASCE 7-16)
Kzt =	1.0	(No topographic effects assumed for rooftop mounted units)
Kd =	0.85	(Directionality factor Table 26.6-1 ASCE 7-16)
V =	115	(Max wind velocity, mph for Cat III & IV bldgs Exp. Cat C)
GCr(horiz) =	1.9	(Refer Sect 29.5.1 ASCE 7-16)
GCr(vert) =	1.5	(Refer Sect 29.5.1 ASCE 7-16)
qz =	32.5 psf	= 0.00256*Kz*Kzt*Kd*V <sup>2</sup> (Eq. 29.3-1 ASCE 7-16)
Fh ASD trans =	2638 lbs	= 0.6*qz*GCr*Lunit*(Hunit+Hcurb) (Eq. 29.5-2)
Fh ASD long =	1302 lbs	= 0.6*qz*GCr*Wunit*(Hunit+Hcurb)
Fvert ASD =	1433 lbs	= 0.6*qz*GCr*Lunit*Wunit (Eq. 29.5-3)

**Curb Loading**

**Transverse:**

Compression <sub>SEISMIC</sub> =	5346 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S <sub>DS</sub> )*Wtmax*wcurb]/wcurb
Tension <sub>SEISMIC</sub> =	4480 lbs	= Comp <sub>SEISMIC</sub> - (0.6-0.14S <sub>DS</sub> )*WGTunit
Compression <sub>WIND</sub> =	2046 lbs	= [F <sub>h trans ASD</sub> *Hcm + 2*0.6*Wtmax*wcurb - F <sub>vert ASD</sub> *wcurb/2]/wcurb
Tension <sub>WIND</sub> =	2222 lbs	= Comp <sub>WIND</sub> + Fvert - 0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

**Longitudinal:**

Compression <sub>SEISMIC</sub> =	3993 lbs	= [FpmaxASD*Hcm + 2*(1+0.14S <sub>DS</sub> )*Wtmax*Lcurb]/Lcurb
Tension <sub>SEISMIC</sub> =	3128 lbs	= Comp <sub>SEISMIC</sub> - (0.6-0.14S <sub>DS</sub> )*WGTunit
Compression <sub>WIND</sub> =	736 lbs	= [F <sub>h trans ASD</sub> *Hcm + 2*0.6*Wtmax*Lcurb - F <sub>vert ASD</sub> *Lcurb/2]/Lcurb
Tension <sub>WIND</sub> =	912 lbs	= Comp <sub>WIND</sub> + Fvert - 0.6*WGTunit

---> Negative values indicate Compression load rather than Tension.

**Governing Reactions:**

<b>Transverse:</b>	Comp <sub>MAX</sub> = 5346 lbs	---> Along long edge of curb.
(on long edge)	Tens <sub>MAX</sub> = 4480 lbs	---> Along long edge of curb.
<b>Longitudinal:</b>	Comp <sub>MAX</sub> = 3993 lbs	---> Along short edge of curb.
(on short edge)	Tens <sub>MAX</sub> = 3128 lbs	---> Along short edge of curb.

---> Negative values indicate Compression load rather than Tension.




**Curb Design**

F<sub>y</sub> = 50 ksi      F<sub>u</sub> = 65 ksi      t = 0.0713 [14 Gauge]  
E = 29500 ksi

**Calculate Section Properties of Curb**

A' = 24.000 in	a = 23.644 in = A' - (2r+t)
B' = 1.750 in	a' = 23.929 in = A' - t
C' = 0.000 in [0 if no lips]	b = 1.572 in = B' - [r+t/2+α(r+t/2)]
α = 0.000 [0 - no Lip; 1 w/ lip]	b' = 1.714 in = B' - [t/2+αt/2]
R = 0.1069 [inside bend radius]	c = 0.000 in = α[C' - (r+t/2)]
t = 0.0713 in	c' = 0.000 in = α(C' - t/2)
r' = 0.143 in = R+t/2	u = 0.224 in = πr/2
x = 0.108 in (Distance between centroid and web centerline)	
I <sub>x</sub> = 115.211 in (Moment of Inertia about X-Axis)	
I <sub>y</sub> = 0.217 in (Moment of Inertia about Y-Axis)	
A = 1.94 in <sup>2</sup>	
r <sub>x</sub> = 7.70 in	
r <sub>y</sub> = 0.334 in	
r <sub>min</sub> = 0.334 in	



**Axial Compression**

P<sub>a</sub> = 2.527 k (Max Axial Comp)      Ω<sub>c</sub> = 1.80  
P<sub>n</sub>/Ω<sub>c</sub> = 8.927 k  
F<sub>e</sub> = 9.44 ksi       $\lambda_c = \sqrt{\frac{F_y}{F_e}}$        $F_e = \frac{\pi^2 E}{(kl/r)^2}$   
λ<sub>c</sub> = 2.30       $\frac{P_n}{\Omega_c} = \frac{F_n A}{\Omega_c}$       If λ<sub>c</sub> ≤ 1.5; F<sub>n</sub> = (0.658λ<sub>c</sub><sup>2</sup>) F<sub>y</sub>  
F<sub>n</sub> = 8.28 ksi      If λ<sub>c</sub> > 1.5; F<sub>n</sub> =  $\frac{0.877}{\lambda_c^2} F_y$   
L<sub>y</sub> = 73.38 in      Lateral unbraced length  
k<sub>y</sub>L<sub>y</sub>/r<sub>y</sub> = 176 (assume k=0.8)

**Compression Check = O.K.**

**Check Web Crippling**

h = 24 in	-- Check limits:	C = 4.00	} (See table C3.4.1-2, fastened to support, one flange, end loading)
t = 0.0713 in	h/t = 336.61 ≤ 200	C <sub>R</sub> = 0.14	
N = 7.00	N/t = 98.18 ≤ 210	C <sub>N</sub> = 0.35	
Ω <sub>w</sub> = 1.75	N/h = 0.291667 ≤ 2.0	C <sub>h</sub> = 0.02	
P <sub>n</sub> = 2.130 k	R/t = 1.50 ≤ 9.0		

P<sub>n</sub>/Ω<sub>w</sub> = 1.217 k       $P_n = Ct^2 F_y \sin(90) \left(1 - C_R \sqrt{\frac{R}{t}}\right) \left(1 + C_N \sqrt{\frac{N}{t}}\right) \left(1 - C_h \sqrt{\frac{h}{t}}\right)$

Long side: P<sub>aTrans</sub> = 1.782 k **web stiffener REQ'D** # clips = 3

Short side: P<sub>aLong</sub> = 1.997 k **web stiffener REQ'D** # clips = 2

**\*\*\*h/t > 200; use web stiffeners**

**Check Web Stiffener**

16Ga x 1.5in x 7in (C-channel)

width of stiffener = 7.000 in      t<sub>s</sub> = 0.0566 [16 Gauge]  
web of stiff. w = 6.717 in      R<sub>s</sub> = 0.0849 in  
\*\*\*Check w/t<sub>s</sub> ≤ 1.28√E/F<sub>y</sub>      Ω<sub>c</sub> = 1.70

w/t<sub>s</sub> = 118.675  
1.28√(E/F<sub>y</sub>) = 31.091 --> w/t<sub>s</sub> over limit Use C3.7.2

P<sub>n</sub> = 0.7(P<sub>wc</sub> + A<sub>e</sub>F<sub>y</sub>) ≥ P<sub>wc</sub>      A<sub>e</sub> = 0.380 in<sup>2</sup>  
P<sub>wc</sub> = 2.130 k  
P<sub>n</sub> = 14.798 k  
P<sub>n</sub>/Ω<sub>c</sub> = 8.704 k      **O.K.**

**Corner Connections**      1/4" φ SAE Grade 8 bolts w/ 1/4-20-UNC Threaded inserts

T<sub>crnmax</sub> = 1263 lbs      Max(F<sub>pmaxASD</sub>/4 -OR- F<sub>hASDtrans</sub>/4 corner connections)  
V<sub>crnmax</sub> = 2240 lbs      (Max Ten/2 corner connections per side)

Bolt: T<sub>all</sub> = 2460 lbs      V<sub>all</sub> = 1096 lbs  
Threaded Insert: T<sub>all</sub> = 2860 lbs      V<sub>all</sub> = 1714 lbs

# of Bolts required for Tension = 0.5  
# of Bolts required for Shear = 2.0  
# of Bolts Used = 3.0      \*\*\*If combined fails: USE --> 4.0

Check Combined Stress in Bolts & Inserts: 0.851 O.K.      StressComb = 0.638 O.K.






Check 1/8" welded connection <--- USE WELD  $\Omega = 2.35$   
 Assume  $L/t > 25$ :  $25*t = 1.783$  in  $P_n/\Omega = \frac{1}{\Omega} 0.75tLF_u \geq V_{req}$   $L_{req'd} = \frac{V_{req}\Omega}{0.75tF_u}$   
 $L_{req'd} = 1.515$  in

Curb Loads	
Transverse: (on long edge)	Comp <sub>MAX</sub> = 5346 lbs Tens <sub>MAX</sub> = 4480 lbs Shear <sub>MAX</sub> = 5053 lbs
Longitudinal: (on short edge)	Comp <sub>MAX</sub> = 3993 lbs Tens <sub>MAX</sub> = 3128 lbs Shear <sub>MAX</sub> = 5053 lbs

Loads at each Isolator		Type:	IQB
Transverse loading: (on long edge)*	Comp <sub>MAX</sub> = 1336.6 lbs Tens <sub>MAX</sub> = 1120.1 lbs		
# isolators: 4	Shear <sub>MAX</sub> = 361.0 lbs		
Longitudinal loading: (on short edge)*	Comp <sub>MAX</sub> = 1331.1 lbs Tens <sub>MAX</sub> = 1042.5 lbs		
# isolators: 3	Shear <sub>MAX</sub> = 361.0 lbs		

Max compression force on isolator: 1.337 k ≤ 1.600 k **O.K.**  
 Max uplift on isolator: 1.120 k ≤ 1.600 k **O.K.**  
 Max shear on isolator: 0.361 k ≤ 1.000 k **O.K.**

\*each case utilizes half capacity of isolators at end of adjacent edge.



**Forces on bottom bolts:**

$d_b = 0.625$  in  
 base curb,  $t = 0.0713$  in  
 Tension = 0.560 k / bolt  
 Shear = 0.180 k / bolt

**Shear on base curb:**  $P_n = t_e F_u$   $\Omega = 2.00$  (Appendix A, Section E3.1 AISI)  
 $P_n/\Omega = 4.635$  k  $e = 1.0$  in


**Net section rupture:**  $P_n = A_n F_t$   $\Omega = 2.22$  (Appendix A, Section E3.2 AISI)  
 $P_n/\Omega = 6.372$  k  $A_n = 0.098$  in

**Bolt Bearing Strength:**  $P_n = C m_f d t F_u$   $\Omega = 2.50$  (Section E3.3.1 AISI)  
 $P_n/\Omega = 3.476$  k  $d/t = 8.77$

**Shear and tension in bolt:** (Appendix A, Section E3.4 AISI)  
 $F_{nt} = 45.0$  ksi  $A_b = 0.3068$  in<sup>2</sup>  
 $P_{nt}/\Omega = 6.136$  k **Bolt tension O.K.**  $\Omega = 2.25$

**Shear:**  $P_{nv} = A_b F_{nv}$   $F_{nv} = 27.0$  ksi  $\Omega = 2.40$   
 $P_{nv}/\Omega = 3.451$  k **Bolt shear O.K.**  $\Omega = 2.40$

**Combined Not Applicable**  $F'_{nt} = 1.3F_{nt} - \frac{\Omega F_{nt}}{F_{nv}} f_v \leq F_{nt}$   $f_v = 0.59$  ksi  $F_{nv}/\Omega = 11.25$  ksi



**Connection of Curb to Supporting Structure**

Roof Loading	SEISMIC: (0.6-0.14SDS)D + 0.7E	WIND: 0.6D + W
Transverse:	Uplift <sub>MAX</sub> = 7682 lbs	Shear <sub>MAX</sub> = 3011 lbs
Compression <sub>SEISMIC</sub>	8793 lbs	= [F <sub>pmaxASD</sub> *(H <sub>cm</sub> +H <sub>curb</sub> )] + (1+0.14S <sub>DS</sub> )*(WGT <sub>unit+curb</sub> /2)*w <sub>curb</sub> /w <sub>curb</sub>
Tension <sub>SEISMIC</sub>	7682 lbs	= Comp <sub>SEISMIC</sub> - (0.6-0.14S <sub>DS</sub> )*(WGT <sub>unit+curb</sub> )
Compression <sub>WIND</sub>	3244 lbs	= [F <sub>htransASD</sub> *(H <sub>cm</sub> +H <sub>curb</sub> ) + 0.6*(WGT <sub>unit+curb</sub> /2)*w <sub>curb</sub> - F <sub>vertASD</sub> *w <sub>curb</sub> ]/w <sub>curb</sub>
Tension <sub>WIND</sub>	3064 lbs	= [F <sub>htransASD</sub> *(H <sub>cm</sub> +H <sub>curb</sub> ) - 0.6*(WGT <sub>unit+curb</sub> /2)*w <sub>curb</sub> + F <sub>vertASD</sub> *w <sub>curb</sub> ]/w <sub>curb</sub>
Longitudinal:	Uplift <sub>MAX</sub> = 5007 lbs	Shear <sub>MAX</sub> = 3011 lbs
Compression <sub>SEISMIC</sub>	6118 lbs	= [F <sub>pmaxASD</sub> *(H <sub>cm</sub> +H <sub>curb</sub> ) + (1+0.14S <sub>DS</sub> )*(WGT <sub>unit+curb</sub> /2)*L <sub>curb</sub> ]/L <sub>curb</sub>
Tension <sub>SEISMIC</sub>	5007 lbs	= Comp <sub>SEISMIC</sub> - (0.6-0.14S <sub>DS</sub> )*(WGT <sub>unit+curb</sub> )
Compression <sub>WIND</sub>	1068 lbs	= [F <sub>htransASD</sub> *(H <sub>cm</sub> +H <sub>curb</sub> ) + 0.6*(WGT <sub>unit+curb</sub> /2)*L <sub>curb</sub> - F <sub>vertASD</sub> *L <sub>curb</sub> ]/L <sub>curb</sub>
Tension <sub>WIND</sub>	888 lbs	= [F <sub>htransASD</sub> *(H <sub>cm</sub> +H <sub>curb</sub> ) - 0.6*(WGT <sub>unit+curb</sub> /2)*L <sub>curb</sub> + F <sub>vertASD</sub> *L <sub>curb</sub> ]/L <sub>curb</sub>

Wood Attachment:	1/4" φ x 4.5" Simpson SDS screw w/ 2.75" threaded emt (SGmin = 0.43)	
Transverse:	Tall <sub>metal</sub> = 946.67 lbs	Vall <sub>metal</sub> = 1043.33 lbs
	Tall <sub>wood</sub> = 760 lbs	Vall <sub>wood</sub> = 672 lbs
# of Screws Req'd for Uplift =	10.11	COMBINED LOADING: 0.858 O.K.
# of Screws Req'd for Shear =	4.48	Req'd Min Spacing = 4.5 in o.c.
Total # of screws required =	17	

Use 17 - 1/4" φ x 4.5" Simpson SDS screws @ 4.5 in o.c. along long side of curb w/ 2.75" threaded embed



Longitudinal:

# of Screws Req'd for Uplift = 6.59  
# of Screws Req'd for Shear = 4.48  
Total # of screws required = 12

COMBINED LOADING: 0.922 O.K.  
Screw Spacing = 3.9 in o.c.

Use 12 - 1/4" φ x 4.5" Simpson SDS screws @ 3.9 in o.c. along short side of curb w/ 2.75" threaded embed

Steel Deck Attachment: 1/2" φ A307 Bolts to steel angle below deck

Tall<sub>bolt</sub> = 6903 lbs  
Transverse: 6903 lbs

Vall<sub>bolt</sub> = 3682 lbs  
3682 lbs  
COMBINED LOADING: 0.965 O.K.  
Bolt Spacing = 68.4 in o.c.

# of Bolts Req'd for Uplift = 1.11  
# of Bolts Req'd for Shear = 0.82  
Total # of bolts required = 2

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 68.4 in o.c. along long side of curb

Longitudinal:

# of Bolts Req'd for Uplift = 0.73  
# of Bolts Req'd for Shear = 0.82  
Total # of bolts required = 2

COMBINED LOADING: 0.772 O.K.  
Bolt Spacing = 38.5 in o.c.

Use 2 - 1/2" φ A307 Bolts to steel angle below deck @ 38.5 in o.c. along short side of curb

For Concrete anchorage: SEISMIC (0.6-0.14SDS)D + 0.7Ω<sub>o</sub>E (Ω<sub>o</sub> = 2.5)

Concrete Attachment: 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed

Tall<sub>LRFD</sub> = 1919 lbs Vall<sub>LRFD</sub> = 3188 lbs α = (1 + 0.2SDS)D + 2.5E = 1.87  
Tall<sub>ASD</sub> = Tall<sub>LRFD</sub>/α = 1026.2 lbs Vall<sub>ASD</sub> = Vall<sub>LRFD</sub>/α = 1704.8 lbs (D = 0.465, E = 0.535)

Transverse: Uplift<sub>MAX</sub> = 18480 lbs Shear<sub>MAX</sub> = 7526 lbs

Compression<sub>SEISMIC</sub> = 19591 lbs = [2.5\*FpmaxASD\*(Hcm+Hcurb)+(1+0.14SDS)\*(WGT<sub>unit+curb</sub>/2)\*wcurb]/wcurb

Tension<sub>SEISMIC</sub> = 18480 lbs = Comp<sub>SEISMIC</sub> - (0.6-0.14SDS)\*(WGT<sub>unit+curb</sub>)

Shear<sub>SEISMIC</sub> = 7526 lbs = 2.5\*FpmaxASD/2

Min Bolts Req'd Uplift = 18.01 spacing = 3.13 in o.c. T<sub>applied</sub> = 972.6 lbs

Min Bolts Req'd Shear = 4.41 spacing = 14.09375 in o.c. V<sub>applied</sub> = 396.1 lbs

Try using 19 bolts spaced at 3.80 in o.c. COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.18$

Use 19 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 3.8 in o.c. max. along long side of curb w/ 4" embed

Longitudinal: Uplift<sub>MAX</sub> = 11791 lbs Shear<sub>MAX</sub> = 7526 lbs

Compression<sub>SEISMIC</sub> = 12902 lbs = [2.5\*FpmaxASD\*(Hcm+Hcurb)+(1+0.14SDS)\*(WGT<sub>unit+curb</sub>/2)\*Lcurb]/Lcurb

Tension<sub>SEISMIC</sub> = 11791 lbs = Comp<sub>SEISMIC</sub> - (0.6-0.14SDS)\*(WGT<sub>unit+curb</sub>)

Shear<sub>SEISMIC</sub> = 7526 lbs = 2.5\*FpmaxASD/2

Min Bolts Req'd Uplift = 11.49 spacing = 3.5 in o.c. T<sub>applied</sub> = 842.2 lbs

Min Bolts Req'd Shear = 4.41 spacing = 9.625 in o.c. V<sub>applied</sub> = 537.6 lbs

Try using 14 bolts spaced at 2.96 in o.c. COMBINED LOADING =  $\frac{T_{applied}}{T_{allow,ASD}} + \frac{V_{applied}}{V_{allow,ASD}} \leq 1.2 = 1.14$

Use 14 - 3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy @ 3 in o.c. max. along short side of curb w/ 4" embed

CURB DESIGN SUMMARY: ISCAL-127 (ISCALPRD3715**)			
UPPER CURB TUBE THICKNESS: 0.1242 in 10 Gauge		Unit: ZT,ZI,ZH,ZR037,049,061; ZF,ZH,ZI,	
UNIT CLIP THICKNESS: 0.1017 in 12 Gauge		ZR,XP,DH,DM,DF,DR,BP 078-150	
# OF CLIPS (LONG SIDE) - 2 clips with 4 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED FOR UPPER TUBE			
# OF CLIPS (SHORT SIDE) - 2 clips with 4 - #14 SMS screws each clip			
WEB STIFFENER: NOT REQUIRED FOR UPPER TUBE			
VIBRATION ISOLATOR TYPE: JQB		Top stud diameter: 1/2	
Anchor bolt diameter: 5/8		Anchor hole diameter: 11/16	
BASE CURB THICKNESS: 0.0713 in 14 Gauge			
WEB STIFFENER: 16Ga x 1.5in x 7in (C-channel) stiffener at each clip on base curb			
CORNER CONNECTION: Use minimum 1/8" welded connection			
CURB ANCHORAGE	WOOD	STEEL	CONCRETE
	1/4" φ x 4.5" Simpson SDS screws w/ 2.75" threaded embed	1/2" φ A307 Bolts to steel angle below deck	3/4" φ thrd'd rods in Hilti Hit-HY 200 epoxy w/ 4" embed
LONG DIRECTION	17 @ 4.52 in o.c.	2 @ 68.38 in o.c.	19 @ 3.8 in o.c.
SHORT DIRECTION	12 @ 3.86 in o.c.	2 @ 38.5 in o.c.	14 @ 2.96 in o.c.