For wood, concrete and steel EST. В PROVENT P/N Α attachment see Roof Anchorage **VIBRATION ISOLATION ROOF CURBS FOR YORK UNITS** WEIGHT Detail, Form No. CB-62. CBISLXS18** 8" 18" 153 Lbs. **FEATURES** PG3E, PC3E, PCG4A, PCE4A 24-42 CBISLXS21** 11" 21" 171 Lbs. PCG6A, PCE6A, PHE4/6A, PHG4/6A 24-30 Roof curbs sides and ends are CBISLXS24** 14" 24" 189 Lbs. galvanized steel. *Upper shell weight 99 Lbs. Fully welded construction. **Note: Spring configuration must be added to part number at time of order. See Price Guide for details. Gasketing package provided. Heat treated wood nailer provided. 31" O.D. Insulated deck pans provided. 29" I.D. 46 1/2" O.D. 44 1/2" I.D. Pitched curbs and taller curbs are available. **NOTES** Attach ductwork to roof curb. Flanges of duct rest on top of the curb, Support ductwork below the curb. 44 1/2" I.D. 14GA UPPER RAIL RTU BASE RAIL B" Total Height OSA ISOLATOR RESTRAINTS (1) PER EACH SIDE FULL PERIMETER 50 1/2" O.D. A" Base Height WOOD NAILER 35" O.D. CURB **PROFILE DETAIL EXPLODED DETAIL** SUBMITED TO: FORM NO: **PART NUMBER:** ProVent 3847 WABASH DRIVE COMPANY: ___ **CBIS-119 CBISLXS SERIES** MIRA LOMA, CA 91752 JOB NAME: __ DATE: REV: DRAWN BY: PHONE (951) 685-1101 EQUIPMENT: 1/13/2025 2 **CNG** FAX (619) 872-9799 NOTES: